



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

October 14, 1982

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-023/03L-0
ER 100450 FILE 841-23
PLA-1348

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-023/03L-0. This event was determined to be reportable, per Technical Specification 6.9.1.9.b, in that, three SRV's acoustic monitors failed to operate correctly during the initial SRV steam test.

H.W. Keiser
Superintendent of Plant-Susquehanna

DGM/cw

Attachment

cc: A. Schwencer
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

82102503815

1E22