



Florida Power

CORPORATION

Crystal River Unit 3

Docket No. 50-302

June 8, 1994
3F0694-10

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Monthly Operating Report

Dear Sir:

Attached is the Crystal River Unit-3 May 1994 Monthly Operating Report. This report is submitted in accordance with Technical Specification 5.7.1.2.

Sincerely,

G. L. Boldt
Vice President
Nuclear Production

GLB/JLB:ff

Attachment

xc: Regional Administrator, Region II
Senior Resident Inspector
NRR Project Manager

150081

CRYSTAL RIVER ENERGY COMPLEX: 15760 W Power Line St • Crystal River, Florida 34428-6708 • (904) 795-6486

A Florida Progress Company

9406150300 940531
PDR ADOCK 05000302
R PDR

IE24
11

OPERATING DATA REPORT

DOCKET NO.	50-302
UNIT	FLCRP-3
DATE	JUNE 2, 1994
COMPLETED BY	Raleigh Smith
TELEPHONE	(904) 795-6486

OPERATING STATUS

1. UNIT NAME:.....	CRYSTAL RIVER UNIT 3
2. REPORTING PERIOD:.....	MAY
3. LICENSED THERMAL POWER (MWt):.....	2544
4. NAMEPLATE RATING (GROSS MWe):.....	890
5. DESIGN ELECTRICAL RATING (NET MWe):.....	825
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe):..	860
7. MAXIMUM DEPENDABLE CAPACITY (NET MWe):.....	818

8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWe):	N/A
10. REASONS FOR RESTRICTIONS, IF ANY:	N/A

	THIS MONTH	YR. TO DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	744.0	3,623.0	150,935.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	0.0	2,306.3	100,272.3
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	1,280.6
14. HRS GENERATOR ON LINE	0.0	2,304.8	98,496.9
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWH)	0	5,742,770	226,884,177
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	0	1,966,498	77,487,372
18. NET ELECTRICAL ENERGY GENERATED (MWH)	0	1,876,733	73,586,942
19. UNIT SERVICE FACTOR	0.0%	63.6%	65.3%
20. UNIT AVAILABLE FACTOR	0.0%	63.6%	65.3%
21. UNIT CAPACITY FACTOR (using MDC net)	0.0%	63.3%	60.5%
22. UNIT CAPACITY FACTOR (using DER net)	0.0%	62.8%	59.2%
23. UNIT FORCED OUTAGE RATE	0.0%	0.0%	17.0%

24. SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, AND DURATION OF EACH):

REFUEL 9 BEGAN 4/7/94 WITH A PROJECTED DURATION OF 60 DAYS.

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:	6/6/94
---	--------

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):

THIS ITEM IS NOT APPLICABLE TO CR-3

	FORECAST	ACHIEVED
INITIAL CRITICALITY	NA	NA
INITIAL ELECTRICITY	NA	NA
COMMERCIAL OPERATION	NA	NA

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	50-302
UNIT	FLCRP-3
DATE	JUNE 2, 1994
COMPLETED BY	Raleigh Smith
TELEPHONE	(904) 795-6486

MONTH MAY

DAY AVERAGE DAILY POWER LEVEL
 (MWe-Net)

1	0
2	0
3	0
4	0
5	0
6	0
7	0
8	0
9	0
10	0
11	0
12	0
13	0
14	0
15	0
16	0

DAY AVERAGE DAILY POWER LEVEL
 (MWe-Net)

17	0
18	0
19	0
20	0
21	0
22	0
23	0
24	0
25	0
26	0
27	0
28	0
29	0
30	0
31	0

INSTRUCTIONS:

On this format, list the daily average unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH: MAY

DOCKET NO.	<u>50-302</u>
UNIT	<u>FLCRP-3</u>
DATE	<u>JUNE 2, 1994</u>
COMPLETED BY	<u>Raleigh Smith</u>
TELEPHONE	<u>(304) 795-6486</u>

NO.	DATE	TYPE (1)	DURATION HOURS	REASON (2)	METHOD OF SHUTTING DOWN REACTOR (3)	LICENSEE EVENT REPORT #	SYSTEM CODE (4)	COMPONENT CODE (5)	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
94-05	940531	S	744	C	1	N/A	ZZ	ZZZZZZ	Continuation of Refuel 9.

1
 F - FORCED
 S - SCHEDULED

2
 REASON:
 A-EQUIPMENT FAILURE
 B-MAINTENANCE OR TEST
 C-REFUELING
 D-REGULATORY RESTRICTION
 E-OPERATOR TRAINING &
 LICENSE ADMINISTRATION
 F-ADMINISTRATION
 G-OPERATIONAL ERROR
 (EXPLAIN)
 H-OTHER

3
 METHOD
 1-MANUAL
 2-MANUAL SCRAM
 3-AUTO SCRAM
 4-CONTINUED
 5-REDUCED LOAD
 9-OTHER

4
 EXHIBIT G - INSTRUCTIONS
 FOR PREPARATION OF DATA
 ENTRY & STS FOR LICENSEE
 EVENT REPORT (LER) FILE
 (NUREG-0181)

5
 EXHIBIT I - SAME SOURCE

MONTHLY OPERATIONAL SUMMARY STATEMENT

DOCKET NO.	<u>50-302</u>
UNIT	<u>FLCRP-3</u>
DATE	<u>JUNE 2, 1994</u>
COMPLETED BY	<u>Raleigh Smith</u>
TELEPHONE	<u>(904) 795-6486</u>

MONTH: MAY

SUMMARY STATEMENT:

Crystal River Unit # 3 continues in Refuel 9.