NRC FORM 366 (12-81)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

APPROVED BY OMB 3150-0011 EXPIRES 4-30-82

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | SCVCS1 (2) | 00-00000-00 (3) | 41000 (4) | (5)
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T
01 | REPORT SOURCE L (6) | 050003958 (7) | 031883 (8) | 041583 (9)
DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On March 18, 1983, with the Plant in Mode 3, the Main Control Board temperature
03 indication (TE-413) for Reactor Coolant Outlet Temperature - T_{HOT} (Wide Range)
04 began to exhibit erratic indications. The channel was declared inoperable at 1100
05 hours in accordance with Action Statement (a) of Technical Specification 3.3.3.6.
06 There were no adverse consequences since the redundant Post Accident Monitoring
07 instrumentation channel remained operable.
08

09 SYSTEM CODE: ID (11) | CAUSE CODE: E (12) | CAUSE SUBCODE: E (13) | COMPONENT CODE: INSTRU (14) | COMP. SUBCODE: E (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 83 | — | SEQUENTIAL REPORT NO. 027 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN: C (18) | FUTURE ACTION: Z (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0000 | ATTACHMENT SUBMITTED: Y (23) | NPRD-4 FORM SUB.: N (24) | PRIME COMP. SUPPLIER: A (25) | COMPONENT MANUFACTURER (26): P427

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cause of the erratic indications is attributed to a varying resistance between
11 the compensated lead and low side resistance leg of TE-413. The temperature
12 element was replaced, and the channel returned to operable status at 1730 hours
13 on March 26, 1983. The licensee plans no additional action in regards to this
14 event unless warranted by similar failures in the future.

15 FACILITY STATUS: D (28) | % POWER: 000 (29) | OTHER STATUS (30): N/A | METHOD OF DISCOVERY: A (31) | DISCOVERY DESCRIPTION (32): Operator Observation

16 ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): N/A | LOCATION OF RELEASE (36): N/A

17 PERSONNEL EXPOSURES NUMBER: 000 (37) | TYPE: Z (38) | DESCRIPTION (39): N/A

18 PERSONNEL INJURIES NUMBER: 000 (40) | DESCRIPTION (41): N/A

19 LOSS OF OR DAMAGE TO FACILITY TYPE: Z (42) | DESCRIPTION (43): N/A

8304260232 830415
PDR ADOCK 05000395
S PDR

20 PUBLICITY ISSUED: N (44) | DESCRIPTION (45): N/A

NRC USE ONLY

NAME OF PREPARER: C. J. McKinney (signature) C. J. McKinney

PHONE: (803) 345-5209