

TABLE 2
MAPLHGR (KW/FT) LIMITS

Planar Average Exposure (MWD/STM)	Reload Modified F	Reload F	Reload G	Reload G-1U	Reload G-3/G-4/H-1	Reload H-2	Reload H-3
0	-	-	-	-	7.21	7.0	6.77
200	9.5	9.4	-	-	-	-	-
360	-	-	-	-	7.62	-	-
1,000	-	-	-	-	7.95	7.8	7.56
1,630	-	-	-	7.56	7.81	-	-
3,810	-	-	-	7.57	-	-	-
3,900	-	-	-	-	7.65	-	-
5,000	9.9	9.7	-	-	-	-	-
6,440	-	-	7.28	-	-	-	-
6,620	-	-	-	7.50	7.48	7.48	7.48
10,000	9.9	9.7	-	-	-	-	-
12,880	-	-	7.17	-	-	-	-
13,520	-	-	-	-	7.49	-	-
13,610	-	-	-	7.56	-	-	-
15,000	9.8	9.6	-	-	-	-	-
19,050	-	-	7.11	-	-	-	-
20,000	8.7	8.6	-	-	-	-	-
20,320	-	-	-	-	7.56	7.56	7.56
20,870	-	-	-	7.78	-	-	-
24,580	-	-	6.84	-	-	-	-
25,000	8.4	8.3	-	-	-	-	-
26,400	-	-	-	-	7.32	7.32	7.32
26,760	-	-	-	7.64	-	-	-
28,210	-	-	6.08	-	-	-	-
30,000	7.4	7.3	-	-	-	-	-
31,210	-	-	-	-	6.73	6.73	6.73
32,000	7.0	6.9	-	-	-	-	-
33,020	-	-	-	7.12	-	-	-
33,380	-	-	-	-	6.69	6.69	6.69
34,000	6.5	6.5	-	-	-	-	-
34,470	-	-	5.73	-	-	-	-
36,000	6.2	6.1	-	-	-	-	-
36,290	-	-	5.73	-	-	-	-