

LICENSEE EVENT REPORT

CONTROL BLOCK: [] [] [] [] [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[0][1] C A S O S 2 [2] 0 0 0 - 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 1 [4] [] [] [] (5) LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T [0][1] REPORT SOURCE [L][6] 0 5 0 0 0 3 6 1 [7] 0 7 1 1 0 8 2 [8] 0 4 1 1 2 8 3 [9] DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCE

[0][2] With the plant in Mode 4 and following maintenance on reactor Trip Circuit Breakers [0][3] (TCB's) 4, 6, and 7, independent verification of their undervoltage trip mechanism [0][4] operability was not performed in accordance with Technical Specification Surveillance [0][5] Requirement 4.3.1.1. Public health and safety were not affected, since the operation [0][6] of the shunt trip feature had been demonstrated to be operable and would have per- [0][7] formed the trip function, if required. Additionally, the unit had not achieved initial [0][8] criticality at this time. (See also LER's 82-175, 83-019, and 83-023 [Docket 50-362])

[0][9] SYSTEM CODE [I][A] [11] CAUSE CODE [A] [12] CAUSE SUBCODE [C] [13] COMPONENT CODE [Z][Z][Z][Z][Z][Z] [14] COMP. SUBCODE [Z] [15] VALVE SUBCODE [Z] [16] LER/RO REPORT NUMBER [17] EVENT YEAR [8][2] SEQUENTIAL REPORT NO. [1][7][6] OCCURRENCE CODE [0][1] REPORT TYPE [T] REVISION NO. [0] ACTION TAKEN [E] FUTURE ACTION [G] EFFECT ON PLANT [Z] SHUTDOWN METHOD [Z] HOURS [0][0][0][0] ATTACHMENT SUBMITTED [N] NPRD-4 FORM SUB. [N] PRIME COMP. SUPPLIER [N] COMPONENT MANUFACTURER [Z][9][9][9]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

[1][0] The cause of this event was personnel oversight in not performing appropriate testing [1][1] following maintenance. The undervoltage trip mechanisms were tested, adjusted, and [1][2] TCB's 4, 6, and 7 were returned to service on July 12, 1983. The maintenance program [1][3] has been revised to assure proper restoration testing following maintenance. [1][4] Additionally, corrective action will be described in separate correspondence.

[1][5] FACILITY STATUS [B] % POWER [0][0][0] OTHER STATUS [N/A] METHOD OF DISCOVERY [B] DISCOVERY DESCRIPTION [32] Review of Maintenance Records

[1][6] ACTIVITY CONTENT [Z] RELEASED OF RELEASE [Z] AMOUNT OF ACTIVITY [N/A] LOCATION OF RELEASE [N/A]

[1][7] PERSONNEL EXPOSURES NUMBER [0][0][0] TYPE [Z] DESCRIPTION [N/A]

[1][8] PERSONNEL INJURIES NUMBER [0][0][0] DESCRIPTION [N/A]

[1][9] LOSS OF OR DAMAGE TO FACILITY TYPE [Z] DESCRIPTION [N/A] 8304260257 830412 PDR ADOCK 05000361 S PDR

[2][0] PUBLICITY ISSUED [N] DESCRIPTION [N/A]