

April 8, 1994

U.S. Nuclear Regulatory Commission Mr. Thomas Scarbrough Mail Stop 7E23 OWFN Washington, DC 20555-0001

Enclosed are the following documents requested during the April 7, 1994 conference call regarding Callaway's GL 89-10 closure document.

- RFR-8746I Verify the Thrust Requirements for MOV's Using Grouping Reference Question No. 8
- Graph titled "Measured Coefficients of Friction for Rising Steam Valves".
 Reference Ouestion No. 5.3

We are also gathering further information to support discussions regarding questions numbers 3, 7 and 12.

Please contact me if you need additional information.

Mark Reidmeyer QA Engineer

314-676-4306

MAR/tmw

Enclosures

cc: NRCI 94002

S. H. Reed, UENE MOV Engineer

314-676-8540

D. E. Shafer, UE Licensing

1,40043

DF01

REPORT: NERP8171 UNION ELECTRIC COMPANY DATE: 01/21/94
PAGE: 1 REQUESTS FOR RESOLUTION SYSTEM TIME: 15:47 RFR TRAVELER SHEET

RFR NUMBER: 8746 I

RFR SUMMARY: VERIFY THE THRUST REQ'T FOR MOV'S USING GROUPING

DRAWING CHANGES REQUIRED: N TEXT CHANGES REQUIRED: N

LIR: Y DIR: N NSE: N

ATTACHMENT	PAGES	A.	TTACHMEN	NT	PAGES
DETERMINATION OF THRUST VALUES ATTACHMENT 2 ATTACHMENT 6 ATTACHMENT 8 TO: SHE		ATTACHMENT ATTACHMENT ATTACHMENT ATTACHMENT /-2/-94	3 5 7 9 FROM:	Pau SHR	2 2 11 13 4
NOTES: No remaining	ng a	elin	1-2-	1-94 hab	

REPORT: NERP8161

PAGE : 1

UNION ELECTRIC COMPANY REQUESTS FOR RESOLUTION SYSTEM

RER PRINT

RFR#: 8746 REV: 1

DATE: 04/06/94 TIME: 10:05

FILE CODE: E170.0102

BED MINEED	REV	STATUS	STATUS	PRI	PRIORITY	CATEGORY						SYS	TEMS				
RFR NUMBER	REY	STATUS	******		*****		0.00				***			***			
8746	1	90	19940124	10	19931213	M V	AL	BB	BG	EN	LF	EJ	BN	EG	EM	EP	
							KA	KC									

ALARA:

NPDES: N PERSONNEL SAFETY CONCERN: N

BUILDINGS:

PLAN PGMS:

MV

IT II CO CO TO A	753000
BHV0015	BB
BHV8037B	BBH
BPV8702A	BBF
3GHV8112	BG
3NHV0004	BN
EGHV0013	EG
JHV8811B	EMI

COMPONENTS : ALHVOO34 ALHVOO35 HV0016 HV8351A

PV87028 HVB109 HV8812A HV0014 HV8807A ENHV0012

ALHV0036 BBHV8000A

BBHV8351B EJHV8701A BGLCV01128 BNHV88128 EGHV0062 EMHV8807B

ENHV0015

EJHV8701B BGLCV0112C EGHV0011 EGHV0132 ENHVO001 ENHV0016

BBHV0013

BBHV8000B

BBHV8351C

B8HV0014 BBHV8037A BBHV8351D BGHVB100 BNHV0003

EGHV0012 EJHY8811A ENHV0006 EPHV8808A

KEYWORDS : SETPOINTS

ENHVD007

REFERENCES : RFR 010324A

RFR 0053531 CALC ZZ-117

CORR ULNRC 1755

RFR 008746C

SUPPLEMENTS:

RFR 0087460 0 0

SUPPLEMENTED BY:

SUPERSEDES: 9878 A 9878 B

SUPERSEDED BY:

RFR SUMMARY: VERIFY THE THRUST REQ'T FOR MOV'S USING GROUPING

FULL DESC:

THE MOV'S REFERENCED ARE MOV'S THAT HAVE HAD THRUST REQUIREMENTS TO ENSURE OPERABILITY UNDER DESIGN BASIS CONDITIONS DETERMINED USING INFORMATION FROM SIMILAR VALVES, THAT HAVE BEEN DP TESTED. THE THRUST REQUIREMENTS FOR THE MOV'S THAT HAVE NOT BEEN DP TESTED MAY NEED TO BE REVISED AS THE THRUST REQUIREMENTS FOR THE VALVES THAT HAVE BEEN DP TESTED HAVE RECENTLY BEEN RECALCULATED USING CLOSE CALIBRATION

TECHNIQUES.

R3370087461

008746 1

REPORT: NERP8161 PAGE : 2

UNION ELECTRIC COMPANY REQUESTS FOR RESOLUTION SYSTEM RFR PRINT

RFR#: 8746 REV: 1

DATE: 04/06/94 TIME: 10:05

FILE CODE: E170.0102

PROPOSED RES: DETERMINE REVISED THRUST REQUIREMENTS FOR THOSE MOV'S THAT HAVE BEEN SET

UP USING INFORMATION FROM OTHER MOV'S THAT HAVE BEEN DP TESTED. ALSO, DETERMINE IF THERE ARE OTHER MOV'S THAT SHOULD HAVE THRUST REQUIRMENTS

DETERMINED USING THIS METHOD VERSUS THE MOVATS DP DATA BASE.

CLOSURE DESC: The scope of this rfr has been expanded from what was first requested

in this rfr. Instead of only evaluating those mov's whose thrust requirements were previously determined from the grouping of other mov's do tested at callaway the thrust requirements for all mov's not do tested to the criteria of edp-zz-01114 were re-evalauted. Some of these mov's previously had thrust requirements based on the movats dp data base, calculations or grouping of mov's dp tested at callaway. It is intended that this rfr will supercede all of these other

evaluations and provide the final thrust requirements that will be used for generic letter 89-10. The dp thrust values previously provided by

the movets dp data base (calc zz-117) will be voided (CATS

41501 will track this action). The revised thrust values from this RFR are summarized on Attachment 4. Note that some of these thrust requirements are commercial values. In addition, the present minimum available thrust from the most recent MOVATS test was compared with the new thrust requirements being developed in this RFR and also

RFR 8746G. This was also done for rev G but was not documented. For traceability this review is being included with this RFR. No operability concerns have been identified with the present setup of

any safety related MOV with an active safety function.

COMMENTS: also covered in this rfr are the following mov's

> emb v8924 ephv8808b,c,d kahv0030 kchv0253

lffv0095 and lfhv0105&106

efpdv0019 and 20

**** APPROVALS/SIGNATURES SECTION *****

DRIGINATOR: WINK ROGER C ORIG SUPERVISOR:

HEINLEIN DAVID E MCGRAW JOHN A

MAXWELL DANIEL J

DES. SUPV. ENG: RESP SUPV. ENG: HEINLEIN DAVID E

RESP INDIVIDUAL DISP: WINK ROGER C REED STEVEN H QUALIFIED REVIEWER: SUPV ENG REVIEW: HEINLEIN DAVID E

PLANT MGR MINOR MOD:

ORC MEETING NBR:

ORIG DEPT HEAD:

ORIG DATE:

19931210 ORIG. DEPT: NESM

APPROV DATE: 19931213 APPROV DATE: 19931213

DEPT: NESM

FORECAST DATE: 19940107 QR DATE: 19940122 REVIEW DATE: 19940124

APPROVAL DATE:

ORC ACCEPTABLE:

REPORT: NERP8161 PAGE : 3

UNION ELECTRIC COMPANY REQUESTS FOR RESOLUTION SYSTEM

RFR PRINT

RFR#: 8746 REV: 1 FILE CODE: E170.0102

DATE: 04/06/94 TIME: 10:05

**** ATTACHMENTS SECTION ****

NUCLEAR SAFETY EVALUATION: N LICENSING IMPACT REVIEW: Y DESIGN IMPACT REPORT: N

ATTACHMENT		PAGES	A	TTACHMENT	PAGES	ATTACHMENT	PAGES

DETERMINATION OF THRUST	VALUES	14	ATTACHMENT	1.	2	ATTACHMENT 2	2
ATTACHMENT 3		2	ATTACHMENT	4	4	ATTACHMENT 5	11
ATTACHMENT 6		3	ATTACHMENT	7	13	ATTACHMENT 8	74
ATTACHMENT 9		4			0		0
CL	ACS	VALID	UPDATE	WOT_/			
DRAW/DOC NUMBER	1	DOCCNTL	RESP	RECEIPT	UPDATED	RESPONSIBLE INDIVIDUAL	
		*****	*****	****	***		

**** END OF REPORT ***

LICENSING IMPACT REVIEW

1)	This review is applicable to RFR 87462
,	IN ANSWERING THE FOLLOWING QUESTIONS, REFER TO ATTACHMENT 4 OF APA-ZZ-00140.
2)	10CFR 50 59 APPLICABILITY
2.1)	No Formal Safety Evaluation Required. (Refer to Attachment 4 of APA-ZZ-00140, justify your findings in Section 7, and proceed to Section 3)
(2.2)	Outside Safety Evaluation (Attach CA-#1340 and proceed to Section 3)
(2.3)	SAFETY EVALUATION SCREENING
(2.3.1)	Ves No A proposed change to the facility as described in the FSAR?
	Yes No A change to procedures as described in the FSAR?
(2.3.2)	Yes No A test or experiment not described in the FSAR?
(2.3.3)	Yes No A change to the Technical Specifications? It is answered "Yes", complete a Formal Safety Evaluation per APA-ZZ-00140. If the strength of the Section 7.0 to provide a written evaluation why an Unreviewed Safety Question does
not exist.	hanges to the FSAR or Technical Specifications require additional processing in accordance with
A	PA-22-00106
(3)	EQUIPMENT QUALIFICATION IMPACT REVIEW
	Does this modification/change involve:
(3.1)	Does this modification change. An activity which involves any safety-related structure, system, equipment, or component?
	If no, then mark questions 3.2 through 3.8 "N/A" and proceed to question 3.9.
(3.2)	Yes No N/A Installation of a new or modification to an existing system, subsystem, subsystem equipment or component involving the issuance of a new design specification and/or the assignment of new equipment tag numbers?
	If yes, then mark question 3.3 "N/A" and proceed to question 3.4.
(3.3)	Yes No NA NA MELB Category A or B in FSAR Table 3.11(B)-3)
	If no, then mark questions 3.4 through 3.6 "N/A" and proceed to question 3.7.

Page 1 of 8

CA-#1339 08-26-93 APA-ZZ-00140

2933

(3.4)	Yes	garden.	No _		N/A	_	For equipment or component changes to items identified as being required to function in a harsh post accident environment (i.e., LOCA, MSLB, or HELB Category A or B in FSAR Table 3.11(B)-3), a change in organic (soft) parts from those specified for the existing equipment or component (e.g., O-rings, packing, paskets, active or pressure boundary rubber/plastic parts, insulation, etc.)?
(3.5)	Yes	-	No .	-	N/A	_	Relocation of existing equipment or installation of new equipment such that submergence after an accident is an issue (compare intended location against FSAR Table 3.6-6)?
(3.6)	Yes		No .	-	N/A	_	For equipment or component changes, a change in performance characteristics that could impact safety functions (e.g., changes in instrument accuracy)?
(3.7)	Yes	_	No .	1	N/A	ante	For equipment or component changes, a significant change in size, mass, orientation, mounting, or center of gravity from that of the existing configuration (e.g., a valve mass change of more than 20% or 20 lbs., per the guidance of EPRI-NP-5639)?
(3.8)	Yes	-	Nu	1	N/A	-	For equipment or component changes, a change to internal parts that may impact Seismic Qualification?
(3.9)	Yes	and a	No	<u> </u>			A change such that the containment spray system could cause the pH of the delivered spray to be outside the range of 4.0 to 11.07
(3.10)	Yes	-	No	¥			An activity which will cause any safety-related system, equipment or component to be moved from its currently installed location to another room?
(3.11)	Yes	-	No	∠.			The possibility of environmental changes to rooms or areas containing safety-related structures, systems, equipment or components (i.e., changes in radiation level, or source terms, temperature profiles, pressure profiles, humidity profiles, flood levels or relocation of a high energy line)?
(3.12)	Yes	-	No	_			An activity which will modify or change any system, equipment or component listed as LOCA, MSLB, or HELB Category C or D in FSAR Table 3.11(B)-3 such that Seismic Qualification may be impacted?
(3.13	Yes	_	No	_			Does the modification, change, or review involve a possible Seismic II/I question or affect Seismic Category I Stress Problems?
(3.14) Yes	-	No	_			The possibility of adding an unqualified coating (paint) to the Reactor Building or on items capable of blocking the containment sump?

- 40922 If any of questions 3.2 through 3.12 are marked "Yes", then the environmental and/or seismic qualification impact shall be verified per APA-ZZ-00390. Such verification must be performed by the EQMuterials Support group or Licensing and documented in Section 8. This verification shall be poordinated with Design Control prior to affected equipment being released to service.
- Requests for Resoluti...n (RFRs) that deal with material equivalency and effect Category A and B equipment (see question 3.3) must be considered for inclusion into the EQ files. If the files are impacted, an EQ Change Notice shall be generated IAW APA-ZZ-00390.

If question 3.13 is marked "Yes", address the notes/questions issled in Attachment 4, Para 3.13. Appropriate records (Example - Formal Safety Evaluation, DIR, etc.) will be generated by the Evaluating Engineer to document the evaluation. In addition, complete CA#1077, "Seismic II/ Hazards Evaluation, DIR, etc.) will be generated by the Evaluating Engineer to document the evaluation. In addition, complete CA#1077, "Seismic II/ Hazards Analysis Review". The original CA#1077 is to be ettached to the "LIR" and a copy forwarded to the Supervising Engineer - Civil/Fire Protection/Design Bases.

If Overstion 3.13 is marked "NO", a Seismic Will question does not exist due to the nature of the modification, change, or review

Question 3.14 is marked "YES", the Chrit/Fire Protection/Design Bases Design Control group should be contacted for essistance on reviews.

This rev	iew is app	licable to			RF	C 8746I		AND ADDRESS OF THE PARTY OF THE
4497	(4)		NMENTAL	EVALU	ATION			
		This mo	dification/ch	ange in	volves			
	(4.1)	Yes	No.	1	An increase in th	ermal power above the	currently licensed i	evel?
	(4.2)	Yes	No	_/_	An increase in n	oise level?		
	(4.3)	Yes _	No.		A physical chan	ge to site grounds or p	siant layout 7	
	(4.4)	Yes	No	_/_	An adverse impe	act on area wildlife and	/or vegetation?	
	(4.5)	Yes	No.	1	A change in the effluents or any	rate, quantity, concent NPDES permitted outf	ration, or composition	on, or temperature of liquid
	(4.6)	Yes	No.	1	A change in the	rate, quantity, concent	tration, or composition	on of gaseous effluents?
	(4.7)	Yes	No.	1	A change in par	ticulate emissions rate	concentration, or o	emposition?
42916	(4.8)	Yes _	No.		Any excavation excavation distr	on UE property outside urbing five acres or mo	e of the Owner Cont re on UE property?	trolled Area fence or any
42427	(4.9)	Yes _	No.	_	A possible char navigable water	nge to the facility's pole is of the U.S.?	ential for the dischar	ge of oil into or upon the
	(4.10)	Yes .	No.	_	A significant in NUREG 0813	crease in any adverse (FES-OL)?	environmental impai	ct previously evaluated in
	(4.11)	Yes .	No.	_	A matter which may have a sig	has <u>not</u> been previous milicant adverse enviro	sty evaluated in NUF onmental impact?	REG 0813 (FES-OL) which
	Departmen	nt If all of the	e above questi questions in th n is not require	IS SECTION	s", a Final Environ are marked "No",	mental Evaluation must an unreviewed environ	it be performed by F nmental question do	Radiological Engineering es not exist and a Final
	(5)	10 CF	R 50 54 AP	PLICAB	ILITY DETER	MINATION		
		This n	nodification/	change	involves:			
	(5.1)	Yes	No	1		ve Radiological Emergi	ency Response Plan	(RERP?)
	(5.2)		prward to the S	upervisor,	Emergency Prepa	redness to answer the	following question:	
		effectiveness			□Yes	□ No		
				tion 8 of t	his form and sign	below.)		
	(remark							
	Superv	risor, Emer	gency Prep	arednes	.5			
	(5.3)	Yes	No	1	A change to th	e Physical Security or Co	ontingency Plan?	
	(5.4)	F yes, S	present to the Sup	perintender	it. Security to answe	r the following question:		
	Is Secur	ity effectivene	ss reduced?		□ Yes	D No		
	(Provide	basis for this	response in Se	ction 8 of	this form and sign	below.)		
	Superi	ntendent	Security					

new is app	olicable to			
(5.5)		No.		A change to the Operating Quality Assurance Manual (OQAM) including the Supplemental QA Programs?
(5.6)	if yes, forw	vard to the Supe	ervising Eng	igineer, Quality Assurance for completion of a Quality Assurance evaluation.
Is Quality A	ssurance redu	iced?		DYes DNo
			n 8 of this f	form and sign below.)
Triberior see				
Supervis	ing Engine	er, Quality A	ssuranc	
		FICATIONS		
(6)				
(6.1)		ROTECTIO		
(6.1.1)				This modification/change/review may involve a change to one or more aspects the approved Fire Protection Program as defined in the checklists of EDP-ZZ-04044. Fire Protection Reviews
if yes, doc Engineer p	serform a cross	4-disciplinary re	NIGHT DI STRE	n Section 8 of the LIR or on a Design Input Report (DIR) and have a Fire Protection LIR or DIR per EDP-ZZ-04044.
(6.1.2)	Yes	No.	1	This modification/change/review involves an addition of combustible or flamma material
If yes, eva	luate the need	for a "Combust	ible/Flamm	nable Material Addition" form IAW EDP-ZZ-04044 Proceed to question 5.1.3.
(6.1.3)	Yes .	N/R		CA-#1855 from EDP-ZZ-04044 attached to LIR and copy sent to Supervising Engineer - Civil/Fire Protection/Design Bases
(6.2)	ALAR	A REVIEW	complete ç	gne section: EITHER Sect 6.2.1 OR 6.2.2)
(6.2.1)	Modifica	ation - Specific(s	applicable f	for CMPs, RMPs, EMPs and Minor Modifications)
	Yes	No		Will this modification require work within the Radiological Controlled Area (RC
	Yes	No		Will this modification require work on a system containing or potentially contain radioactive material?
	Yes	No		Will this modification involve work on a system which connects to or interface a system or component storing, transferring, or handling radioactive material?
	Yes	No		Will this modification or associated implementation or operation involve modifi- removal, or installation of shielding?
	Yes	No		Will this modification involve radioactive waste generation?
If the an ZZ-003-	swer to any of 00 If ZZ-003-	the questions a -00 requirement	bove is "ye s cannol be	es", an ALARA design review is required per Nuclear Engineering Design Guide be met, an ALARA review must be performed by Radiological Engineering.
D	Documenta	tion detailing the	results of	f this review is included in Section 8 of the LIR.
D	All answers exposures t	to the above qui beyond the expo	estions are	re "No" and k is certified that the proposed change does not increase potential rad taineady exist.
(t2	GENE			
	Ø	I hereby certify	that the pr	proposed change does not increase potential radiation exposures beyond the expo
		that already ex	st.	Page 4 of 8 CA-#1339 08-26-93

APA-ZZ-00140

and the lands	cast .	RFL 87.	46 I
view is applicab	le 10	- Andrews - Andr	
D	This change required further 003-00 Documentation of th	evaluation by a qualified A is review is included in Se	LARA reviewer per Nuclear Engineering Design Guide ZZ ection 8 of the LIR.
(6.3)	ODCM/PCP REVIEW		
(6.3.1)	Yes No	This modification/o (PCP) as detailed it	hange/review may impact the Process Control Program n APA-ZZ-01011.
(6.3.1.1)	If yes, forward to the Superinte with Administrative Technical	endent, Chemistry & Radw Specification 6.13.	raste to answer the following two questions in accordance
is the overall confo	ormance of the solidified waste pr	roduct to existing criteria for	or solid wastes reduced?
		□ Yes	□ No
Does this modifica	ation/change/review require a cha	inge to the PCP7	
		□Yes	D No
(Provide basis for	this response in Section 8 of thi	s form and sign below)	
Superintende	nt, Chemistry and Radwa		
(6.3.2)	Yes No V	This modification Manual (ODCM)	/change/review may impact the Off-site Dose Calculation as detailed in APA-ZZ-01003
(6.3.2.1)	If yes, forward to the Superin Administrative Technical Sp	ntendent, Health Physics t ecification 6.14	o answer the following two questions in accordance with
is the accuracy of	of effluent release calculations, d	ose calculations or setpoir	nts determinations reduced?
		☐ Yes	D No
		□Yes	
	ication/change/review require a c	□Yes	
Does this modifi		☐ Yes hange to the ODCM? ☐ Yes	D No
	(6.3) (6.3.1) (6.3.1.1) Is the overall confidence (Provide basis for Superintender (6.3.2) (6.3.2.1)	(6.3) ODCM/PCP REVIEW (6.3.1) Yes No (6.3.1.1) If yes, forward to the Superinte with Administrative Technical with Administrative Technical state overall conformance of the solidified waste properties that modification/change/review require a characteristic for this response in Section 8 of this Superintendent, Chemistry and Radward (6.3.2) Yes No (6.3.2.1) If yes, forward to the Superintendent of the Superin	This change required further evaluation by a qualified A 003-00 Documentation of this review is included in Section 3.1.1) Yes No This modification/of (PCP) as detailed a with Administrative Technical Specification 6.13. Is the overall conformance of the solidified waste product to existing criteria for the overall conformance of the solidified waste product to existing criteria for the PCP? Description of this response in Section 8 of this form and sign below) Superintendent, Chemistry and Radwaste (6.3.2) Yes No This modification Manual (ODCM)

his review	v is appl	ILAUIC	10		and the second s	8746.	
6.4)	HUMA	NFAC	TO	REVALU	JATION		
	This N	Modifica	ation	/Change	involves:		
6 4 . 1)						ol Board (RLI	001 through RL028) or Auxiliary Shutdown Panel
6.4.2)	Yes _		No .		A change to the Plant Annu	nciator Wind	ow location, engraving, etc.?
6.4.3)					A change to the Control Ro	om temperati	ure, air velocity, lighting, ambient sound level, etc.?
6 4 4)	Ves		No	1	A change to the Auxiliary S	hutdown Pan	el Room lighting?
	to any of t	he above bove are	"NO"	rES", prepa ", a Human	re a brief description of the mod Factor Review is not required.		nge and forward to the Human Factors Design Revi ontrols, instrumentation, etc. change to other location
		NI	IR				
Human Fa	actors D	esign I	Rev	iew Engir	neer		
(6.5)	STAT	ION B	LAC	KOUT (SBO) EVALUATION		
(0.0)					e involves:		
					Placing additional electrical	load on the	Station Batteries
(6.5.1)				1			
(6.5.2)							toom (3601) or Equipment Cabinet Area (3605)
(6.5.3)	Yes		No		indicators		ver for any Containment Isolation Valve or its position
(6.5.4)	Yes		No		A change in the source of instrumentation or control		ver for any safety-related or Station Blackout
(6.5.5)	Ves		No		A change that will increas	e the rate of I	Reactor Coolant Inventory loss, 5
(6.5.6)	Yes		No		A reduction in the require	d Condensate	e Storage Tank volume
(6.5.7)					A reduction in the volume Generator Atmospheric F	of backup nit	trogen for the Auxiliary Feedwater Control or Steam
(6.5.8)	Yes		No	_	The addition of heat gene the following rooms	rating source	s, that will be present after a loss of AC power, to a
	1304 1305 1322 1323 1327 1330 1331 1408 1409 1411 1412 1501	Auxiliary Piping P Piping P Auxilian Auxilian Corrido Electrico Main Fa Control Conder	Feed Feed Feed Penetri Feed Prive No 1 al Per Pedvis Pedvis Room Room Room Feed Feed Feed Feed Feed Feed Feed Fee	water Pipe Coation Room I ation	hase 8 A Valve Compartment No. ? Valve Compartment No. 4 eadwater Pump Room em B unnel unnel ston Units Room B a Valve House	1508 1509 1512 3302 3404 3405 3407 3408 3410 3411 3413 3414 4201	Main Feedwater/Steam Tunnel Main Feedwater/Steam Tunnel Control Room A/C & Filtration Units Room A Engineered Safety Features Switchgear Room No. 2 Switchboard Room No. 4 Battery Room No. 4 Battery Room No. 1 Switchboard Room No. 2 Battery Room No. 2 Battery Room No. 2 Battery Room No. 3 Switchboard Room No. 3 Condenser Pit e modification/change and forward to the Station ackouf Review is required.
	piec	THE PARTY					
			0				1 1

Page 6 of 8

CA-#1339 08-26-93 APA-ZZ-00140

			PFL 8746T
This re	view is applicable		at your state of the first state of the stat
66)	PROBABILISTIC F	RISK ASSESS	MENT (PRA) REVIEW
	This modification/o	change involve	es
(6.6.1)		No /	A potentially FRA-significant change to a plant system
(6.6.2)	Yes	No _	A change to plant Technical Specifications
(6.6.3)	Ves	No /	A change to emergency operating procedures
	If the answer to an ZZ-04004, Perform Design If all of the	ny of the above mance of PRA he above are "I	e is "Yes", prepare a PRA Evaluation Request (PRAER) Form (CA-#2237; ref. FDF Evaluations), and forward to the Supervising Engineer, Safety Analysis & Reactor No", a probabilistic risk assessment is not required.
	NIR		
PRA E	ngineer		
(7)	JUSTIFICATIO!	N FOR NO U	INREVIEWED SAFETY QUESTION
	Briefly state why this	modification doe	es not require a Formal Safety Evaluation, use guidelines in Attachment 4 of APA-ZZ-00140; attac
	extra sheets if neces	usary)	for morty
	1	-	11 11 11 11 11
	This PEX	o de Lun	vines the Horns of requirements that have
	11	11	Judd in accordance wet Fol- 27-01114
	mot file	49 -	- 25-10 A reined has been
	and for	Genera	serge of the first of
	potente	wooha	motipassant from setting 15 the
	Lequiers	ento so	miled this RA He speciality
	2 Marine	7	ale fifiel (reporto ATT 9) Hurs, mo
	Children War		101: -0
	- mal	aft ty	eveluation a regular
	1	- STATE OF THE PARTY OF THE PAR	
	-		
	-		
	-		

COMMENTS			
List any special conditions or comments per	taining to these evaluations and cert	ifications	
		-	
AC 400 100 000 100 100 100 100 100 100 100			
			Annual State of State
			110
and the second s			

121 100 100 100 100 100 100 100 100 100			
	- //		
APPROVALS	7/-1//		ate <u>1-8/-9</u>

RFR 87461 DETERMINATION OF THRUST VALUES

INTRODUCTION

Generic Letter 89-10 requires that utilities differential pressure (DP) test safety related MOV's when practical in order to verify that these components will be capable of performing their intended safety function. RFR 10324A has been dispositioned and provides the reasoning why it is impractical to DP test selected safety related MOV's at Callaway¹. It has been the Callaway Plants philosophy to DP test all safety related MOV's when practical, however, because of situations where an MOV cannot be adequately DP tested alternate methods are needed to determine how the thrust requirements for these MOV's can be established in order to satisfy GL 89-10 requirements. The purpose of this RFR is to describe for each safety related rising stem valve MOV that has not been DP tested to the criteria described in EDP-ZZ-01114, Motor Operated Valve Predictive Performance Program, how the thrust requirements are being established in order to satisfy Generic Letter 89-10 requirements. Note that RFR 10324A addressed both safety related rising stem and butterfly valve MOV's. This RFR is only addressing safety related rising stem MOV's as all safety related butterfly MOV's have already been evaluated².

Several attachments are provided with this RFR as summarized below:

- Attachment 1: Provides a comparison of actual DP test results vs. calculated thrust values.

 When DP test results are referred to they originate from this attachment.
- Attachment 2: Determines the calculated thrust values for valves discussed in this RFR that have not been DP tested.
- Attachment 3: Provides information regarding the Rate of Loading Factors used in this RFR.
- Attachment 4: Provides a summary of the final thrust values for values being evaluated in this RFR.
- Attachment 5 Provides seat ring dimensions for Westinghouse supplied MOV's.
- Attachment 6: Provides DP test information for ENHV0006 and 12 from Wolf Creek.
- Attachmetnt 7: Provides PRA information for MOV's discussed in this RFR
- Attachment 8: Provides the latest information from the EPRI MOV Predictive Performance Program.
- Attachment 9: Operability verification for the revised thrust requirements provided by RFR 8746I and G.

PRIMARY METHOD OF DETERMINING DP REQUIREMENTS FOR VALVES NOT DP TESTED

For those valves that cannot be DP tested the preferred method for determining thrust requirements has been to group similar MOV's that have been DP tested at Callaway and either using that data directly or demonstrating that the thrust requirements can be conservatively predicted using calculations.

¹Note that RFR 10324A stated that EFHV23,39,40,41,42 could not be DP tested to the criteria of EDP-ZZ-01114. These valves have been DP tested greater than 50% of the design DP per RFR 8746H. In addition, RFR 10324A did not refer to LFFV0095 and LFHV00105,106. These valves were DP tested but not to the criteria of EDP-ZZ-01114. EFPDV0019 and 20 thrust values are also determined in this RFR even through they are routinely DP tested near the design DP of 134 psid.

²RFR 8746H

Before this method is considered reliable several conditions should be met. First the valves being used for comparison purposes must be of the same manufacturer and type. Secondly, the valves being used for comparison must meet the criteria listed below before the test results can be directly applied. If the test DP for valves being used for comparison are above the design DP of the valve(s) being evaluated the thrust values are reduced proportionately. Flow rates should also be considered when using similar valves to determine thrust requirements. Additionally, the similar valve(s) should be the same nominal size or larger. If these conditions are not satisfied the secondary method is employed.

toting IF WE WAS DET the the work

Test DP must be 80% of design DP for valve not DP tested if design DP is > 260 psid Test DP must be 50% of design DP for valve not DP tested if design DP is < 260 psid

SECONDARY METHOD OF DETERMINING DP REQUIREMENTS FOR VALVES NOT DP TESTED

The secondary method used to determine thrust requirements for MOV's not DP tested is use of a modified standard industry equation³. Listed below is the modified industry equation being used for gate and globe valves.

OPEN THRUST REQUIREMENTS = ROL x (DAxDPxVF)

CLOSED THRUST REQUIREMENT = ROL x ((DAXDPx VF) + SAX LP)

where: ROL= Rate of Loading; set dependent on actuator size4 (ranges 4 com (5% to 22%)

DA = Mean Seat Area sq inches.

VF = Valve Factor = 4 to 1.0 for flex wedge gate valves, 1.1 to 2.2 for globe valves DP = Differential Pressure psid

and 4 for parallel disc/slide gate valves5

SA = Stem Area sq. inches

LP = Line Pressure

For example, refer to the information provided on Attachment 2 for ALHV0034:

ROL = 1.15

DA = 44.92 sq. in

DP = 135 psid in closed direction

VF = .5

SA = 1.22718 sq. in

Using the information above the closing thrsin requirements become:

CLOSED THRUST = (1.15) * ((44.92 *135 *.5) + (1.22718 * 135)) = 3677 lbs

³Refer to EPRI NP-6660-D. Application Guideline for Motor Operated Valves in Nuclear Power Plants

⁵Other valve factors may be used if supported by the results of EPRI Predictive Performance Program. If other valve factors are used they will be discussed in the individual section of this RFR. RFR87461.DOC

Note that the open thrust equation is the same as the closing thrust equation with the exception of the SAxLP term. This term, commonly referred to as the piston effect would actually be negative in the open direction thus reducing the calculated thrust requirements further. This term is set equal to zero for conservatism. Also note that neither term includes a value for stem packing loads. This term is included during field testing where the packing loads are measured rather than being provided here based on generic guidelines.

In summary, the discussion above was intended to demonstrate the methodology being used at Callaway to satisfy GL 89-10 requirements with regards to establishing thrust requirements. Each of the 54 rising stem MOV's at Callaway that have not been DP tested to the criteria of EDP-ZZ-01114 and the basis for the thrust requirements to allow close-out of GL 89-10 is provided in this RFR. Note that some thrust requirements are being changed from that previously established in the Callaway Equipment List (CEL) to provide added conservatism while some MOV's have had thrust requirements relaxed because of unrealistic thrust requirements that were overly conservative. Finally, it will be noted that the weighting each MOV has on the Callaway Plant PRA is included on Attachment 7. No MOV's that are of high priority with respect to the Independent Plant Evaluation (IPE) have had there thrust requirements determined using the methods described in this RFR. Thus, any rising stem MOV that is considered to have high priority with respect to the IPE has been DP tested to the criteria of EDP-ZZ-01114.

ALHV0034,35,36: CST TO AFP SUCTION ISOLATION VALVES

These MOV's were partially DP tested during the IE.Bulletin 85-03 program. However, the test DP (14 psid) was inadequate to satisfy the criteria of EDP-ZZ-01114 for extrapolation purposes. The present closing thrust requirements for ALHV0034,35,36 originated from RFR 8746D based on comparison of the thrust requirements from EGHV0058,59,60,71,126,127,130 and 131. However, in reviewing the valve design for these valves it became apparent that some of these valves should not be considered suitable for comparison as similar valves. ALHV0034,35,36 are Anchor Darling flex wedge gate (FWG) valves. EGHV0058,59,60,127,130 and 131 are also Anchor Darling valves but are of the parallel disc gate (PDG) design. The difference in the two designs are that the FWG valve discs are wedged downward into the sloped scating surface of the valve body whereas the PDG valves are thrust outward by a wedge assembly. The flex wedge design will have a higher valve factor assuming an equal disc friction coefficient because of the sloped seating surface. This still leaves EGHV0071 and 126 which are of the same design as ALHV0034,35,36 but of different sizes as described below.

VALVE ID	MANUFACTURER	TYPE	SIZE
ALHV0034	ANCHOR DARLING	FWG	8"
ALHV0034	ANCHOR DARLING	FWG	8"
ALHV0036	ANCHOR DARLING	FWG	10*
EGHV0071	ANCHOR DARLING	FWG	12"
EGHV0126	ANCHOR DARLING	FWG	12"

For ALHV0034,35,36 it is desired, since the valves sizes are different, to demonstrate that the thrust requirements for EGHV0071 and 126 can be approximated using calculations and a valve factor of .5 when compared with the actual DP test results. Once this has been shown the thrust requirements for ALHV0034,35,36 will be determined using calculations and a .5 valve factor. Attachment 1 provides the results of the DP test measurements for EGHV0071 and 126 and the calculations using the equations described in the Introduction section. The information from Attachment 1 is repeated here for reference.

VALVE ID EGHV0071 EGHV0126

CALC CLOSED THRUST 5054 LBS 4951 LBS

MEASURED CLOSED THRUST 5267 LBS 4220 LBS

As can be seen the calculational method would have provided a good approximation of the closing thrust requirements for EGHV0071 and 126. Note that the thrust values listed above inherently include conservatism with respect to measured thrust due to the methods in which DP testing is performed at Callaway, i.e. include spring pack apparent spring pack preload.

ALHV0034,35 and 36 are installed in a system with basically the same fluid medium as EGHV0071 and 126, i.e. sub cooled liquid with a normal temperature less than 100 degrees Fahrenheit. The fluid velocity through EGHV0071 and 126 during the DP testing (~3300 GPM or 11.13 ft/sec6) is much greater than the worst case velocity for ALHV0034,35,36 (575 GPM or 3.7 ft/sec for ALHV0034,35 and 1145 GPM or 4.7 ft/sec through ALHV00367).

Based on the discussion above the closing thrust requirements for ALHV0034,35,36 can be established using calculational methods. The revised closing thrust requirements for ALHV0034,35,36 are provided below. Note that the opening thrust requirements for ALHV0034,35,36 as provided in RFR 8746D remain unchanged.

ALHV0034,35 CLOSING THRUST REQUIREMENTS =

3677 LBS 4993 LBS

CLOSING THRUST REQUIREMENT = ALHV0036

BBHV0013,14,15,16 RCP THERMAL BARRIER RETURN FLOW ISOLATION VALVES

These MOV's have been DP tested but did not satisfy the criteria for extrapolation provided in EDP-ZZ-01114 in the closed direction. These are MOV's that have no similar valves tested to a high chough pressure to compare DP test data with at Callaway. In referring to the EPRI Performance Prediction Program a 2.5" Velan FWG has been tested under blowdown conditions at 530 degrees F and 2660 psid. Under these conditions the disc friction coefficient is recorded as .328. Assuming a 5 degree wedge angle this corresponds to a valve factor of .340. The disc friction coefficient is converted to valve factor using the following equation8.

VALVE FACTOR μ*SIN Φ COS Φ -

APPARENT FRICTION COEFFICIENT WHERE u WEDGE ANGEL (ASSUMED 5 DEGREES)

The design basis conditions for BBHV0013,14,15,16, i.e. isolate under a thermal barrier break, are similar to the test conditions for the 2.5" Velan FWG valve. BBHV0013,14,15 and 16 are 3 inch Velan FWG valves. Since the design of these valves are the same and only the size is slightly different (2.5" vs. 3") the disc friction coefficient information provided above is considered valid for determining the thrust requirements for BBHV0013,14,15 and 16. For added conservatism a valve factor of .4 will be used in place of the .34 valve factor determined above.

⁶Refer to Special Test Report for ETP-EG-ST002.

Refer to FSAR Chapter 10.4

⁸Refer to EPRI MOV Program Review Meeting Minutes 12/1/93 included in Attachment 8. RFR8746LDOC

Using the calculational method described previously with a .4 vaive factor a closing thrust requirement of 8482 lbs closing thrust is obtained. The opening thrust requirements provided by RFR 14359A should continue to be used as they are based on in situ DP testing within the criteria of EDP-ZZ-01114.

CLOSING THRUST REQUIREMENT FOR BBHV0013,14,15,16: 8482 LBS

BBHV8000A/B PORV BLOCK VALVES

The present opening and closing thrust requirements for BBHV8000A/B originate from RFR 5353I and are based on a comparison with other Westinghouse flex wedge gate valves that have been DP tested at Callaway. The design DP for these valves is 2485 psid open and 2335 psid closed. The test DP's for the valves used for comparison in RFR 5353I and their revised thrust measurements 10 to overcome the test DP is repeated below.

VALVE ID	SIZE	TEST DP	MEASURED OPEN THRUST	MEASURED CLOSED
				THRUST
BGHV8105	3"	2572 PSID	2490 LBS	10373 LBS
BGHV8106	3"	2572 PSID	4540 LBS	12127 LBS
EMHV8801A	4"	2677 PSID	4458 LBS	4221 LBS
EMHV8801B	4"	2677 PSID	6062 LBS	2815 LBS
EMHV8803A	4"	2727 PSID	10586 LBS	4632 LBS
EMHV8803B	4"	2702 PSID	3760 LBS	1567 LBS
EMHV8821A	4"	1595 PSID	4299 LBS	3934 LBS
Control of the Control of the	4"	1540 PSID	4249 LBS	2709 LBS
EMHV8821B EMHV8835	4"	1595 PSID	3650 LBS	N/A

BGHV8105 and BGHV8106 are the same size and type valve, have the largest measured closing thrust requirements and were DP tested at a pressure in excess of the design DP for BBHV8000A/B. Using the calculational method a closing thrust of 11630 lbs is obtained for comparison with the test DP thrust requirements on BGHV8105/8106. The calculations are comparable with the test results.

However, before using the DP test results from BGHV8105/8106 to predict bounding thrust requirements for BBHV8000A/B the differences between the DP test of BGHV8110&8111 and design conditions for BBHV8000A&B should be addressed. BGHV8105 & 8106 were tested under pumped flow, cold water conditions under relatively low flowrates (<120 GPM or less than 7.2 ft/sec) compared with what BBHV8000A/B would be expected to see. Under a design basis accident BBHV8000A/B would be expected to isolate under 2 phase blowdown conditions.

In referring to the EPRI MOV Predictive Performance Program a Westinghouse 3" FWG valve is being tested under high DP conditions at a nominal velocity of 15 ft/sec. Under these conditions an opening apparent friction coefficient of .313 is recorded. For the 7 degree wedge angle for this model valve this corresponds to a valve factor of .328 (refer to the discussion for BBHV0013,14,15 & 16 on how to calculate valve factor). In reviewing the EPRI study it is found that the opening apparent friction coefficients tend to bound or closely approximate the closing apparent friction coefficients in the high pressure cold/hot water test loop data. Thus, for non blowdown conditions it appears that a valve factor of below .5 could be justified. However, since these valves have not been DP tested under blowdown conditions the use of a .6 valve factor is recommended for BBHV8000A/B. Using the a valve factor of .6 the revised closing thrust becomes 11355 lbs.

RFR87461.DOC

01/21/94

⁹Refer to Attachment 2 ¹⁰Refer to RFR's 8746F&G

In the open direction using a .6 valve factor the thrust requirements for BBHV8000A/B become 9244 lbs.

It should also be noted that these are limit closed MOV's that will develop the torque/thrust necessary to overcome DP conditions up to locked rotor conditions. The capabilities of these MOV's to develop this amount of torque/thrust is provided by calculation ZZ-224.

11355 LBS BBHV8000A/B CLOSED THRUST REQUIREMENT = 9244 LBS OPEN THRUST REQUIREMENT

PRESSURIZER RELIEF TANK ISOLATION VALVES BBHV8037A/B

These valves have had their thrust requirements determined using calculations as described in RFR 9878B. The thrust requirements using this method were determined to be 1100 lbs both open and closed for a design DP of 104 psid. The method used in RFR 9878B is slightly different than that used in

BBHV8037A/B are 4 inch Westinghouse FWG valves. There have been several 4" valves of this design DP tested under more severe conditions that BBHV8037A/B would be subjected to and well in this RFR disposition. excess of the design DP for BBHV8037A/B (refer to BBHV8000A/B section above). If one takes the largest measured closing thrust from the 4" valves that have been DP tested (EMHV8803A) and compares it to what would be determined using calculations and a 1.0 valve factor it is evident that the calculational

Based on this discussion the thrust requirements for BBHV8037A/B can be determined very method provides conservative results. conservatively using calculations. For consistency the thrust requirements are being recalculated via the method described in this RFR. For additional conservatism the thrust requirements have been calculated using a valve factor of 1.0.

1337 LBS BBHV8037A/B CLOSING THRUST REQUIREMENTS 1190 LBS OPENING THRUST REQUIREMENTS

BBHV8351A,B,C,D RCP SEAL INJECTION ISOLATION VALVES

MOV's BGHV8110 and 8111 are identical MOV's that have been DP tested at 2582 and 2824 psid respectively. BGHV8110 and 8111 are the same size globe valve and were tested under higher flowrates (- 60 GPM) than what BBHV8351A,B,C and D provide. BGHV81110 and 8111 are the CCP minflow line isolation valves that have flowrates limited to 60 GPM by use of an upstream orifice. BHV8351A,B,C and D normally have a combined flow rate of ~32 GPM (or ~8 GPM each) to supply the RCP seals. These valves are 2" Velan globe valves with flow under the seat. These valves have been determined to not have an active safety function but for commercial considerations it is desired to have their thrust requirements established to overcome a DP of 2813 psid11. In reviewing the DP data for BGHV8110 and BGHV8111 it is discovered that the amount of thrust to overcome the test DP was less than the apparent preload of the spring packs. Thus, the amount of thrust to overcome those test DP's had to have been less than the apparent preload of the spring packs. Since BGHV8111 was tested at a DP above the commercial DP for BBHV8351A,B,C,D the closed apparent preload from BGHV8111 will be used for the open and closed thrust requirements for BBHV8351A,B,C,D.

BBHV8351A,B,C,D OPEN AND CLOSING THRUST REQUIREMENT = 7039 LBS

¹¹Based on the disposition of RFR 5353G and SOS 90-1584 it was determined that these valves have no active safety function to open or close. RFR 5353X provides a commercial DP.

BBPV8702A,B EJHV8701A,B RHR PUMP SUCTION ISOLATION VALVES FROM RCS LOOPS 1 & 4

There are no other valves of the same size at Callaway that have been adequately DP tested for comparison. BBPV8701A/B & EJHV8702A/B are 12" Westinghouse FWG valves. Additionally, there is limited information available in the EPRI Performance Prediction Program for this size and type of valve. What is provided in the EPRI program is an apparent friction coefficient for the 3" Westinghouse valve. What is provided in the EPRI program is an apparent friction coefficient for this 3" valve is .328. FWG valve discussed earlier in the section for BBHV8000A/B. The valve factor for this 3" valve is .328. Because of the limited information with regard to this size of valve it is recommended that the .5 valve factor continue to be used. Using calculations and a .5 valve factor the thrust requirements for these valves become:

BBPV8702A/B EJHV8701A/B OPENING THRUST REQUIREMENTS 19761 LBS CLOSING THRUST REQUIREMENTS 28065 LBS

BGHV8100 & 8112 RCP SEAL WATER RETURN ISOLATION VALVES

A review of valves DP tested at Callaway indicates that BGHV8110 & 8111 are identical valves that have been DP tested. These valves are 2" Velan globe valves with flow under the seat. The DP testing for BGHV8110/8111 was at significantly higher DP's and flowrates (~60 GPM and ~2600 psid) testing for BGHV8100/8111 was at significantly higher DP's and flowrates (~60 GPM and ~2600 psid) than the design DP and nominal flowrate for BGHV8100/8112 (155 psid and <32 GPM). Refer to the previous discussion for BBHV8351A,B,C,D. BGHV8100/8112 will experience lower flowrates than the BBHV8351's since a portion of RCP scal injection goes into the RCS.

Both BGHV8110 and 8111 had thrust requirements to overcome the test DP less than spring pack preload so a determination of the actual thrust requirements for these valves is unknown. Calculations indicate that the thrust required to open/close against 155 psid is 541 lbs and 736 lbs respectively.

It is known that BGHV8111 was tested at a DP significantly higher than the design DP for BGHV8100/8112 and it is known that the thrust requirement for BGHV8111 was less than the measured apparent spring pack preload from BGHV8111. Therefore, the thrust requirements for BGHV8100/8112 apparent spring pack preload for BGHV8111. For extreme conservatism the thrust must be less than the apparent spring pack preload for BGHV8111. For extreme conservatism the thrust requirements for BGHV8110/8111 will be set equal to the apparent spring pack preload from BGHV8111 (7039 lbs).

BGHV8100 & 8112 OPEN & CLOSING THRUST REQUIREMENT = 7039 LBS

BGHV8109 NORMAL CHARGING PUMP MINIFLOW ISOLATION VALVE

This valve is identical to those discussed above for BGHV8110 & 8112. Based on the closing design DP for BGHV8109 (2818 psid) being near the test DP for BGHV8111 (2842 psid) the closing test data for BGHV8111 will be used as the closing thrust requirements for BGHV8109.

As stated previously the closing thrust requirements to overcome the test DP for BGHV8111 were less than spring pack preload so a determination of the actual thrust requirements is unknown. The spring pack preload for BGHV8111 is 7039 lbs. It is known that the thrust required to overcome DP for BGHV8111 is below this value.

In the open direction it is known that this valve requires no assistance from the motor operator to open 12. This valve has been known to open by itself with line pressure as the operator is de clutched. For conservatism the opening thrust requirements will be established based on calculations.

BGHV8109 CLOSING THRUST REQUIREMENTS 7039 LBS

¹²refer to RFR 7263A RFR87461.DOC 01/21/94

RFR 87461

OPENING THRUST REQUIREMENTS 328 LBS

BGLCV0112B.C CHARGING PUMPS SUCTION ISOLATION VALVES FROM VCT

These MOV's were included in the response to NRC I.E. Bulletin \$5-03. Because these valves could not be adequately DP tested as discussed in RFR 10324A and ULNRC 1755 the thrust requirements for these valves were determined using valves of the same design but different sizes. In preparing for and testing MOV's in accordance with GL 89-10, additional Westinghouse FWG valves of the same type and size have been DP tested at significantly higher DP's and flowrates than the design DP of 100 psid for BGLCV0112B/C. Refer to the table below.

VALVE ID	SIZE	TEST DP	MEASURED OPEN THRUST	MEASURED CLOSED THRUST
EMHV8801A	4*	2677 PSID	4458 LBS	4221 LBS
EMHV8801B	4*	2677 PSID	6062 LBS	2815 LBS
EMHV8821A	4"	1595 PSID	4299 LBS	3934 LBS
EMHV8821B	4*	1540 PSID	4249 LBS	2709 LBS
EMHV8835	4"	1595 PSID	3650 LBS	N/A

If one calculated the thrust requirements for BGLCV0112B/C a thrust requirement of 1286 lbs closed and 1145 lbs open would be obtained using valve factor of 1.0. These valves were proviously set up for 3110 lbs open and 1965 lbs closed. Since these MOV's are capable of providing significantly higher thrust and for added conservatism it is recommended that the thrust values for BGLCV0112B/C be set up to the largest open and closed thrust measurement listed in the table above.

BGLCV0112B/C

CLOSING TERUST REQUIREMENT: 4221 LBS OPENING TERUST REQUIREMENT 6062 LBS

BNHV00034 RWST TO CTMT SPRAY PUMP ISOLATION VALVES

These valves presently have thrust requirements established using calculations in accordance with RFR 9878A. The method used in RFR 9878A is slightly different than that used in this RFR. For consistency the thrust requirements are being recalculated in this RFR. As shown on Attachment 2 the recalculated values become 3356 lbs closed and 3301 lbs open using a valve factor of 1.0 to overcome the design DP of 32 psid.

In referring to the DP tests performed at Callaway the only valves comparable are EGHV0071 and 126. The only significant difference between these valves types are that BNHV0003/4 are stainless while EGHV0071/126 are carbon steel valves. Listed below are the measured thrust requirements from EGHV0071/126. The DP test for EGHV0071 was at 94 paid and the test for EGHV0126 at 92 paid.

VALVEID	MEASURED OPEN TERUST	MEASURED CLOSED THRUST
EGHV0071	4885 LBS	5267 LBS
EGHV0126	1982 LBS	4220 LBS

As can be seen with the data above, if the thrust values for EGHV0071 is derated to the design DP for BNHV0003&4 lower values than that calculated above would be obtained. For added conservatism the thrust requirements for BNHV0003&4 will be based on a valve factor of 1.0

BNHV0003&4 OPENING THRUST REQUIREMENT 3301 LBS
CLOSING THRUST REQUIREMENT 3356 LBS

RFR8746LDOC 01/21/94

BNHV8812A,B RWST TO RHR PUMP SUCTION ISOLATION VALVES

There are no other valves of the same size at Callaway that have been adequately DP tested for comparison. These are 14" Westinghouse FWG valves. Additionally, there is limited information available in the EPRI Performance Prediction Program for this size and type of valve. What is provided in the EPRI program is an apparent friction coefficient for the 3" Westinghouse FWG valve discussed in the section for BBHV8000A/B. The valve factor for this 3" valve is .328. Because of the limited information with regard to this size of valve and the thrust margin available it is recommended that a 1.0 valve factor be used. Using calculations the thrust requirements for these valves become:

BNHV8812A&B

OPENING THRUST REQUIREMENTS 4482 LBS CLOSING THRUST REQUIREMENTS 4607 LBS

EFPDV0019, 20 ESW SELF CLEANING STRAINER DRAIN DP CONTROL VALVE

These valves are routinely operated under DP conditions during ESW pump runs. However, the MOVATS test equipment has not been installed on these valves so measured thrust requirements to overcome DP conditions is unknown. EFHV0097 and 98 are identical valves which are also routinely DP tested during ESW pump operation and have been diagnostically tested under DP conditions. The DP data for EFHV0097 and 98 however, is not being used for comparison purposes because the thrust requirements can be more conservatively determined using calculations. The DP data for EFHV0097 was less than spring pack preload and the required thrust analysis for EFHV0098 is based on a very conservative spring pack displacement value not attributable to DP effect 13. In addition, EFPDV0019 and 20 have been determined to not have an active safety function to close per RFR 5353S so closing thrust requirements are not critical and can be determined conservatively using analytical methods. Referring to Attachment 2 the thrust requirements for EFPDV0019 and 20 are calculated using a valve factor of 1.0 as follows:

EFPDV0019 & 20

OPENING THRUST REQUIREMENTS 834 LBS CLOSING THRUST REQUIREMENTS 1023 LBS

EGHV0011,12,13,14 ESW TO CCW EMERGENCY MAKEUP ISOLATION VALVES

These valves are Yarway 1.5 inch globe valves with flow under the seat. The only safety function for these valves is to open as an emergency makeup water supply for the CCW system. Since the safety function for these valves is to open and flow is under the seat the opening thrust requirements for these valves will be minimal and can be conservatively calculated. Referring to Attachment 2 an opening thrust of 462 lbs and a closing thrust of 560 lbs is obtained using a valve factor of 2.2. The operators for these valves are equipped with heavy spring packs are capable of providing well in excess of these thrust values. For additional conservatism an open and closed thrust requirement of 1500 lbs will be specified.

EGHV00011,12,13,14; OPEN & CLOSED THRUST REQUIREMENT = 1500 LBS:

EGHV0062 RCP THERMAL BARRIER RETURN CCW SYSTEM ISOLATION VALVE

¹³Refer to RFR 8746G ¹⁴Reference RFR 5353S RFR87461.DOC 01/21/94

This MOV has an active safety function to close against 2335 psid and a commercial function to open against 112 psid. The thrust requirements to open are determined below in the discussion for EGHV0132. The thrust requirements to close against 2335 psid were previously calculated in RFR 9878A using slightly different methods. For consistency the thrust requirements for EGHV0062 have been recalculated to be 12984 lbs using a valve factor of .6. This valve factor is considered conservative for this style of valve. This is a Velan parallel slide gate valve that is position closed. This type of valve is designed to operate with lower thrust requirements than their FWG counterparts. In reviewing the EPRI Performance Program no valves were available for comparison. There have been similar valves DP tested at Callaway, i.e. EGHV0061 and 133. However, they were tested at too low a DP to be considered for determining the thrust requirements for EGHV0062.

EGHV0062 OPENING THRUST REQUIREMENT 1220 LBS CLOSING THRUST REQUIREMENT 12984 LBS

EGHV0132 CCW RETURN FROM RCP THERMAL BARRIER EGHV0062 BYPASS ISOLATION VALVE

The DP that these valves may be expected to operate against is 112 psid for commercial considerations¹⁵. Previously these valves had their thrust requirements determined using calculational methods from RFR 9878A. For consistency these thrust requirements are being re-calculated in this RFR Valves EGHV0061 and 133 are identical MOV's that have been DP tested to 94 and 90.5 psid respectively. Referring to Attachment 1 the thrust requirements to overcome these test conditions are as follows:

VALVE ID	TEST DP	CLOSING THRUST 812 LBS	OPENING THRUST 829 LBS
EGHV0061 EGHV0133	94 PSID 90.5 PSID	1609 LBS	983 LBS

Using calculations the thrust requirements for EGHV0133 are 379 lbs closed and 247 lbs open using a DP of 112 psid. Thus, it is apparent that it would be most conservative to use the thrust requirements for EGHV0133 extrapolated to 112 psid to determine the thrust requirements for EGHV0132 (and EGHV0062 in the open direction). Using this method the following thrust values are obtained:

OPEN THRUST VALUE = (983 LBS)(112/90.5) = 1216.5 LBS SAY 1220 LBS CLOSED THRUST VALUE = (1609 LBS)(112/90.5) = 1991 LBS SAY 2000 LBS

EGHV0132 OPEN THRUST REQUIREMENT = 1220 LBS CLOSED THRUST REQUIREMENT = 2000 LBS

 ¹⁵Reference RFR 5353X
 RFR87461.DOC
 01/21/94

EJHV8811A,B RHR PUMP SUCTION ISOLATION VALVES FROM EMERGENCY SUMPS

There are no other valves of the same size at Callaway that have been adequately DP tested for comparison. These are 14" Westinghouse FWG valves. Additionally, there is limited information available in the EPRI Performance Prediction Program for this size and type of valve. What is provided in the EPRI program is an apparent friction coefficient for the 3" Westinghouse FWG valve discussed earlier in the section for BBHV8000A/B. The valve factor for this 3" valve is .328. Because of the limited information with regard to this size of valve and the thrust margin available it is recommended that a 1.0 valve factor be used. Using calculations the thrust requirements for these valves become:

EJHV8811A/B OPEN THRUST REQUIREMENT 7199 LBS CLOSING THRUST REQUIREMENT 7399 LBS

EMHV8807A,B

Because of how the system is aligned when these valve are manipulated there is no DP across these valves when they are required to be operated 16. These valves presently have their thrust requirements established to overcome the stem rejection load (930 lbs per RFR 9878A). However, for commercial considerations these valves should be set up to overcome a DP of 252 psid per RFR 5353X.

Valves EMHV8923A/B are identical valves which have been DP tested against 178 and 180 psid respectively. From RFR 8746G the thrust required to overcome these DP's are as follows:

VALVE ID	THRUST TO OPEN	THRUST TO CLOSE
EMHV8923A	1573 LBS	1929 LBS
EMHV8923B	2148 LBS	3186 LBS

Since these are identical valves that have been DP tested it is recommended that for commercial reasons the thrust requirements for EMHV8807A/B be determined by extrapolating the thrust requirements from EMHV8923B to the commercial DP of 252 psid. Using this method the thrust requirements for EMHV8807A/B are as follows:

(2148 lbs) * (252/180) = 3007.2 lbs SAY 3110 lbs open (3186 lbs) * (252/180) = 4660.4 lbs SAY 4665 lbs closed

Based on the above the commercial thrust requirements for EMHV8807A/B should be established as follows. These commercial requirements bound all safety related thrust requirements.

EMHV8807A/B CLOSED THRUST REQUIREMENT 4665 LBS
OPEN THRUST REQUIREMENT 3110 LBS

EMHV8924

This MOV has no active safety function and is used solely as a maintenance isolation valve. During normal power operation this valve is maintained open with a locking device installed and with electrical power isolated at the breaker. Additionally, this MOV has input into the ESF status panel which would alert operators should it become mispositioned. Based on the above discussion this MOV has been removed from the GL 89-10 program and no thrust requirements are being provided via this RFR.

¹⁶Reference RFR 5353X RFR87461.DOC 01/21/94

ENHV0001,7 CONTAINMENT SPRAY PUMP SUCTION ISOLATION FROM EMERGENCY SUMPS

These valves presently have thrust requirements established using calculations in accordance with RFR 9878A. For consistency the thrust requirements have been recalculated on Attachment 2. This resulted in predicted thrust requirements of 2878 lbs closed and 2786 lbs open.

In referring to the DP tests performed at Callaway the only valves comparable are EGHV0071 and 126. The only significant difference between these models are that ENHV0001/7 are stainless while EGHV0071/126 are carbon steel valves. These are all 12" Anchor Darling FWG models. Listed below are the measured thrust requirements from EGHV0071/126. The DP test for EGHV0071 was at 94 psid and the test for EGHV0126 at 92 psid. The design DP for ENHV0001/7 is 54 psid.

VALVE ID	MEASURED OPEN THRUST	MEASURED CLOSED THRUST
EGHV0071	4885 LBS	5267 LBS
	1982 LBS	4220 LBS
EGHV0126	1702 Livi	

If the DP test thrust measurements for EGHV0071 are de-rated to the design DP of ENHV0001/7 slightly more conservative numbers vs. calculated numbers are obtained for ENHV0001/7. Since ENHV0001/7 are stainless valves it is believed that the valve factor for these valves is lower and requires less thrust than EGHV0071. Based on the discussion above the thrust requirements for ENHV0001&7 are being conservatively established as follows:

OPEN THRUST REQUIREMENT =	(4885 LBS)(54/94) = 2806 say 3000 lbs
CLOSE THRUST REQUIREMENT	(5267 LBS)(54/94) = 3026 say 3100 lbs

ENHV0001 & 7 OPEN THRUST REQUIREMENT = 3000 LBS

CLOSED THRUST REQUIREMENT = 5100 LBS

ENHV0006,12 CONTAINMENT SPRAY PUMP DISCHARGE IS OLATION VALVES

These valves are 10" Anchor Darling stainless steel FWG valves. There have been no other valves at Callaway that have been adequately DP tested that can be considered similar. However, these valves have been DP tested at Wolf Creek. The data sheets from the DP test at Wolf Creek have been provided as Attachment 6.

The DP test at Wolf Creek was under maximum system flow and DP conditions obtainable (232 psid). Under these conditions the thrust required to open against these test conditions (including VOTES equipment accuracy) are documented as 3027 lbs for ENHV0006 and 4848 lbs for ENHV0012. No closing thrust requirements were provided since this valve has no safety function in the closed direction. Note that these thrust numbers are direct stem thrust measurements during the DP test.

Wolf Creek then calculated the disc/seat coefficient of friction for these valves to be .17 and .28 for ENHV0006 and 12 respectively. Using the method described in the discussion for BBHV0013,14,15 & 16 this corresponds to valve factors of .173 and .288 for a 5 degree disc wedge angle. These coefficients of friction validated the .35 value that was assumed at Wolf Creek prior to performing this DP test. Thus, they successfully demonstrated that the .35 friction coefficient was conservative for these valves at Wolf Creek.

Because of the differences in the MOV programs at Wolf Creek and Callaway it is not recommended that DP test thrust measurements be applied directly at Callaway. Instead it is recommended that a conservative valve factor based on the Wolf Creek testing and rate of loading factor be assumed to determine the thrust requirements. Since the Wolf Creek testing validated a coefficient of

RFR87461.DOC 01/21/94 friction of .35 it is recommended that a .4 valve factor be used with a rate of loading factor of 1.20. Using these numbers the thrust requirements are as follows:

ENHV0006 & 12

OPEN THRUST REQUIREMENT

8970 LBS

CLOSED THRUST REQUIREMENT =

9487 LBS

ENHV0015,16 CONTAINMENT SPRAY ADDITIVE TANK TO CONTAINMENT SPRAY PUMP SUCTION

The present thrust requirements for ENHV0015 and 16 originate from RFR 8746C and is based on the thrust requirements of similar valves. The design DP for these valves is 18 psid. RFR 8746C conservatively determines the thrust requirements for these valves to be as follows;

OPENING THRUST CLOSING THRUST VALVE ID REOUTREMENT REQUIREMENT 2801 LBS 4234 LBS ENHV0015 1557 LBS 1938 LBS ENHV0016

These valves are being removed from the plant with the implementation of modification MP 92-1053. This modification is eliminating the containment spray additive tank and thus the need for these valves. This modification is scheduled for implementation spring, 1995.

Based on the conservatism of the present thrust requirements, the low design DP, and the fact that these valves are scheduled for removal from the plant no further action is required for these valves. The thrust requirements presently imposed should continue to be used until these MOV's are eliminated.

EPHV8808A,B,C,D

These valves are listed as having no active safety function to open with an active safety function to close but at zero differential pressure 17. Based on the above it is apparent that the thrust requirements for these valves can be adequately determined using conservative engineering analysis. Using calculational methods and a .5 valve factor the thrust requirements become 26223 lbs open and 30500 lbs closed for a DP of 726 psid. Note that these thrust requirements are for commercial considerations only. As the thrust rating of the operators on these valves is 140,000 lbs it is evident that these thrust requirements can be easily satisfied. For safety considerations these valves must be able to overcome piston effect associated with a line pressure of 726 psid. This value is calculated below:

PISTON EFFECT CALCULATION FOR EPHV8808A, B, C, D

(line pressure)(stem area)(rate of loading factor) Piston effect

(726 psid)(4.9087 lbs)(1.20)

4277 lbs SAY 4300 ibs

Based on the above discussion EPHV8808A,B,C,D have commercial and safety thrust requirements as provided below.

EPHV8808A,B,C & D COMMERCIAL OPENING THRUST REQUIREMENT 26223 LBS COMMERCIAL CLOSING THRUST REQUIREMENT 30500 LBS SAFETY OPEN & CLOSED THRUST REQUIREMENT 4300 LBS

¹⁷Reference RFR 5353X RFRº7461.DOC 01/21/94

KAHV0030

The purpose of this MOV is to provide additional redundancy to the hydrogen recombiners in the event makeup air is needed to purge hydrogen from containment following an accident. This valve was installed in accordance with Reg. Guide 1.7. This valve is not considered to have an active safety function. 18

No other valves of this type have been DP tested at Callaway. Since this valve has no active safety function its thrust requirements can be conservatively determined using calculations. Using this methodology a closing thrust of 276 lbs and an opening thrust of 173 lbs is provided for a design DP of 149 psid assuming a valve factor of 1.0.

KAHV0030 OPENING THRUST REQUIREMENT = 347 LBS CLOSING THRUST REQUIREMENT = 450 LBS

KCHV0253

The valve is a 4 inch VELAN parallel slide gate valve with a design DP of 189 psid open and closed. Two other valves of this size and model (EGHV0061/133) were DP tested 94 and 90.5 psid respectively. However, these test DP's are not within 50% of the design DP of KCHV0253 and thus are not being considered. KCHV0253 is a 4" Velan parallel slide gate valve that typically requires less thrust than the FWG counterparts. No valve of this type is being tested in the EPRI Performance Prediction Program. For conservatism the thrust requirements for this valve will be calculated using a valve factor of 1.0.

KCHV0253 CLOSED THRUST REQUIREMENT = 1507 LBS
OPEN THRUST REQUIREMENT = 1291 LBS

LFFV0095,LFHV0105&106 CONTAINMENT NORMAL SUMP AND AUXILIARY BUILDING SUMP DISCHARGE ISOLATION VALVES

All three of these MOV's were DP tested. However, for LFFV0095 in the closed direction and LFHV0105&106 in both directions they were not tested at a high enough DP to satisfy the criteria of EDP-ZZ-01114. Because of the thrust margin available with these valves the thrust requirements are most easily determined by assuming a valve factor of 1.0 and calculating the thrust requirements. Using this method the thrust requirements become:

LFFV0095	CLOSING THRUS		=	1766 LBS 295 LBS
LFHV0105/106	CLOSING THRUS	T REQUIREMENT	=======================================	548 LBS 532 LBS

ATTACHMENT 1 TO RFR 87461 COMPARISON OF CALCULATED VS MEASURED THRUST VALUES FOR MOV'S DP TESTED AT CALLAWAY

		CALCULATED	MEASURED THRUST CLOSED	MEASURED THRUST OPEN	DP CLOSED	DP OPEN	VALVE MFGR	TYPE	MODEL	SIZE	TYPE	SIZE	STEM DIA	STEM AREA	DIA (pote 4)	DISC	OF LOADING (note 5)	FACTOR (note 6)	PRELOAD
VALVE	CALCULATED			(note 1)	(note 1)	(note 1)	(note 2)	(note 3)	(note 3)	(note 3)	(note 2)	(note 2)	(note 2)	0.3068	2.0000	3.14	1.15	1.5	379
ID.	THRUST CLOSED	THRUST OFEN	(note 1) 3259	2430	1504	1604	MASON	GLOBE	90-207X1	4	SMB	00	0.625	0.3068	2,0000	3.14	1.15	1.1	691
ALHV0005	595C	6374 6355	8282	2535	1599	1599	MASON	GLOBE	90-207X1	4	SMB	00	0.625	0.3068	2.0000	3.14	1.15	11	450
ALHV0007	6928	100000	7059	3057	1624	1624	MASON	GLOBE	90-207X1	4	SMB	00	0.625	0.3068	2 0000	3.14	1.15	11	258
ALHV0009	7036	6454	7324	1622	1624	1624	MASON	GLOBE	90-207X1	4	SMB	00	1.25	1 22716	7.5625	44.92	1.15	0.5	150
ALHV0011	7036	6454	979	3466	14	14	A/D	FW GATE	E6207-5	8	SMB	00	1.25	1 22718	7.5625	44 92	1.15	0.5	332
ALHV9034	381	362	1139	3053	14	14	A/C	FW GATE	E6207-5	. 8	SMB	00	1.25	1 22718	9.8750	61.86	1.15	0.5	281
ALHV0035	381	362	510	2501	14	16	A/D	FW GATE	E6207-4	10	SMB	00	1 125	0.99402	2.6250	5.41	1.15	0.5	1290
ALHV0G36	518	498	N/A	1290	103	193	VELAN	FW GATE	B10-3054P-02	3	SMB	00	1 125	0.99402	2.6250	5.61	1.15	0.5	1278
BBHV0013	458		N/A	1278	113	113	VELAN	FW GATE	B10-3054P-02	3	SMB	00	1 125	0 99402	2.6250	5.41	1.15	0.5	1625
BBHV0014	489	352	N/A	1625	103	103	VELAN	FW GATE	810-3054P-02	3	SM8	00	1 125	0 99402	2.6250	5.61	1.15	0.5	1381
BBHV0015	458	321	N/A	1381	103	103	VELAN	FW GATE	B10-3054P-02	3	SM8	00	1 125	0.99402	1.8750	2.76	1.15	3.1	7966
BBHY0016	458	321	7968	7793	73	73	VELAN	GLOBE	ZTM78FNA	2	SM8	00	1.25	1 22718	2.6200	5.39	1 15	0.5	269
BGHV8104	347	255	10373	2490	2572	2572	WEST	FW GATE	3-GM78FNA	3	58	00	1 25	1 22718	2.6200	5.39	1 15	0.5	226
BGHV8105	11630	7973	12127	4540	2572	2572	WEST	FW GATE	3-GM78FNA	3	SB	00	1 125	0.99402	£ 8750	2.76	1.15	11	8162
BGHV8106	11630	7973	8152	6910	2582	2582	VELAN	GLOBE	P2-6303-N2	2	SMB	00	1 125	0.99402	1.8750	2.76	1 15	11	7039
BGHVB110	12267	9020	7039	6185	2824	2824	VELAN	GLOBE	P2-6303-N2	2	SMB	00	0.625	0.99402	0.3750	0.11	1.15	11	952
BGHV8111	13414	9864	7039	472	2531	0	A/D	GLOBE	70-18-9	. 1	SMB	000	0.625	0.3068	0.3750	0 11	1 15	11	847
BGHV8357A	354	0	847	586	2611	0	A/D	GLOBE	70-18-9	1	SMB	000	1 25	1 22718	6.5050	33.23	1.15	0.5	102
8GHV83578	365	0	1921	4219	197	197	WEST	FW GATE	8GM72FBA	8	SB	00	1 25	1 22718	6.5050	33 23	1.15	0.5	1129
BNHV8806A	4072	3765	1592	2654	197	197	WEST	FW GATE	8-GM72FBA	8	SB	00	1 125	0.99402	1 8750	2.76	1 15	1.1	3230
BNHV88068	4072	3765		9036	1520	1520	VELAN	GLOBE	21M78FNC	2	SMB	00		1 22718	6.3050	33.23	1.15	0.5	313
BNHV8813	7223	5311	3230	4529	193	193	WEST	FW GATE	8GM72FBA	8	SB	00	1 25	A CONTRACTOR OF THE PARTY OF TH	6.5050	33.23	1.15	0.5	1110
NLCV0112E	3999	3690	3025	4963	195	195	WEST	FW GATE	8GM72FBA		SB	00	1.25	0 99402	2.6250	5.41	1.15	0.5	1138
BNLCV0112E	4038	3730	2026	4963 N/A	130	130	VELAN	SW GATE	B10-00548-02	3	SMB	000	1 125	0.99402	2.6250	5.41	1.15	0.5	523
EFHV0097	553	405	1138		125	125	VELAN	SW GATE	B10-0054B-02	3	SMB	000	1 125	1.0.00	11 9379	111.92	1.15	0.4	3767
EFHW0098	632	3.89	1515	N/A	95	95	AD	DBL DISC	E6207-1	12	SMB	00	1 625	2.07394	10.000	111 92	1.15	0.4	1314
EGHV0058	5175	4891	5545	5420	98	98	A/D	DBL DISC	E6207-1	12	SMB	00	1 625	2 07394		111.92	1 15	0.4	
EGHV9059	5332	5045	5105	5458	98	94	A/D	DBL DISC	E6207-1	12	SMB	00	1 625	2.07394		5.94	1 15	0.4	812
EGHV0060	5121	4840	9682	5394	94	94	VELAN	PDG	812-01448-02		SMB	000	1.125	0 99402	2.7500	89.71	1 15	0.5	276
EGHVD061	394	257	812	829	94	94	A/D	FW GATE	E6207-3	12	SMB	60	1.373	1 48489		1 92	1 15	11	1233
EGHV0071	5054	4849	5267	4885	103	103	YARWAY	GLOBE	5515B-SA105M	2	SMB	000	0.937	0.68956		1.92	115	11	1497
EGHV0072	340	250	N/A	1233	103	103	YARWAY	GLOBE	5515B-SA105M	2	SMB	000	0.937	0.6895€	A STATE OF THE PARTY OF THE PAR	1.92	1 15	11	2259
EGHV0073	340	250	NA	1497	103	103	VARVVAY	GLOBE	5515B-SA105M	2	SMB	300	0.937	0.58936		1.92	1 15	11	2466
EGHV0074	340	250	N/A	2259	103	103	YARWAY	GLOBE	5515B-SA105M	2	SMB	000	0.937	0.68956		89.71	1 15	0.5	556
EGHV0075	340	250	N/A	2466	92	92	AD	FW GATE	E6207-3	12	SMB	00	1.375	1 48486		111.90		0.4	150
EGHV0126	4951	4746	4220	1982		99	A/D	DBL DISC	E6207-1	12	SMB	00	1.625	2 07394		111.90	and the second second second second	0.4	230
EGHV0127	5381	5097	8539	3448	99	88	AID	DBL DISC	E6207-2	12	SM8	00	1.625	2 07394		111.9		0.4	391
EGHV0130	4798	4531	4564	2165	98	98	AD	DBL DISK	E6207-21	12	SMB	00	1 625	2 07394		5.94	115	0.4	309
EGHV0131	5332	5045	6311	4321	96	96	VELAN	PDG	B10-0144B-02	- 6	SMB	000	1 125	0.9940		5.39	1.15	0.5	134
EGHV0133	379	247	1609	983	208	208	WEST	FW GATE	3-GM88FNB	3	SMB	000	1 125	0.9940		5.39	1 15	0.5	330
E.PCV0610	The second second	645	809	816		201	WEST	FW GATE	3-GM88FNB	3	SMB	000	1 125	0.9940	A Commission of the Control of the	78.93	The state of the s	0.5	0
EJFCV061		623	857	507	201	189	WEST	FW GATE	10000GM84FEB	10	SB	1	2.5	4 9087			The second second	0.5	472
EJHV87168	The second secon	8951	NA	10611	189	128	WEST	FW GATE	UBDODGM84FEB	8	SB	00	1.25	1 2271		33.23		0.5	349
EJHV8804/	The second second second second	2446	7314	2733	161	153	WEST	FW GATE		Access to the second	SB	00	1.25	1.2271		33.23		0.5	29983
EJHV88049	The second secon	2923	4070	3522	153	The second second		FW GATE	1DGM78FNC	10	SBD	. 3	2.5	4 9087		60.20		0.5	12006
EJHV8809/	The second second second	6646	29983	38350	184	184	WEST.	FW GATE		10	580	3	2.5	4.9087		60.20		0.5	17170
EJHV8809		6827	20466	13337	189	189		PW GATE	10GM78FNC	10	SBD	3	2.5	4 9087		60.20	The second second	0.5	443
EJHV8840		6827	17170	14363	189	189	WEST.	FW GATE	The second secon		SBD	00	1.25	1.2271		9.29		0.5	255
FMHV8801		14309	4221	4458	2677	2577	WEST	A CONTRACTOR OF STREET		A CONTRACTOR OF THE	580	00	1.25	1.2271					551
EMHV8801	A STATE OF THE PARTY OF THE PAR	14309	2815	6062	2677	2677	WEST	FW GATE	The second secon	and the same of th	580	00	1 25	1 2271		9.29		0.5	541
	The second second second second	3677	3767	1357	688	688	WEST	FW GATE	A STATE OF THE PARTY OF THE PAR		SBD	00	1.25	1.2271		and the same of the same		0.5	235
EMHV8802		3516	2787	2009	656	658	WEST	FW GATE	THE RESERVE THE PROPERTY OF THE PARTY OF THE		SBD	00	1 25	1 2271				0.5	599
EMHV8802	The second second	14575	4632	10586	2727	2727	WEST	FW GATE		and the same of the same of	580	00	1.25	1 2271	8 3.4400	9.29	1 15	0.5	599
EMHV8803	A 18424 B 18253	14440	1567	3760	2702	2702	WEST	FW GATE	04000GM88FNB	4	300			_	-				

Notes:

- 1. From RFR 8746G
- 2. From CEL
- 3. From valve drawings.
- 4. Anchor Darling values from RFR 5353, Westinghouse values from attachment 5. Rest from valve drawings
- 5. From Attachment 3.
- 6. Refer to RFR text.

ATTACHMENT 1 TO RFR 87461 COMPARISON OF CALCULATED VS MEASURED THRUST VALUES FOR MOV'S DP TESTED AT CALLAWAY

			MEASURED	MEASURED	TEST	TEST							STEM		DISC		RATE OF	VALVE	
VALVE	CALCULATED	CALCULATED	THRUST	OPEN	CLOSED (note 1)	OPEN (note 1)	MFGR (note 2)	TYPE (note 3)	MODEL (note 3)	SIZE (note 3)	TYPE (note 2)	sizf (ngle 2)	(note 2) 1 125	AREA 0 99402	DIA (pote f)	AREA 2.76	(note 5)	(note 6)	PRELOAD 6754
(0)	THRUST CLOSED		(note 1)	(note 1) 8055	(note 1) 1515	1515	VELAN	GLOBE	1-1/2-TM78FN	1.5	SMB	00	1 125	0.99402	1 9750	2.76	1.15	0.5	6697
MHV8814A	7199	5293	675A		1520	1520	VELAN	GLOBE	-1/2-TM78FN	1.5	SMB	00		1.22718	3.5000	9.62	1 15	0.5	486
MHV88148	3282	2413	5697	7200	1595	1595	WEST	FW GATE	04000GM87FHB	4	58	00	1.25	1 22718	3 5000	9.62	1 15	0.5	447
MHV8821A	11117	8824	3934	4299	1540	1540	WEST	FW GATE	04000GM87FHB	4	58	00	1.25		1.4400	9.29	1.15	0.5	480
MHV88219	10735	8520	2709	4249	1595	1595	WEST	FW GATE	04000GM88FNB	4	580	00	1.25	1 22718	6.0650	28.89	1 15	0.5	820
EMHV8835	10502	8524	NA	3650	178	178	WEST	FW GATE	06001GM92FBB	- 6	SMB	00	1 25	1.22718		28.89	1.15	0.5	815
MHV8923A	3239	2957	1573	1929		180	WEST	FW GATE	06001GM92FBB	6	SMB	00	1.25	1.22718	6.0650		1 15	1.1	971
MHV89238	3272	2990	2148	3186	180	Accessed to the same		GLOBE	82-14097A	. 4	SMB	000	1 125	0.99402	1 4950	1.76		0.5	420
FCHV0312	N/A	2387	NIA	1921	1075	1075	GIMPEL	FW GATE	E6118-5	- 6	SMB	00	1	0.7854	3 7188	25 69	1 15	0.5	543
	89	81	283	645	6	- 6	A/D		E6118-10	6	SMB	000	- 1	0.7854	5.7188	25.69	1 15	0.5	831
LFFV0095	127	114	543	1409	8	8	A/D	FW GATE	£6118-10	6	SMB	000	1	0.7854	5.7188	25 69	1.15	0.0	431
LFHV0105	127	114	831	1242	8	- 8	A/D	FW GATE	E0110/10	-	-	-							

Notes:

- 1. From RFR 8746G
- 2. From CEL
- 3. From valve drawings.
- 4. Anchor Darling values from RFR 5353, Westinghouse values from attachment 5. Rest from valve drawings.
- 5. From Attachment 3.
- 6. Refer to RFR text.

ATTACHMENT 2 TO RFR 87461 CALCULATED THRUST VALUES FOR VALVES EVALUATED IN RFR 87461

	DESIGN DP OPEN	DESIGN DP	WIO ERROR AND	CALCULATED THRUST OPEN W/O ERROR AND STEM LOAD	RATE OF LOADING (note 2)	VALVE FACTOR (note 5)	STEM AREA	DISC	VALVE MFGR (note	TYPE (nots 4)	MODEL (note 4)	SIZE (note 4)	TYPE (notat 1)	\$12'E (note 1)	STEM DIA (note 1)	DISC DIA
VALVEID	(note 1)	(ngte 1)	STEM LOAD	846	1 15	0.50	1 22718	44.92	A/D	FW GATE	E6207-5	6	SMB	00	1.25	7.5625
ALHV0034	25	135	3877	646	1.15	0.50	1 22718	44.92	A/D	FW GATE	E8207-5	8	SMB	00	1 25	N 8750
ALHV0035	25	135		889	1.15	0.50	1 22718	61.88	A/D	FW GATE	E6207-4	10	SMB	00	1.25	2 6250
ALHV0036	25 4 8		4993	361	1 15	0.40	0.99402	5.41	VELAN	FW GATE	B10-3054P-02	3	SMB	00	1 125	
B8HV0013	145 # 9	2335	8482	361	1 15	0.40	0.99402	5.41	VELAN	FW GATE	B10-3054P-02	3	SMB	00	1 125	2.6250
BBHV0014	245 15	Education of the State of the S	8482	361	1.15	0.40	0.99402	5.41	VELAN	FW GATE	B10-3054P-02	3	SMB	00	1 125	2 62 90
3BHV0015	145	2335	8482	361	1.15	0.40	0.99402	5.41	VELAN	FW GATE	B10-3054P-02	3	SMB	00	1 125	2 6250
BBHV0016	145	2335	8482	9244	1.15	0.50	0 99402	5 39	WEST	FW GATE	3-GM88FNB	3	SB	-00	1 125	2.6200
BBHV8000A	2485	2335	11355	9244	1.15	0.60	0.99402	5.39	WEST	FW GATE	3-GM88FNB	3	SB	00	1 125	2 6200
BBHV8000B	2485	2335	11355	1190	1.15	1.00	1 22718	9.95	WEST	FW GATE	040000GM-82F	4	SB	00	1 25	3.5600
BBHV8037A	104	104	1337		1 15	1.00	1 22718	9.95	WEST	FW GATE	040000GM-82F	4	SB	00	1.25	3.5600
BBHV8C37B	104	104	1337	1190	1 15	1 10	0.99402	2.76	VELAN	GLOBE	2TM78FNA	2	SMB	00	1 125	1.8750
BBHV8351A	2813	2813	13363	9625	1 15	1 10	0.99402	2.76	VELAN	GLOBE	2TM78FNA	2	SMB	00	1 125	1.8750
BBHV8351B	28*3	2813	13383	9825		1 10	0.99402	2.78	VELAN	GLOPE	2TM78FNA	2	SMB	00	1 125	1.8750
BBHV8351C	2813	2813	13363	9825	1 15	1.10	0.99402	2.76	VELAN	GLOBE	2TM7BFNA	2	SMB	00	1 125	1.8750
BBHV8351D	2813	2813	13363	9825	1 15		7 08858	86 67	WEST	FW GATE	12002GM885EH	12	SMB	2	3	10.5050
BBPV8702A	380	484	28065	19761	1 20	0.50	7 06858	88 67	WEST	FW GATE	12002GM885EH	12	SMB	2	3	10.5050
BBPV8702B	380	464	28065	19761	1 20	0.50	0.99402	2.78	VELAN	GLOBE	P2-8303-N2	2	SMB	00	1 125	1.8750
BGHV8100	155	155	738	541	1 15	1 10		2 76	VELAN	GLOBE	P2-6303-N2	2	SMB	00	1.125	1.8750
BCHV8109	94	2818	13386	328	1 15	1 10	0.99402	278		GLOBE	P2-6303-N2	2	SMB	00	1.125	1.8750
BGHVc112	155	155	736	541	115	1.10	0.99402		VELAN	SW GATE	040000GM82FB	4	SB	00	1.25	3.5600
BGLC VOTT2B	100	100	1288	1145	1.15	1 00	1.22718	9 95	WEST	A CONTRACTOR OF THE PARTY OF TH	04000GM82FBB	4	SB	00	1.25	3.5600
BGLCV0112C	100	100	1288	1145	1 15	1 00	1.22718	9.95	WEST	SW GATE	E6118-3	12	SMB	00	1 375	10 6875
BNHV0003	32	32	3358	3301	1 15	1.00	1.48489	89.71	A/D	FW GATE	E6118-3	12	SMB	00	1 375	10.6875
BNHV0004	32	32	3358	3301	1 15	1.00	1.48489		A/D	FW GATE	14GM74FEC	14	SB	1	2	12.0050
BNHV8812A	33	33	4607	4482	1 20	1.00	3 14159		and the second section is a second section in the	FW GATE	14GM74FEC	14	SB	1	2	12 0050
BNHV8812B	33	33	4607	4482	1.20	1.00	3 14159	Acres de la companya del la companya de la companya		FW GATE	And the second section is a second section of the second section of the second section is a second section of the second section section is a second section of the second section sec	3	SMR	0	1.25	2.6250
EFPDV0019	134	134	1023	834	1.15	1.00	1.22718	Acres and the second	VELAN	SW GATE	B10-0054B-02 B10-0054B-3	4	SMB	1	1.25	2.6250
EFPDV0020	134	134	1023	834	1 15	1.00	1.22718	Annual Contract of the Contrac	VELAN	SW GATE	55158	15	SMB	000	0.937	1 3750
	123	123	560	462	1 15	2.20	0 68956	1.48	YARWAY	GLOBE	A second	1.5	SMB	000	0.937	1 3750
EGHV0011	A CONTRACTOR OF THE PARTY OF TH	122	555	458	1 15	2.20	0 68956	Access to the	YARWAY	GLOBE	55158	15	SMB	000	0.937	1 3750
EGHV0012	122	123	560	462	1 15	2.20	0.68956		YARWAY	GLOBE	55158	15	SMB	000	0.937	1 3750
EGHV0013	123	122	555	458	1 15	2.20	0.68956		YARWAY		55158	1 A	SMB	0	1 125	2.7500
EGHV0014	122	2335	12984	487	1 22	0.60	0.99402	5.94	VELAN	PDG	B12-0144B-02	1 2	SMB	00	1 125	2.7500
EGHV0062	112	112	434	308	1 15	0.40	0 99402		VELAN	PDG	B12-3144P	12	SMB	2	3	10.50%
EGHV0132	112	464	28065	19781	1 20	0.30	7.06858			FW GATE	12002GM88SEH	12	SMB	1 2	3	10.5059
EJHV8701A	360	484	28085	19781	1.20	0.50	7 06858	86 67	WEST	FW GATE	12GM88SEF	14	SB	1 1	2	12.00%
EJHV8701B	380	-	7399	7199	1 20	1.00	3 14159	113 1	9 WEST	FW GATE	14000GM84FEH	14	SB	-	2	12.00%
EJHV8811A	53	53	7399	7100	1 20	1 00	3 14159	113 1	9 WEST	FW GATE	14000GM84FEH	6	SMB	00	1.25	6.0650
EJHV8811B	53	53	4542	4186	1.15	0.50	1 22718	28 89	WEST	FW GATE	060001GM92FB	6	SMB	00	1 25	6.06%
EMHV8807A	252	252	4542	4186	1.15	0.50	1.22718	28 89	WEST	FW GATE	060001GM92FB		SMB	00	1 375	10.687
EMHV8807B	252	252	2878	2786	1 15	0.50	1.48489	89 71	A/D	FW GATE	E6118-4	12	SMB	00	15	0.874
ENHV0001	54	54	9487	8970	1 20	0.40	1.78711	78 56	Q/A	FW GATE		10	and the second second	00	1 375	10.687
ENHV0006	244	244		2786	1 15	0.50	1 48489	89 71	A/D	FW GATE	And the second of the second o	12	SMB		15	0.8.3
ENHV0007	54	54	2878	8970	1 20	0.40	1.76715	78 59	C/A F	FW GATE	E6118-1	10	SMB	00	0.75	3.0680
ENHV0012	244	244	9487	77	1 15	0.50	0.44175	and the second	A/D	FW GATE	E6118-2	3	SMB	00	0.75	3.068
ENHV0015	18	18	86	77	1 15	0.50	0.44179		the second second second second	FW GATE	E6118-2	3	SMB	00		8.75%
ENHV0018	18	18	86		1.20	0.50	4 9057		and the second second	FW GATE		10	SBD	3	2.5	8 75%
EPHV8808A	726	728	30500	26223	1 20	0.50	4 9087		Section 19	FW GATE	10000GM88FNH	10	SBD	3	2.5	8 75%
EPHV88088	726	728	30500	26223	1 20	0.50	4 9087		Carlotte and the second	FW GATE	A DECEMBER OF THE PROPERTY OF THE PERSON NAMED IN COLUMN TWO PERSONS ASSESSMENT OF THE PERSON NAMED IN COLUMN TWO PERSONS ASSESSMENT OF THE PERSON NAMED IN COLUMN TWO PERSONS ASSESSMENT OF THE PERSON NAMED IN COLUMN TWO PERSON NAMED IN C	10	SSD	3	2.5	8 (3.9
EDHVARORC	728	728	30500	26223	1.29	0.30	4 000	00.61	A T ALL OF	and the second second second	And in case of the last of the					

- 1. Some design DP's are for commercial reasons. CEL has design basis DP's.
- 2. From Att 3
- 3. A/D valves seat dia from 5353 analysis, West. valves from Att 5. Rest from drawings.
- 4. From drawings
- 5. Refer to RFR text.

ATT2.XLS 1/21/94 1 of 2

ATTACHMENT 2 TO RFR 87461 CALCULATED THRUST VALUES FOR VALVES EVALUATED IN RFR 87461

	DESIGN DP OPEN	DESIGN OP	WIO ERROR AND	ERROR AND STEM	ACC 100 100 100 100 100 100 100 100 100 1	VALVE FACTOR (note 5)	STEM	DISC	VALVE MFGR (note	TYPE (note 4)	MODEL (note 4)	SIZE (note 4)	TYPE (note 1)	SIZE (note 1)	STEM DIA	
VALVE ID	(note 1)	(nate 1)	STEM LOAD	LOAD	(note Z)		4.90874	60.20	WEST	FW GATE	10000/GM88F:NH	10	SBD	3	4 4 4	
EPHV8808D	728	726	30500	26223	1.20	A comment of the same				SWIGATE		1.5	SMB	000	0.875	1.5050
		-	450	347	1.15	1.00	0.60132	2.02	WARNER		17015		SMB	000	1.125	2.7500
KAHV0930	149	149	The second secon	1291	1.15	1.00	0.99402	5.94	VELAN	PDG	1015		A CONTRACTOR OF THE PARTY OF TH	00	-	5.7188
KCHV0253	189	189	1507			1.00	0.7854	25.69	A/O	FW GATE	E6118-5	- 6	SMB			Acres de la constante de la co
	40	58	1788	295	1 15		1		Account to the second	Company of the Park of the Par	E6118-10		SMB	000		5.7188
LFFV0095	10	A STATE OF THE PARTY OF THE PAR	and the second second second second	532	1 15	1.00	ti. 785	25 69	A/D	FW GATE			0340	000	4	5.7188
LFHV0105	18	18	548	334		1.00	0.7854	25 69	A/D	FW GATE	E6118-10	. 5	SMB	000	_	
with the second colored	1	4	548	532	1.15	5.00	0.004	And the second	and the second liverage of the second	And in concession of the later						

Notes:

- 1. Some design DP's are for commercial reasons. CEL has design basis DP's.
- 2. From Att 3
- 3. A/D valves seat dia from 5353 analysis, West. valves from Att 5. Rest from drawings.
- 4. From drawings
- 5.Refer to RFR text.

ATT2 XLS 1/21/94 2 of 2

ATTACHMENT 3

RATE OF LOADING FACTORS USED IN RFR 87461

The following rate of loading factors are used in RFR 87461. These rate of loading factors are based on information contained in MOVATS Engineering Report 5.0 Rev 6 page 20 of 20 attached.

ACTUATOR SIZE	ROL FACTOR
SMB-000	1.15
SMB-00	1.15
SBD-00	
SB-00	
SMB-0	1.22
SMB-1	1.20
SBD-1	
SB-1	
SMB-2	
SB-2	
SMB-3	
SBD-3	

PFR 8746I ATT 3 Pg aga ER-5.0, Rev. 6 Page 20 of 20

TABLE 3 Load Rate Testing Summary Belleville Spring Testing

LOAD RATE

Actuator	Overall	Force (Disp (in/Sec)	% Difference			
	Actuator Ratio	Max	Min	Max	Min	.08"	0.16"	0.28"
SMB-1	27.2:1	250,000	22,000	1.3	0.13	18	14	14
SMB-1	88.4:1	82,000	9,000	0.5	0.04	12	11	11
SMB-1	72.42:1	99,000	10,000	0.52	0.09	17	14	14
SB-0	39.11:1	500,000	75,000	5.5	0.8	18	15	10
SB-0	95.2:1	220,000	26,000	2.7	0.4	25	26	18
SMB · O	69.59:1	110,000	15,000	1.1	0.2	22	21	21
SMB-00	72.0:1	48,000	4,500	0.83	0.07	14	12	12
SMB-00	23.0:1	130,000	12,000	2.30	0.21	13	13	10
SMB-00	72.0:1	45,000	5,000	0.8	0.1	-5	- 5	- 5
SMB-00	41.0:1	88,000	9,000	1.6	0.17	- 5	-6	-7
SMB-00	23.0:1	108,000	15,000	4	0.7	8	5	-11
SMB-00	72.0:1	35,000	5,000	1.8	0.3	4	2	- 5
SMB-000	33.5:1	13,500	4.000	1.6	0.5	10	7	5
SMB-000	36.0:1	15,000	4,000	1.7	0.5	9	11	11
SMB-000	75.0:1	6,700	1,700	0.75	0.2	13	10	9

*Percent difference between force at fast-load-rate and force at slow-load-rate at a given spring pack displacement.

i.e., At .08" of spring pack displacement:

Thrust at maximum load rate * 15,000 lbs Thrust at minimum load rate = 12,300 lbs

% difference = 15.000-12.300 x 100 = 18 15,000

for SmB-004 2 lee . 15

DOUDS

Sm8-0 Alse . 22 1's ratione . 20

BEST AVAILABLE COPY

ATTACHMENT 4 SUMMARY OF THE THRUST VALUES DETERMINED IN RFR 87461

ALVE ID	CLOSED THRUST REQUIREMENT	OPEN THRUST REQUIREMENT	PRA SIGNIFICANCE	METHOD USED FOR DETERMINING THRUST REQUIREMENT	NOTES
LHV0034	3677	UNCHANGED	LOW	SIMILAR VALVES DP TESTED VALIDATED CALULATIONS VS DP TEST RESULTS THEN USED CALCUALTIONS FOR ALHV0034	OPEN THRUST REQUIREMENT BASED ON DP TESTING
1.HV0035	3677	UNCHANGED	LOW	SIMILAR VALVES OP TESTED. VALIDATED CALULATIONS VS OP TEST RESULTS THEN USED CALCUALTIONS FOR ALHVO035	OPEN THRUST REQUIREMENT BASED ON DP TESTING
	4903	UNCHANGED	LOW	SIMILAR VALVES OF TESTED VALIDATED CALULATIONS VS OF TEST RESULTS THEN USED CALCUALTIONS FOR ALHVOOR	OPEN THRUST REQUIREMENT BASED ON DP TESTING
J.HV0036		UNCHANGED	NONE	USED CALCULATION WITH A 4 VALVE FACTOR BASED ON EPRI PERFORMANCE PREDICTION PROGRAM RESULTS	OPEN THRUST REQUIREMENT BASED ON DP TESTING
3BHV0013	8482	UNCHANGED	NONE	USED CALCULATION WITH A .4 VALVE FACTOR BASED ON EPRI PERFORMANCE PREDICTION PROGRAM RESULTS	OPEN THRUST REQUIREMENT BASED ON DP TESTING
3BHV9014		UNCHANGED	NONE	USED CALCULATION WITH A 4 VALVE FACTOR BASED ON EPRI PERFORMANCE PREDICTION PROGRAM RESULTS	OPEN THRUST REQUIREMENT BASEL ON DP TESTING
BBHV0015	8482	UNCHANGED	NONE	USED CALCULATION WITH A 4 VALVE FACTOR BASED ON EPRI PERFORMANCE PREDICTION PROGRAM RESULTS	OPEN THRUST REQUIREMENT BASEL ON DP TESTING
BBHV0016	8482	9244	MEDIUM	COMPARED DP DATA WITH SIMILAR VALVES. USED CALCULATIONS WITH A 6 VALVE FACTOR TO DETERMINE FINAL THRUST NUMBERS	
BBHV8000A	11355	9244	LOW	COMPARED DP DATA WITH SIMILAR VALVES. USED CALCULATIONS WITH A 6 VALVE FACTOR TO DETERMINE FINAL THRUST NUMBERS	
BBHV8000B	11355	1190	NONE	COMPARED SIMILAR VALVES THAT WERE DP TESTED. USED CALCULATIONS WITH A LO VALVE FACTOR TO DETERMINE FINAL THRUST NUMBERS BECAUSE OF MARGIN AVAILABLE	
BBHV8037A			NONE	COMPARED SIMILAR VALVES THAT WERE DP TESTED. USER CALCULATIONS WITH A 1.0 VALVE FACTOR TO DETERMINE FINAL THRUST NUMBERS BECAUSE OF MARGIN AVAILABLE	
BBHV8037B	1337	7039	NONE	USED THRUST REQUIREMENTS FROM AN IDENTICAL VALVE TESTED UNDER LARGER OP AND FLOWRATE.	OPEN AND CLOSED THRUST

SUMMARY OF THE THRUST VALUES DETERMINED IN RFR 87461

	CLOSED THRUST	OPEN THRUST REQUIREMENT	PRA SIGNIFICANCE	METHOD USED FOR DETERMINING THRUST REQUIREMENT	NOTES
ALVEID	REQUIREMENT				OPEN AND CLOSED THRUST REQUIREMENTS PROVIDED ARE FOR COMMERCIAL CONCERNS
3BHV8351B	7039	7039	NONE		OPEN AND CLOSED THRUST REQUIREMENTS PROVIDED ARE FOR COMMERCIAL CONCERNS
3BHV8351C	7039	7039		USED THRUST REQUIREMENTS FROM AN IDENTICAL VALVE TESTED UNDER LARGER DP AND FLOWRATE.	OPEN AND CLOSED THRUST REQUIREMENTS PROVIDED ARE FOR COMMERCIAL CONCERNS.
BBHV8351D	7039	7039	NONE	USED CALCULATIONS WITH A 5 VALVE FACTOR	
BBPV8702A	28065	19761	LOW	USED CALCULATIONS WITH A 5 VALVE FACTOR	
BBPV8702B	28065	19761	LOW	BASED ON THRUST REQUIREMENTS OF IDENTICAL VALVE TESTED AT HIGHER DP AND FLOWRATE.	
BGHV8100	7039	7039	NONE	CLOSED THRUST BASED ON REQUIREMENTS OF IDENTICAL VALVE TESTED AT HIGHER DP AND FLOWRATE. OPEN THRUST BASED ON CALCS.	
BGHV8109	7039	7039	NONE	BASED ON THRUST REQUIREMENTS OF IDENTICAL VALVE TESTED AT HIGHER DP AND FLOWRATE	
BGHV8112	4221	6062	LOW	BASED ON THRUST REQUIREMENTS OF IDENTICAL VALVE TESTED AT HIGHER DP AND FLOWRATE	
BGLCV0112B BGLCV0112C	4221	6062	LOW	BASED ON THRUST REQUIREMENTS OF IDENTICAL VALVE TESTED AT HIGHER DP AND FLOWRATE	
BNHV0003	3356	3301	LOW	COMPARED THRUST REQUIREMENT OF SIMILAR VALVES THEN DETERMINED REQUIREMENTS BASED ON CALCS AND A VALVE FACTOR OF 1.0 FOR CONSERVATISM	
	1356	3301	LOW	COMPARED THRUST REQUIREMENT OF SIMILAR VALVES THEN DETERMINED REQUIREMENTS BASED ON CALCS AND A VALVE FACTOR OF 1 0 FOR CONSERVATISM	
BNHV0004	4607	4482	LOW	CALCULATIONS WITH A VALVE FACTOR OF 1.0	
BNHV8812A		4482	LOW	CALCULATIONS WITH A VALVE FACTOR OF 1.0	THE PROPERTY BEAUTIFFE ADD
BNHV8812P	4607	R14		CALCULATIONS WITH A VALVE FACTOR OF 1.0	CLOSE THRUST REQUIREMENTS ARE FOR COMMERCIAL CONCERNS
EFPDV0019	1023	R34		CALCULATIONS WITH A VALVE FACTOR OF 1.0	CLOSE THRUST REQUIREMENTS ARI
EFPDV0020	1023	1500	NONE	THRUST REQUIREMENTS BOUND CALCULATIONS USING A VALVE FACTOR OF 2.2.	CLOSE THRUST REQUIREMENTS ARE FOR COMMERCIAL CONCERNS

ATTACHMENT 4 SUMMARY OF THE THRUST VALUES DETERMINED IN RFR 87461

ALVE ID	CLOSED THRUST	OPEN THRUST REQUIREMENT	PRA SIGNIFICANCE	METHOD USED FOR DETERMINING TH3UST REQUIREMENT	NOTES
ALVE ID	REQUIREMENT	1500	NONE	THRUST REQUIREMENTS BOUND CALCULATIONS USING A VALVE FACTOR OF 2.2.	CLOSE THRUS; REQUIREMENTS ARE FOR COMMERCIAL CONCERNS
GHV0012	1500		NONE	THRUST REQUIREMENTS BOUND CALCULATIONS USING A VALVE FACTOR OF 2.2.	CLOSE THRUST REQUIREMENTS ARE FOR COMMERCIAL CONCERNS
GHV0013	1500	1500	NONE	THRUST REQUIREMENTS BOUND CALCULATIONS USING A VALVE FACTOR OF 2.2.	CLOSE THRUST REQUIREM. TS ARE FOR COMMERCIAL CONCERNS
GHV0614	1500	1220	NONE	CALCULATIONS WITH A VALVE FACTOR OF 6 CLOSED AND SIMILAR VALVES THAT WERE DP TESTED IN THE OPEN DIRECTION	OPEN THRUST REQUIREMENTS ARE FOR COMMERCIAL CONCERNS
GHV0062	12984	1220	NONE	SIMILAR VALVES THAT WERE DP TESTED	THRUS I REQUIREMENTS ARE FOR COMMERCIAL CONCERNS. VALVE HAVE NO ACTIVE SAFETY FUNCTION.
EGHV0132	28065	19761	LOW	USED CALCULATIONS WITH A 5 VALVE FACTOR	
JHV8701A	28065	19761	LOW	USED CALCULATIONS WITH A 5 VALVE FACTOR	
JHV8701B	7399	7199	MEDIUM	CALCULATIONS WITH A VALVE FACTOR OF LO	A CONTRACTOR OF THE PARTY OF TH
EJHV8811A		7199	MEDIUM	CALCULATIONS WITH A VALVE FACTOR OF 1.0	
EJHV8811B	7399			SIMILAR VALVES THAT WERE DP TESTED	THRUST REQUIREMENTS FOR COMMERCIAL CONCERNS. SAFETY RELATED DP IS 0 PSID. NUMBERS BASED ON 252 PSID.
EMHV8807A	4665	3110	LOW	SIMILAR VALVES THAT WERE DP TESTED	THRUST REQUIREMENTS FOR COMMERCIAL CONCERNS. SAFETY RELATED DP IS 0 PSID. NUMBERS BASED ON 252 PSID.
EMHV8807B	4665	3110	LOW	SIMILAR VALVES THAT WERE DP TESTED	
ENHV0001	3100	3000		USED CALCULATION WITH A 5 VALVE FACTOR. VALVE FACTOR CONSISTENT WITH EPRI PREDICTIVE PROGRAM RESULTS	CLOSED THRUST REQUIREMENTS ARI FOR COMMERCIAL CONCERNS. NO ACTIVE CLOSE FUNCTION.
ENHV0006	9487	8970	LOW	SIMILAR VALVES THAT WERE DP TESTED	
ENHV0007	3100	3000	LOW	USED CALCULATION WITH A 5 VALVE FACTOR. VALVE FACTOR CONSISTENT WITH EPRI PREDICTIVE PROGRAM RESULTS	CLOSED THRUST REQUIREMENTS ARE FOR COMMERCIAL CONCERNS. NO ACTIVE CLOSE FUNCTION.
ENHV0012 ENHV0015	9487 NO CHANGE	NO CHANGE	NONE	SIMILAR VALVES DP TESTED UNDER BOUNDING CONDITIO	NS VALVES BEING ELIMINATED IN 1995
ENHV0016	NO CHANGE	NO CHANGE	NONE	SIMILAR VALVES DP TESTED UNDER BOUNDING CONDITIO	NS VALVES BEING ELIMINATED IN 1996


ATTACHMENT 4 SUMMARY OF THE THRUST VALUES DETERMINED IN RFR 87461


VALVE ID	CLOSED THRUST REQUIREMENT	OPEN THRUST REQUIREMENT	PRA SIGNIFICANCE	METHOD USED FOR DETERMINING THRUST REQUIREMENT	NOTES
EPHV8808A	30500 4100	26223 4300	NONE	CALCULATIONS WITH A 3 VALVE FACTOR	COMMERCIAL THRUST VALUES PROVIDED FIRST WITH SAFETY THRUST VALUES (4300 LBS) PROVIDED NEXT.
FPHVRRORB	30500 4300	26223 4300	NONE	CALCULATIONS WITH A .5 VALVE FACTOR	COMMERCIAL THRUST VALUES BASEL ON DP OF 726 PSID. VALVE HAS SAFETY RELATED DP OF 0 PSID.
	30500 4300	26223 4300	NONE	CALCULATIONS WITH A .5 VALVE FACTOR	COMMERCIAL THRUST VALUES BASEL ON DP OF 726 PSID. VALVE HAS SAFETY RELATED DP OF 6 PSID.
EPHV8808C	30500 4300	26223 4300	NONE	CALCULATIONS WITH A .5 VALVE FACTOR	COMMERCIAL THRUST VALUES BASE ON DP OF 726 PSID. VALVE HAS SAFETY RELATED DP OF 0 PSID.
EPHV8808D	450	347	NONE	CALCULATIONS WITH A VALVE FACTOR OF 1.0	VALVE INSTALLED IN AN AIR SYSTEM
KAHV0030	1507	1291	NONE	CALCULATIONS WITH A VALVE FACTOR OF 1.0	
LFFV0095	1766	295		CALCULATIONS WITH A VALVE FACTOR OF 1.1	VALVES OP TESTED UNDER LOW DPS
LFHV0105	548	532		CALCULATIONS WITH A VALVE FACTOR OF 1.2	VALVES DP TESTED UNDER LOW DPS
LFHV0106	548	532		CALCULATIONS WITH A VALVE FACTOR OF 1.3	VALVES DP TESTED UNDER LOW DPS

ATTACHMENT 5 TO RFR 8746I


THE ATTACHED DRAWINGS WERE OBTAINED FROM THE WESTINGHOUSE STRESS REPORTS IN THE QA VAULT OF THE CALLAWAY NUCLEAR PLANT.

THESE DRAWINGS SHOW THE MEAN SEAT AREA OF WESTINGHOUSE FLEX WEDGE GATE VALVES.








ATTACHMENT 5 3816





2-4












1307649 SEAT RING-12-1500LBu SURFACES PER BOIGS-Z, CL. DOK. 9 MACHINED SURFACES PER BOIGE-2, PER BOIGS-2, CLOA. 6.6. w/ 10/2 SEAT RING T. Port Polis 3 ALL TOXERANCES & GEOMETRIC SYMBOXS SHOWN ARE RECIDENTH PART IN A RESTRAINED CONDITION. PART MAY WAY FROM RECID TOLERANCES # 4 Westinghouse Electric Corporation 307C GOMETRIC SHABOLS WITHIN DZ IN 9556314401 10K 27 [AOI REVISIONS C 04808 | 3 RELAXED CONDITION. 1197 OF MATERIALS SARES ENGINEERS BATCOMIA INDES PT PER NOTE 4 (SURFACE 'K) PT PER NOTE . 9 Pet 843 DEAL OVER UNLESS CHIEFAWISE SPECIFIED Bath allege at an aber pregnet Commit an appropriate to the first section of the section of the section of the team of the section of t VIEW 'Y to provide the pro NE I Soli Past Manuel ARVEIDERCT I seption I B333 DIA. YYOU BUBALIAVA 90165-2 00 (82142PUS12 PPT (SEE NEW A WARKSERM GAKTIVA I D. 13.25DIA 606 (800), 79 85 1 12 - IBOMIN -EIAI005 10 500 DIA 26°CHE 10 1.0000 ¥ . WELD PREP - 521 38-90.00 HSO 839 KO.38 NA. IT KATS CHE 841 SCHIBE LINE APPROX OI DEEP AS SHOWN ILASS DIA PA COSDIA 500 David 111 1000

ATT 5 108 + 15 Party

87



11 0 S

ATTACHMENT 6
WOLF CREEK DP TEST RESULTS
FOR CONTAINMENT SPRAY PUMP
DISCHARGE ISOLATION VALVES
ENHV0006 AND 12

HELT, Mros.

STEM PITCH STEM LEAD

BEAT ANGLE STEM PITCH STEN: LEAD

HECK ONE HAT.

8+

HECK Mor.

ATTACHMENT 7 RISK IMPORTANCE CATEGORIZATION OF MOV'S THAT CANNOT BE DP TESTED FOR RFR 8746I

Mr. J. A. McGraw:

December 22, 1993

Mr. J. A. McGraw:

IPE Impact of Non-DP Tested MOVs Ref.: UOTE 93-221

This letter responds to the referenced letter, which requested that a review be performed to assess the impact on the IPE due to the inability to ΔP test selected MOVs.

In order to perform a meaningful review, a draft NUMARC document, "Guidelines for Optimizing Safety Benefits in Assuring the Performance of Motor Operated Valves," was used as guidance. This document is provided as Attachment 1.

The procedure described in Attachment 1 involves categorization of MOVs into one of three importance groups (high, medium or low). Testing recommendations are then made for each importance category. MOVs are placed into an importance category based on their PRA numerical importance. MOVs that were not included in the PRA must be placed into an importance category using deterministic methods and/or engineering judgment. Attachment 2 is a flow chart that delineates the NUMARC guidance for application to Callaway MOVs.

Using the process represented by the flow chart, MOVs that were included in the Callaway at-power PRA were assigned to an importance category. The review/categorization process is documented in the table provided as Attachment 3.

Note on Attachment 3 that only those valves that were modeled in the PRA were assigned to an importance category. Those valves that are not in the PRA will have to be assessed by Engineering/Operations for assignment to an importance category.


If there are any questions, please contact Keith Connelly at 42868.

A. C. Passwater

KGC/kea Attachments

> 177 8 POJA+ RFR 8746I 28 13

cc:	W. B. Bobnar	Wlo	attach
	K. G. Connelly	2.5	111
	C. D. Naslund	4.1	98
	T. E. Hermann	11	25
	D. E. Heinlein	**	3.9



Attachment

~
1.3
ottani.
D
1.1
person .
and and
and .
LL3
00
have .
(mag
Total Control
Same
Z.
<
U
Jan.
4
T
-
un
-
0
-
2
II.
(3)
Sand
2
(
· man
IZAT
<
14
CT
6
1.50
(1)
144
par.
40
O
LLF
(3
Sec.
4
-
lake
0
0_
5
IMPO
14
10
RIS
C.

Value Functional Desc. [PRA?	A7	PRA? CD equation?	CCF or both?	Importa	CSF function of valve, if any.	Med.	-
BRHVESOOR PE DRV LINK Whe	>	Y	Both	1.355 15 - 5		300/	T
FRHV5500 BB. FORV black valve	>	Y	13014	3.2516-4.	Name of the last o	3	
FRAN SistA PRIJOTAT normal	Z	1	1	4			
BBHV 8:3713 Pict/Crost Macmal	N	1	1	1	KAOD ∃TI		
BBIN JSKIA ROF A SEAL INJ	R	an .			BALIAVA .		
BANY 335/18 ROP 18 Sent in	N	1		1	LS38		
BRUN 8351C REPC SCALING	N	1	1				
BEHVESTUD ROP D Seal inj.	>	ř	-	1			
88 PY 8702A 1865 Long 1 HILL to PHIR S. C. L. Long 150. Valve	>	λ	Both	2.1396-4	<i>b</i> -	Low	-

ATT ?

5813

RISK IMPORTANCE CATEGORIZATION OF MOVS THAT CANNOT BE DP TESTED

		Valve in	berner	If yes, random failure,	V-V	CSF function of valve, if any.	Category	Method
BBFV 87028	Alve Functional Desc.	PRA?	CD equation?	CCF or both?	2.639E-4		mart	-
	150. Valve					YGOS		
RGHU 8100	Sial water returns	8)	1	1	37877		
FC13 8H58	PDP recire . 1500, value	N	١	ŋ	1	AVA T23B		
EGUV EIIZ	Seal water edien	3	1		1			
BGLEVITZB	Stream iso	>	>-	GOF	5.6216-6		Low	
211757115	Receviled Vet ontlet dam	>	>	ecF:	560/E-1	j	7007	
60 HV 1953	3 RWST/ Mint Sping 8:15.	>	Α*	Both	3.787 E-4	<i>h</i>	m67	-

2 eged E ALL VALVE is in "In se reduse " senation

RISK IMPORTANCE CATEGORIZATION OF MOVS THAT CANNOT BE DP TESTED

SAME TO Valve Functional Desc.	_	The same of the sa		THE OWNER OF THE PERSON	COLUMN TO THE PARTY OF THE PART			
20/00	RUST/CENT Soray	PRA?	CD equation?	B.K	4-47267	лен опримент	Low	
RNHV BEIZARWST / EHR F F	STIEHR Front	Α	>	Botts	7.6395-4		7007	7
FWHV 88,2B RWST/ RUR BUTS	R 150. VALVE	>	>	Bott	7.639 E-4	JE COPY	mc7	
EFHUCOCZ3 SW	Xun Isa Valve	>	À	130 -6	1.754 E-2	ANIAVA .	H;2A	1
EFHV 0024 SU	XRON. ISU. VAIVE	>	>	Botts	3.535 E-3	1838	med	
EFHVOOZS Sid	Xern. 150. Value	>	>	Bath	3,640E-3		med	
EFHV 3026 S	EFHUSOZL SUJESLU Train E YEON, : Sw. valve	>	>	Bath	1.835E-2		Hist	
EFHY0037 ES	HS. J Tenin A HHS 15.4. VAID	>	>	BALL	\$245E-3		Mrd	

Page 3

ATT 7 PFP 8746X 7813

RISK IMPORTANCE CATEGORIZATION OF MOVS THAT CANNOT BE DP TESTED

П		Valve in	Valve in If yes, valve in	If yes, random failure, CCF or both?	Importance	CSF function of valve, if any.		Method
Valve ID	Valve Functional Desc.	N. P.	Co eduanon:	name.	1	.)	rom	1
Nowik	EFPONOON ESW SIC Strainer		2					
EF PDV 0820	Esw s/c strainer	>	2	*	-	-	mez	13
	Brain Dr					Y900		
ESHV DIG 11	A upstrain	2	e principle o	1		3184JIAWA		
=411v4412-	Esny Cow Trans 1500, Valva	2	i			TS38		
E6HV+6/3	Essylven Tra A downstream 15n. Valve	2)	* ************************************				
43/11/00/14	155 Joen Ten 150. Valve	2	3		1			
EJHV 8721A	A Suction	À	>	Rolls	2439E	4	7	

Page 4

ATT 7 AT 8746 8813

RISK IMPORTANCE CATEGORIZATION OF MOVS THAT CANNOT BE DP TESTED

ve, if any. Category Method	med. 1	Med.	AVA TZBB	1 600	Two T
If not modeled in PHA, important Important CSF function of valve, if any.	S.789E-3	5.787E-3	1.7366-4	1.7205-4	3.757 E-4
CCF or both? 6576	BALL	Both	Both	BAIL	Bottl
Valve in If yes, valve in PRA? CD equation?	>	>	*	*	*
Valve ID Vaive Functional Desc. PRA? F.THY (2) 175 KHIL PAINTERS Y	EJHVRRIIIA ETINT Smanpl Y RHR pring A snedion ison	EJHV SSIIIS CTINT SUCREY Y RHR Pring B. Suchion 150	ENHVERER CTOTT SAME OF Y	FNHVassle (TMT Sprang Y	ENHVOORT Chris Soume / Y

Page S

RISK IMPORTANCE CATEGORIZATION OF MOVS THAT CANNOT BE DP TESTED

	processor	Valve in	Valve in If yes, valve in PRA? CD equation?	m failure.	F.V Importance	If not modeled in PHA, important CSF function of valve, If any.	Category	Method
EN HV OWITE	Pung Rayah	>	*	Boths	2757E-4		Comp	
ENHVOORS	Sattes Tra A	2	1	ł	1	, A.		
ELW Dalle	SAT/CS Tra B	2		1	1	ABLE COF		
42828AHJ	EFHVETETA Acrom, A out-	N		, was	1	LIMANA TO		
ELASABIS	Prema Bont	77	and the second			38		
EMV87203C	Account. C. out	3	1)	1			
ETHVSZAZZD	A tot 1500 value	7)	7	1			
42KAVH2A	CTint is.	2	1	1				
ATT 7 RFF 874CI				Page (

RISK IMPORTANCE CATEGORIZATION OF MOVS THAT CANNOT BE DP TESTED

AMMSOS Paraset al Str. N	Secoil outler	-			
H, every 2015/45. N — — — — — — — — — — — — — — — — — —	He event as sys. N Eve post losg N (ST/MDAPP B (ST/				TITI
Fix pert loop N I shows tream I shows tream I shows tream I show where I show where	Eve port loop N to Est Enillo downstrain is. Valve is. Valve is. Valve V CST/MDAPP B V CST/TDAPP VST/TDAPP SECON JALVE VST/TDAPP V	1	YHOO		
(STIMPAINTE Y N VAINE Y N LOW CSTIMPAINTE Y N LOW LOW CSTIMPAINTE Y NXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX	CST/MDAPPE Y CST/MDAPPE Y CST/TOAPF Y CST/		E\$T AVAILABLE		
1 Togst 9 V N X X	TONER Y TONER Y TONER N Alle	1	8	Low	17
Touster V NX**	Togstf Y Value N TB N g. coil outler	1		7	r)
Res a Tles N	Res O 1/18	1		400	2
	150. VIIVE				

RISK IMPORTANCE CATEGORIZATION OF MOVS THAT CANNOT BE DP TESTED

Valve ID	Valve Functional Desc.	> 4	If yes, valve in CD equation?	CCF or both?	F-V Importance	CSF function of valve, if any.	Category	Method	
158HVAVIL	Clos. (2) Se. 1	2							
CE HV + 415	Repenting	8				AdOD			
FYSHVM6 16	Red D TIPE dag coil	8	1			BUBALIAVA TZ			
HV 4 P3	EFHV 4439 FS. J Trn A/SW	>	>	Batta	3.6026-3		m.p.	7	
EFHI 4349	Esty Tra R/Sw X com. nostream	7	>-	Bothy	8.75E-	2	med	1	
Hosey	EFHVORY ESS Ten Plsw Xwn. down stream 180	>	>	Both	6.25 p. 6-3	20	Pow	1	

A 80ed

RISK IMPORTANCE CATEGORIZATION OF MOVS THAT CANNOT BE DP TESTED

Key Tra Elsw	PRA? CD	CD equation?	CCF or both? Bs 14	3.54 IE-3	CSF function of valve, if any.	Category Mcd.	Method
1 2		199	1		X3(
R					DD BJBAJIAVA		
>		N			TS38	Low	2
>		2	1	1		7007	N
2		1					

Page 9

ATTACHMENT 8 EPRI MOV PREDICTIVE PERFORMANCE PROGRAM DATA USED IN THE DISPOSITION OF RFR 8746I

RFR 8746I

EPRI MOV Performance Prediction Program REVIEW MEETING

Dallas Airport Hyatt Regency Hotel

AGENDA

December 1, 1993

OPEN SESSION (Open to all domestic utilities and to all participating international utilities)

1:00 pm	n Introduction/Meeting Objectives	PRI)
1:15	Technical Advisory Group Perspective M. Eidson (S	NC)
1:30	NUMARC Perspective C. Callaway (NUMA	ARC)
1:45	EPRI Program Overview/Status	PRI)
2:00	Review of Flow Loop Test Program Results 1. Hosler/W. Kennedy (E	PRI)
3:00	Break	
3:15	Assessment of Potential Implications for Installed MOV's	Co.)
4:00	Question/Answer Period	All
4:45	EPRI MOV Program Follow-on Activities	TVA)
5:00	Adjourn	

2874

EPRI MOV Performance Prediction Program REVIEW MEETING


Dallas Airport Hyatt Regency Hotel

AGENDA

December 2, 1993

CLOSED SESSION (Open only to utilities participating in the EPRI MOV Program)

8:00 am	Introduction
8:15	Review of Key Program Findings/Issues 1. Hosler (EPRI)
8:45	Methodology Overview P. Damerell (MPR)
9:15	Globe Valve Modeling Approach/StatusP. Damerell (MPR)
10:00	BREAK
10:15	Gate Valve Modeling Approach/Status P. Damerell (MPR)
12:00	LUNCH
1:00	Butterfly Valve Modeling Approach/Status M. S. Kalsi (KEI)
2:00	Method for Assessment of Rate-of-Loading Effects P. Damerell (MPR)
3:00	BREAK
3:15	Question/Answer PeriodAll
4.00	Adjourn



NUCLEAR REGULATORY COMMISSION
OFFICE OF RUCLEAR REACTOR REGULATION & Ellis Guilding WASHINGTON, D.C. 20555 November 30, 1993

HRC INFORMATION NOTICE 93-88: STATUS OF MOTOR-OPERATED VALVE PERFORMANCE PREDICTION PROGRAM BY THE ELECTRIC POWER RESEARCH INSTITUTE

Addressees

TOT D' TOMATO

All holders of operating licenses or construction permits for nuclear power reactors.

Purpose

The U.S. Nuclear Regulatory Commission (NRC) is issuing this information notice (IN) to alert addressees to preliminary results of motor-operated valve (MOV) tests conducted by the Electric Power Research Institute (EPRI). It is expected that recipients will review the information for applicability to their facilities and consider actions, as appropriate, to avoid similar problems. However, suggestions contained in this information motice do not constitute MRC requirements; therefore, no specific action or written response is required.

Background

On June 28, 1989, the MRC issued Generic Letter (GL) 89-10, "Safety-Related Motor-Operated Valve Testing and Surveillance, to request that nuclear power plant licensees and construction permit holders verify the design-basis capability of their safety-related MOVs. In GL 89-10, the MRC staff requested that licensees and permit holders test each MOV within the scope of the generic letter under design-basis differential pressure and flow conditions, where practicable. The recommended schedule in GL 89-10 would have licensees and permit holders verify MOV design-basis capability by June 28, 1994, or three refueling outages after December 28, 1889 (whichever is later).

In response to concerns regarding MOV performance, EPRI and its utility advisors established a research program to develop a methodology to predict the performance of MOVs under design-basis conditions. MUMARC coordinates the interaction between EPRI, its stillity Technical Advisory Group (TAG), and NRC staff related to the EPRI program. The EPRI program includes detailed analyses and testing of MOVs at test facilities and nuclear power plants. The EPRI MOV Performance Prediction Methodology is intended to allow licensees to demonstrate the design-basis capability of MOVs based on analytical predictions combined with diagnostic tests conducted under static conditions. In August and October 1993, EPRI presented the status and preliminary results from its Flow Loop Testing Program to the NRC staff. The flow loop results in

0311190452

BEST AVAILABLE COPY

\$ 4374

IN 93-88 November 30, 1993 Page 2 of 6

SURECU . .

--- EUM-

the EPRI presentation have not received full quality assurance verification, but the preliminary information may be helpful to licensees as they implement their MOV programs.

In a letter on September 16, 1993, NUMARC provided responses from EPRI to MRC staff questions on the EPRI MOV Performance Prediction Program. Among the information provided in the enclosure to the letter, EPRI stated that its program is expected to cover about 90 percent of gate valves (about half with its computer code and half with empirically-based data), essentially all globe valves, and about 95 percent of butterfly valves. The globe and gate valves are covered primarily by the computer code. EPRI also stated its method for determination of operator output torque capability under degraded voltage conditions is to apply standard methods as documented in EPRI NP-6660-D (March 1990), "Application Guide for Motor-Operated Valves in Nuclear Power Plants."

Description of Circumstances

In conducting its MCV Performance Prediction Program, EPRI tested 28 gate, 4 globe, and 2 butterfly valves under a total of 62 test conditions. These tests were performed at Wyle Laboratories and Siemens test facilities. EPRI plans to obtain test data for an additional 35 valves being tested in nuclear power plants. In addition, EPRI completed testing at Kalsi Engineering of 10 butterfly valve designs to assess flow and upstream piping configuration effects. The results summarized below are based on the Wyle/Siemens MOV tests.

1. Gate Yalves

EPRI stated that all gate valves tested were initially preconditioned by conducting a large number (50-1000) of short (no flow) strokes in cold water under differential pressure loading. Initial "sliding friction coefficients," prior to preconditioning, generally ranged from 0.2 to 0.4. EPRI indicated that, after preconditioning, "apparent friction coefficients" ranged from 0.3 to 0.6 for all but four valves tested under cold water pumped-flow conditions. The "apparent friction coefficients" for the remaining four valves ranged from 0.66 to 1.93. EPRI results demonstrated "apparent friction coefficients" ranging from 0.36 to 0.41 for hot water pumped-flow conditions, 0.35 to 0.8 for hot water blowdown conditions, and 0.25 to 0.66 for steam blowdown conditions. EPRI's "apparent friction coefficients" reflect all valve internal phenomena and are not necessarily indicative of a "sliding friction coefficient." The major difference between the "apparent friction coefficient used by EPRI and the "valve factor" used historically by valve vendors in sizing motor operators is the consideration of the valve disc angle in determining the EPRI "apparent friction coefficient."

Most valve vendors have used a "valve factor" of 0.3 for flexible wedge gate valves and 0.2 for parallel disc gate valves in sizing motor operators. Therefore, the EPRI test results indicate that the thrust required to operate

BEST AVAILABLE COPY

4 5g 74

Movember 30, 1993 Page 3 of 6

NUTABLE &

gate valves could be significantly greater than the thrust predicted by the valve vendors. The EPRI blowdown test results are generally consistent with those obtained in the limited testing program conducted by the Idaho National Engineering Laboratory (INEL) for the MRC Office of Nuclear Regulatory Research in 1989.

EPRI reported that the valve sliding friction coefficient tends to decrease with increasing differential pressure which lends support for linear extrapolation of reduced differential pressure results when there is a low potential for valve damage (for example, under nominal flow velocity pumped-flow conditions).

EPRI reported that several gate valves were damaged during hot water and steam ablowdown testing. These included a 6-inch Anchor-Darling valve (disk and seat damage); a 6-inch Crane valve (guide damage); a 10-inch Velan valve (guide damage); a 6-inch Walworth valve (guide damage); and a 10-inch Edward valve (disk and seat damage). Two of the damaged valves exhibited "apparent friction coefficients" exceeding 0.6.

Two gate valves were damaged under cold water pumped-flow conditions. These included a Velan 6-inch valve (plastic bending of body guides at high flow velocity greater than 30 feet per second) and an 18-inch Anchor-Darling valve (valve disk forced through seating area resulting in leakage above disk).

EPRI test results revealed that it is generally not possible to determine accurately the point of flow isolation prior to disk wedging based on the thrust diagnostic trace alone.

EPRI stated that it had not observed differences in thrust requirements for valve operation between valves installed in horizontal pipes with the stem either vertical or horizontal. This finding differs from some operating experiences in nuclear power plants.

2. Globe Valves

MUL D' GUMAKU

EPRI stated that, for incompressible flow conditions, globe valve thrusts are consistent with industry calculational-method predictions only if the appropriate area is chosen for differential pressure application. The appropriate area (disk mean seat area versus disk guide area) appears to be unique to valve design. It was determined that use of disk mean seat area rather than disk guide area can result in significant underestimation of required thrust for some globe valve designs. Specifically, one globe valve tested under cold water pumped-flow conditions required approximately twice as much thrust to close using disk mean seat area and a valve factor of 1.0.

A two-inch Rockwell/Edward globe valve, tested under hot water blowdown conditions, exhibited thrust requirements exceeding predictions based on disk guide area by approximately 35 percent. This valve sustained damage to the portion of the body bore that guides the disk.

BEST AVAILABLE COPY

\$ 6874

Current industry practice for determining the required thrust for globe valves varies by manufecturer. Many manufacturers assume disk mean seat area multiplied by a valve factor in the 1.0 to 1.1 range. Others use disk guide area in making thrust predictions. Therefore, the EPRI results indicate that actual thrust requirements may exceed those predicted using current industry practice for some globe valve designs.

3. Butterfly Valves

MUY 2" YUMAN,

EPRI stated that the Wyle flow loop testing revealed torque requirements to operate Pratt butterfly valves which were bounded by the most current torque predictions of the manufacturer. However, butterfly valves at some nuclear power plants [for example, Catawba and Palo Verde) have demonstrated torque requirements that exceed vendor predictions. EPRI is currently evaluating data from testing conducted at Kalsi Engineering to assess butterfly valve torque requirements for a wide range of butterfly valve designs.

4. Data Interpretation and Assessment

In July 1993, EPRI sent a Quarterly Status Report to all utilities participating in the EPRI MOV Performance Prediction Program. This report summarized preliminary flow loop test results. After the completion of wyle/Siemens quality assurance checks, EPRI plans to update this information in its next Quarterly Status report scheduled for late 1993. Detailed test reports documenting these results are scheduled for delivery to participating utilities between October and December 1993. EPRI stated that, in interpreting the EPRI flow loop test results, utilities need to understand the assumptions and equations that were used by EPRI in presenting the data. For example, the EPRI calculated 'apparent friction coefficient' for gate valves is based on the equation provided in EPRI Report NP-6850-D, 'Application Guide for Motor-Operated Valves in Nuclear Power Plants.' This equation is solved for 'apparent friction coefficient' using (1) the maximum measured stem thrust which occurs prior to the initiation of wedging (for valve closing) or the maximum thrust which occurs after cracking (for valve opening); (2) full (valve closed) tested differential pressure; (3) mean seat area; (4) valve disk angle; (5) full (valve closed) upstream tested pressure for stem rejection thrust; and (6) measured values of packing load.

EPRI stated that valve design and test conditions, maintenance history, and operating experience may be important in assessing the applicability of EPRI test results to plant MOVs.

EPRI uses the greatest thrust requirement to overcome differential pressure and flow to determine its "apparent friction coefficient." EPRI assumes the highest differential pressure observed during the test regardless of the stem position where the greatest differential pressure/flow required thrust occurs. This results in a lower calculated friction coefficient than would be determined if the actual differential pressure at the point of greatest thrust was used in determining the friction coefficient.

BEST AVAILABLE COPY

100 mms4

IN 93-88 November 30, 1993 Page 6 of 6

EPRI plans to submit sections of a topical report for MRC review as they are completed between November 1993 and April 1994. EPRI intends to submit supporting reports in advance of the final topical report to allow the staff to raise questions with EPRI early in the review process.

.:--,---, 5.01

EPRI stated that its final methodology is scheduled for delivery to utilities in April 1994 as a tool that may be used to confirm many espects of MOY calculations and setup. Further, the EPRI flow loop test results provide licensees with information which might be helpful in supplementing other "best available" data in establishing MOV switch settings.

Discussion

MUY I' HUMAN.

Since EPRI initiated its MOV Performance Prediction Program, the MRC staff has conducted public meetings with MUMARC and EPRI to discuss the goals of the EPRI program, the development of the program activities to accomplish those goals, the tests conducted in support of the program and the results of those tests, and the completion schedule for the program. The staff has provided questions and comments to MUMARC and EPRI on the EPRI MOV program as a result of these meetings. For example, in a public meeting on October 6-7, 1993, the staff emphasized the need for EPRI to ensure that licensees clearly understand the application of the EPRI test data and methodology. Also at this meeting, contents of this notice were discussed and the comments from EPRI have been considered. The staff expressed concern about the valves damaged during the EPRI testing and the apparent lack of action by some valve manufacturers in response to the valve damage. The staff also discussed the need for EPRI to ensure that adequate peer review of the EPRI methodology is conducted.

Although some issues remain to be resolved, the EPRI testing program should provide a significant amount of MOV test data that can assist nuclear power plant licensees in demonstrating the design-basis capability of MOVs that cannot be tested under dynamic conditions as installed. The preliminary test information provided in this notice is provided for licensee consideration in implementing programs in response to GL 89-10. The staff plans to conduct additional public meetings with MUMARE and EPRI to discuss the status of the EPRI MOV program. The staff will consider the need for additional generic communications to nuclear power plant licensees and construction permit holders as additional information is obtained from the EPRI MOV program.

Related Seneric Communications

 MRC Information Notice 90-40, "Results of NRC-Sponsored Testing of Motor-Operated Valves."

BEST AVAILABLE COFY

IN 93-88 November 30, 1993 Page 6 of 6

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact the person listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

-. "1-32-33 - 3-34 - . .

Brian K. Grimes, Director

Division of Operating Reactor Support Office of Nuclear Reactor Regulation

~~. __M-

Technical contact: Thomas G. Scarbrough, MRR

(301) 504-2794

Attachment:

7-1 2 10800 V

List of Recently Issued NRC Information Notices

BEST AVAILABLE COPY

A 9974

EPRI MOV ProgramReview Meeting

Flow Loop Test Results

Data Tables

DFW Airport Hyatt December 1-2, 1993

HUNTSVILLE COLD WATER PUMPED FLOW TEST LOOP

SUMMARY OF GATE VALVE TEST RESULTS

		SUMMAI	RYOF	GAIL		F	HIG	H DP PER	FORMANC	0
			LOV	no DI-HI	ALLIES		13.9	Open	Close	1.00
		TEMP	DP _	Appare	nt Disc µ	Isol.	Psid 275	0.168	0.140	0 135
	٧	F	Psid		0.163	0.141	213		0 620	0 571 Note A
MFG/Size	FI/Sec	AMB	90	0.20		0.347	270	0 643	0.020	
ve No. MFG/5/2	13		80	0.924	0.881	0.541		0.206	0.200	
	15	AMB	0.0	770	0.297	0.225	275	0.200		0.297
8 B-W/6		AMB	90	0 278	0.23	1	270	0.304	0.298	0.23
15 Aloyco/4	15	-		0.347	0 361	0.325	-	101	0.417	0 375
13	15	AMB	90		2074	0.253	260	0.431	-	
18 Pacific/4	+	T AMD	90	0 446	0.374			+		1
velan/6	15	AMB		0.510	0.454	0.296	3		0.56	1 0.387 Note B
23 Velaivo	1 00	AMB	90	0.510			260)	0.56	
23 Velan/6	30		-	-		-		0 0.34	16 0.39	9 0.390
	50	AMB	-		0 45	2 041	4 26	0 1 0.5	10	
23 Velan/6	15	AMB	90	0.39	9 1 040					

29

High apparent μ under study, no damage COMMENTS

Cantilevered guides bent at 250 psid/50 ft /sec Note A

Note B

HUNTSVILLE INTERMEDIATE PRESSURE PUMPED FLOW SIMULATION TEST LOOP

SUMMARY OF GATE VALVE TEST RESULTS

				LC	W DP PE	REORMAN	ICE	HIC	GH DP PER	REORMAN	CE	
		V	TEMP oc °F	DP	DP Apparent Disc μ			DP	App	arent Disc	μ	_
laive No.	alve No. MFG/Size	Ft/Sec		Psid	Open	Close	Isol.	Psid	Open	Close	Isol.	Comments
4	A-D/10	15	AMB	250	0 451	0.385	0.371	630	0.389	0.361	0.347	
4	A-D/10	15	AMB	250	0.460	0.401	0.397	650	0.379	0.370	0.365	Note A
4	A-D/10	15	AMB	250	0.455	0.417	0.392	640	0.413	0.407	0.389	Note B
4	A-D/10	15	AMB	250	0.448	0.406	0 384	630	0.411	0.403	0.380	Note C
10	B-W/12	15	AMB	250	0.685	0.663	0.560	630	0.627	0.570	0.497	Note D
17	Pacific/10	15	AMB	100	0.594	0 546	0.483	270	0.513	0.489	0.447	
25	Velan/10	15	AMB	260	0.540	0.594	0.499	750	0.493	0.529	0.447	Note F
31	WaV12	15	AMB	100	0.752	0.497	0.426	265	0.701	0.478	0.405	Note G
43	Edward/10	15	AMB	650	0.486	0.700	0.584	1800	0.438	0.495	0 363	Note H

N/A Par 1-11-94

COMMENTS

Note A	Stem Horizontal
Note B	Elbow from side
Note C	Elbow from top
Note D	Wear on interior surface of one body guide no seat damage
Note E	Heavily scratched at 4:30 and 7:30 positions on disc and seat leaked 1 ml/min
Note F	No torque arm
Note G	High opening μ's associated with disc/body interference on opening
Note H	Valve flow isolated but failed to wedge on max dp closure due to motor stall

NORCO HIGH PRESSURE COLD/HOT WATER TEST LOOP SUMMARY OF GATE VALVE TEST RESULTS

		V	Temp	DP LC		RFORMAN rent Disc		DP HIC	GH DP PEI App			
/alve No. MFG/	MFG/Size	Ft/Sec	F	Psid	Open	Close	Isol.	Psid	Open	Close	Isol.	Comments
1	A-D/3	15	AMB	200	0.464	0 504	0.320	780	0 440	0 432	0 361	
3	A-D/6	15	AMB	660	0.526	0 615	0 535	1830	0 475	0.515	0 463	
3	A-D/6	15	450°	630	0 418	0 423	0.410	1300	0 382	0 416	0 399	
3	A-D/6	50	AMB	660	0 585	0 569	0.489	1900	0 539	0.561	0 435	
3	A-D/6	B/D	530°					1210		0.453	0 430	Note A
3	A-D/6	B/D	530°					1290		0.420	0.402	Note B
7	B-W/3	15	AMB	630	0 458	0.637	0.537	2600	0.521	0.564	0 480	
7	B-W/3	50	AMB	670	0.514	0.715	0.514	2630	0 513	0.553	0 430	
9	B-W/6	15	AMB	650	0.665	0.710	0.480	1800	0 610	0 642	0.423	Note C
9	B-W/6	B/D	530°					1250		0.393	0.366	
13	Velan/2.5	15	AMB	1300	0 646	0 484	0.260	2650	0.593	0.460	0 282	
13	Velan/2.5	50	AMB	1360	0.635	0.496	0.284	2660	0.580	0 452	0 287	
13	Velan/2.5	B/D	530°					2660		0.328	0.279	

COMMENTS

Note A Some body and disc seat damage, flow limited by loop piping

Note B Some disc seat damage

Note C Wear on downstream side of body guides

NORCO HIGH PRESSURE COLD/HOT WATER TEST LOOP SUMMARY OF GATE VALVE TEST RESULTS

				LOW		ORMANC			GH DP PER			
		V	Temp	DP	the second second second	rent Disc	Contract of the Contract of th	DP		parent Dis		-
Valve No.	MFG/Size	FI/Sec	F	Psid	Open	Close	Isol.	Psid	Open	Close	Isol.	Comments
14	Crane/6	15	AMB	650	0 442	0.419	0 295	1930	0 379	0.415	0 344	
14	Crane/6	50	AMB	650	0 507	0 378	0 337	1900	0 436	0 429	0 347	
14	Crane/6	B/D	530°					1280		0 788	0.762	Note D
16	A-D/3	15	AMB	500	0.672	0 620	0 526	1870	0 487	0 451	0 436	
21	Rock/Ed/2-1/2	15	AMB	470	0 320	1 930	0.928	1810	0 375			
24	Velan/f	15	AMB	480	0.530	0 567	0 324	1910	0.531	0 501	0.365	
24	Velar/6	15	AMB	460	0 585	0.596	0 451	1930	0 539	0 486	0 385	Note E
24	Velan/6	15	450°	670	0.527	0.343	0.300	1180	0.487*	0.324	0 280	
24	Velan/6	50	AMB	640	0 602	0.567	0 353	1800	0 536	0.498	0.367	
24	Velan/6	15	AMB	940	0.640	0.592	0.383	1720	0.621	0 552	0.401	Note F
24	Velan/6	B/D	530°					1270		0 468	0 417	
30	Walworth/6	15	AMB	650	0.359	0.287	0.207	1890	0.422	0.399	0.331	
30	Walworth/6	B/D	530°					1320		0.531	0 497	Note G
34	West/3	15	AMB	750	0.475	0.319	0.315	2650	0.313			
41	A-D/6/PD	15	AMB	480	0.762	0.950	0 469	1900	0 545	0 548	0 444	
41	A-D/6/PD	B/D	530°					1270		0 348	0.331	

COMMENTS

Note D Damage to guide rails

Note E Stem horizontal

Note F

Note G

Torque arm disconnected

Gouging damage to guide rails

* Downstream seat Temperature lower than 450: (probably 200 300 F range)

65TBL/WSK/jp

12 there 12

SIEMENS/KWU HIGH PRESSURE COLD WATER AND STEAM TEST LOOP

SUMMARY OF GATE VALVE TEST RESULTS

	v			DP L(OW DP PE Appa	RFORMAN rent Disc		DP Apparent Disc µ				
Valve No.	MFG/Size	Ft/Sec	Temp	Psid	Open	Close	Isol.	Psid	Open	Close	Isol.	Comments
5	A/D/10	15	AMB	460	0.576	0.465	0.408	1350	0.442	0.394	0.376	
6	A/D/18	15	AMB	167	0,226	0.327	0.194	333		0.295	0.18	Note A
2.4	Velan/6	200	Sat. Steam		*property and the			1200		я		
24	Velan/6	B/D	Sat. Steam	600			*	1200				
26	Velan/10	B/D	Sat. Steam					1200	-	0.718	0.56	Note B
4 1	A/D/6/PD	B/D	Sat. Steam			principal in the second		1200	0.333	0.591	0.347	
43	Edwards/10	B/D	Sat. Steam					1200	0.344	0.41	0.33	Note C

COMMENTS

Note A Disc driven below normal wedge location; flow leakage above disc; disc permanently "pinched"

Note B No damage to disc and seat, severe damage to body guide rails

Note C Some stellite edge damage to disc and seat

* Still under evaluation

SUMMARY OF GLOBE VALVE FLOW LOOP TEST RESULTS

alve No.	MFG/Size	Max AP Psid	V Ft/Sec	Temp	Valve Factor (Seat Based)	Valve Factor (Guide Based)	Comments
44	B-W/6	1800	15	AMB	1 925	0 978	-
44	B-W/6	1800	50	AMB	1 998	0 976	
48	Edward/2	2500	15	AMB	1 246	0.905	
48	Edward/2	2500	50	AMB	1 417	0 922	
48	Edward/2	2500	B/D	530 HW	2 146	1 480	Note A
49	Velan/2-1/2	2500	15	AMB	1.039	0 514	
50	A-D/10	740	15	AMB	1.062	0.719	Note B
50	A-D/10	740	15	AMB	1 065	0.738	Note C

COMMENTS

Note A Valve did not close, valve factor abnormally high

Note B Flow over disc Note C Flow under disc

		Maximum			Maximum Apparent Disk Friction Coef.		Maximum Stem Frict		Stem Thrust at Torque Switch Trip	
Valve Number	Manufacturer, Size and Type	Differential Pressure	Flow Velocity	Fluid Temperature	Open	Close	Open	Close	Static	Dynamic
1	Borg Warner 4-inch FWG	1620 psid	17 fl/sec (water)	Ambient	0.305	0.304 ° (0.555)	0.135	0.105	24,605 lbs	20,376 lbs
3	Borg Warner 16-inch FWG	300 psid	13 ft/sec (water)	86 °F	0.332	0.373	0.161	0.113	36,622 lbs	34,114 lbs
4	Borg Warner 16-inch FWG	300 psid	12 fl/sec (water)	86 °F	0.371	0.355	0.166	0.134	35,039 lbs	35,281 lbs
11	Anchor/Darling 16-inch FWG	340 psid	6.2 ft/sec (water)	110 °F	0.210	0.174 ° (0.328)		* * *	65,827 lbs	52,948 lbs
12	Anchor/Darling 16-inch FWG	350 psid	6.4 ft/sec (water)	105 °F	0.208	0.238			39,990 lbs	34,994 lbs
17	Velan 4-inch FWG	900 psid	30 ft/sec (steam)	535 °F	0.394	0.338 * (0.512)	0.167	0.122	9,810 lbs	10,020 lbs
18	Anchor/Darling 4-inch PDG	965 psid	60 ft/sec (steam)	540 °F	0.196 **	0.353			13,410 lbs	Limit Seated

^{*} These valves showed brief thrust increases just before wedging. The first value of apparent disk friction coefficient is just prior to the increase. The second value in parenthesis is at initial wedging.

^{**} Data indicate a possible zero shift during opening stroke which would increase apparent disk friction coefficient to about 0.30.


EPRI MOV PerformancePrediction Program

Technical Advisory Group Perspective Industry Update Meeting

December 1-2, 1993

Michael Eldeon (SNC)





EPRI MOV Performance Prediction Program TAG Perspective December 1-2, 1993

- I TAG Overview
- II. Recent TAG Activities
- III. TAG Perspective
 - A Positive Notes
 - B. TAG Concerns
 - C. Program Objectives
 - D. Program Results/Impact
- IV. Summary



EPRI MOV PPP Technical Advisory Group and Subcommittee Structure

- The EPRI MOV Performance Prediction Program (PPP) Technical Advisory
 Group (TAG) provides technical guidance to the EPRI Staff in the planning
 and implementation of the program.
- The primary TAG focus is on program goals, significant technical leaves, scheduling and budget activities, i.e., the TAG acts like a stearing committee. The TAG provides monitoring and oversight of technical issues by reviewing and approving subcommittee and EPRI project staff recommendations.
- The detailed program technical sepects are monitored and reviewed by the subcommittees, which include an expanded membership from the MOV PPP member utilities. The subcommittees report back to the TAG.
- The TAG represents the MOV PPP member utilities.
- The TAG reports to the EPRI Operations & Maintenance Technology Subcommittee and the EPRI Engineering & Operations Task Force.
- The TAG Interfaces with outside organizations such as NSSS Owner's Groups, NUMARC and NRC.



1993 EPRI MOV PPP TAG Members

NAME

' John Allen

Denver Atwood Bill Black

Clive Calleway

Brian Curry

Michael Eldson, Chairman

Neel Estep, Vice Chairman

Chris Hensen

Sam Henry

Nick Konstantinou

Fred Martsen Bob McPheerson

Ron Schemen

* Robert Woehl

COMPANY

Tennessee Valley Authority

Southern Nuclear

TU Electric

NUMARC

Philadelphia Electric

Southern Nuclear

Duke Power

Yankee Atomic

Tennessee Velley Authority

Commonwealth Edison

New York Power Authority

Southern California Edison

Cleveland Electric

PGAE

* Liason to Operations & Maintenance Subcommittee.

FLOW LOOP

EPRI MOV PPP TAG Subcommittees

Larry Dorfman Milke Eldson

Nest Estep, Chairman BIR Kennedy

Southern Nuclear Duke Power

EPPE

PPSI

TU Electric

Philadelphia Electric

Nebraska Public Power District

Southern Company Services

MODELING & SEPARATE EFFECTS

Buzz Beltz Lorraine Benesky Bill Stack Brian Curry Horm Dingman Chuck Lynch

Fred Martsen, Co Cheirman Steve Reed

Ron Scherman, Co-Chairman Ken Wolfe

TOPICAL REPORT

Clive Calleway Chris Hensen, Chairman

John Hosier John Sutton Brian Sullivan Jos Price

NEMBARC

EDE

Union Electric

Cleveland Electric

Yankee Atemic E DOM

Yankse Atomie Reston Edison

FPSL

Recent TAG Activities 1993

NRC memo closes 6 of 22 concerns and adds 6 new concerns

TAG Subcommittee meetings. Jan 12

Jan 13-18 TAG expressed concerns over feeting progress, requested action sians to resolve 3 MOV phenomena

EPPET AG report to OAM Tech Subcommittee Jan 18

TAG letter to perticipants requests MOV in altu test deta Fab 5

EPSE MOV PPP update meeting with program participants;

90% population to be included in program.

TAG informed of new liow loop test sequence deletions and in situ

test data icoses; approved 3 action plans.

TAG/EPPENUMARC/Valve Manufacturer meeting with NRC Apr 22

EPRE memo provides seems sment of test data losses on May 5 methodology validation

May 18-20 EPRETAG report to E&O Yeah Force and DAC

June 8 BAC letter to executive contacts requests MOV in altu test data

June 15 EPPE/TAG agreement on additional flow loop testing.

June 18 Topical Report Subcommittee meeting



Recent TAG Activities 1993 (Cont'd)

Modeling & Separate Effects Subcommittee meeting

EPRE MOV PPP update meeting with program participants

EPFE E&O letter to utility management requests continued

TAG and Subcommittee membership support.

Flow Leap Subcommittee meeting. Aug 3

Aug 4.5 TAG meeting

Aug 19-20 TAG/EPPR/NUMARIC meeting with NRC at Wyle Labs to review

flow loop results and inspect values.

EDSE letter to NUMARC formally responds to NRC concerns.

Sept 27.76 EPFETAG report to O&M Tach Subcommittee and E&O Tesh Force

TACKEPPENUMARC moeting with ACRS.

TAGEPRENIMARC/Velve Manufacturer meeting with NRC

Oct 28-27 TAG meeting.

Modeling and Separate Effects Subcommittee meeting

EPPS MOV PPP update meeting with industry and program participants



December 1993 Positive Notes

- O Preliminary scope/applicability of code methods identified.
- Gate valve analytical model development.
- Globe & butterfly valve model development/validation.
- Scope expanded by developing new non-code methods
- O Butterfly valve parametric test program.
- O Valve design effect test facility.
- Quarterly progress report for program participants.
- Valve manufacturers support improving.
- Recent program reports' quality improving.
- O EPRI MOV PPP Project Staff performance.



EPRI/TAG Agreement For Additional Flow Loop Testing (June 15, 1993; Amended September 27, 1993)

- O Priority #1: 2500 psi cold water and hot water parametric and 2500 psi BD testing
 - parametric and 2500 pai BD testing of one or two globe valves.
- O Priority #2: 2500 psi steam testing of 2 1/2" gate valve
 - at 200 FPS and BD conditions, and cold water testing of 10" valve at 50 FPS
 - (cold water test is complete).
- O Priority #3: Cold water, 15 FPS, testing (partial stroke) of a 18" gate valve at DPs up to 500 psid.
- O Priority #4: Cold water, 15 FPS, testing (partial stroke) of a 12" gate valve at DPs up to 1800 psid.
- O Priority #5: Cold water, 15 FPS testing of valve #19.



December 1993 TAG Concerns

Flow Loop Subcommittee

- Additional flow loop testing
- O Plant In situ testing
- O Data analysis

Modeling & Separate Effects Subcommittee

- MOV "rate-of-loading"
- Gate valve friction-factor changes with stroke/temperature
- Gate valve designs with T-head perpendicular to flow
- Globe valve performance under blowndown conditions
- Gate valve carbon steel guide friction changes with temperature

Topical Report Subcommittee

- O Project schedule and budget
- O TAG and Subcommittee work load
- Review/approval of topical report by NRC




Program Objectives


- Develop and validate a methodology for predicting safety-related MOV performance which covers ~75% population and applications, i.e., common gate, globe and butterfly valve designs with Limitorque motor-operators in wide range of system conditions.
 - · Dynamic in situ testing is not required.
 - MOV specific Information/data may be used to reduce
 - Gate and globe valve rate-of-loading effects are assessed.
 - Potential for gate valve internal damage is predicted
 - User-Irlendly
- 2. Establish valve/operator internals database
- 3 Develop MOV general information database
- 4 Develop improved valve design specification
- 5. Determine areas for future research.




42-4-44 St







~80% Population Covered By EPRI MOV PPP



EPRI MOV Program Results/Impact - Good News & Bad News

- 1. Modelers have developed detailed gate valve prediction methodology.
 - Scope may be limited due to ineufficient flow loop test data and certain gate valve design features.
 - Classic valve vendor equations are not sufficient and give non-conservative results.
 - Some valve manufacturer designs and/or manufacturing processes result in valves that will have non-predictable performance.
 - Utilities without aggressive MOV Programs may have many MOVs with low torque switch settings or undersized motor-operators.
 - Son's valves may have to be reworked, replaced, and/or have motor operators resized.
 - All gats valve designe, sizes, manufacturers, and non-stellite are not covered.



28 21974

1874

EPRI MOV Program Results/Impact - Good News & Bad News (Cont'd)

- 2 Modelers have refined globe valve prediction methodology.
 - Scope does not include blowdown
 - Velve manufacturers and utility angineers using classic vendor equations and valve "nominal" dimensions may underpredict thrust requirements.
 - Some existing switch settings may be insufficient or the motor-operators may be understred.
 - All globe valve designs, sizes, manufacturers are not in scope.



EPRI MOV Program Results/Impact - Good News & Bad News (Cont'd)

- Modelers have developed detailed butterfly valve prediction methodology.
 - Valve manufacturers using older-generation equations and utility engineers using classical equations may under-predict forque.
 - Some existing switch settings may be insufficient or the motor-operators may be understrad.
 - All butterfly valve deelgns, sizes, and manufacturers are not in scope.
- NRC has agreed to review EPRI MOV PPP topical report and leave SER.



Summary

- Must complete Investigation/resolution of key MOV phenomena.
 - Rate-of-loading
 - Gate valve T-head influences
 - Stellite behavior in cold water
 - Globe valve blowdown performance
 - Carbon steel behavlor in warm water
- Must complete additional testing.
 - Flow loop
 - in situ
- Continued utility support for TAG and Subcommittees is imperative.
- Must adhere to very light schedule to ensure April 1994 completion.
- O Program funding is marginal.



Summary (Cont'd)

- Model validation process and/or NRC review may necessitate additional testing.
- NRC tentalively agrees to use generic funding for FPR: MOV PPP topical report review.
- Quality of recent program reports is much improved.
- Excellent progress with butterfly and globe valve model development and validation.
- Good progress with gate valve model development and validation.
- Scope of applicability exceeds objective.
- O Plants without aggressive MOV Programs may be in trouble.
- O Long-term EPRI MOV PPP support for utilities is necessary.

Assessment of Potential Implications for Installed MOV's

EPRI MOV Program Review Meeting

DFW Airport Hyatt

December 1, 1993

N. Estep

EPRI - Dallas Update Meeting

Introduction

Information Available for Evaluation

- EPRI Weekly Status Reports
- EPRI Special Update Reports
- EPRI industry Meeting Presentations
- NRC Information Notices

Issues:

- Gate valve apparent disk-seat friction coefficient and anomalous behavior
- Globe valve apparent valve factors and anomalous behavior
- Butterfly valve hydrodynamic torque coefficients
- Stem-stem nut friction coefficient generic issue and not considered in this evaluation
- Rate-of-Loading generic issue and not considered in this evaluation

Step 1:

- EPRI weekly status reports, special update notices, and industry presentation results were reviewed to identify valves with performance that:
 - Would not have been bounded by Duke thrust/torque predictions, and/or
 - Sustained damage during testing

Considerations for Step 1:

- In presenting the apparent disk to seat sliding friction coefficient (μ) results for gate valves, EPRI used the NMAC Guide [1] equations for differential pressure load, FDP:
 - » Closing (Equation 5-3a)

$$F_{\rm DP}(lbs) = (\mu)(\Delta P)(A_{\rm meam_sest})\frac{1}{\left(\cos\theta - \mu\sin\theta\right)}$$

» Opening (Equation 5-3b)

$$F_{\text{DP}}(lbs) = (\mu)(\Delta P)(A_{\text{mean_seat}})\frac{1}{(\cos\theta + \mu\sin\theta)}$$

Duke uses the following equation to predict the open and close FDP term [2]:

$$F_{DP}(1bs) = (VF)(\Delta P)(A_{mean_seat})$$

Therefore, to convert the EPRI apparent seat friction coefficient values to the valve factor (VF) term used in the Duke equations, the following relationships are used:

» Closing:

$$VF_{close} = \frac{\mu}{(\cos\theta - \mu\sin\theta)}$$

» Opening:

$$VF_{open} = \frac{\mu}{(\cos\theta + \mu\sin\theta)}$$

EPRI - Dallas Update Meeting

Approach

VF and μ are identical when the disk half-wedge angle (θ) is 0-degrees (for example, Anchor-Darling double disk gate valves).


For a 5-degree half wedge angle and a μ of 0.5:

$$> VFc = 0.525$$


For a 5-degree half wedge angle and a VF of 0.5:

» Close
$$\mu = 0.477$$

» Open
$$\mu = 0.520$$



Valve Factor vs Friction Coefficient (for 5-degree half wedge angle)



Consideration 2:

The EPRI values for seat friction coefficient under cold water test conditions represent "preconditioned" values. Therefore, the EPRI friction coefficient results may represent worst case conditions for cold water test conditions. For elevated temperature water (above 200 degrees F) and steam testing, it was observed that seat preconditioning had little effect on the apparent seat friction coefficient results.

Consideration 3:

For globe valves, the valve factor (VF) is essentially a correction term to account for the difference between the assumed and actual area upon which the DP is acting.
 Duke typically uses a VF for globe valves of 1.1.
 Therefore, EPRI globe valve test results with a VF greater than 1.1 were noted.

Table 1 - EPRI Test Valves Exceeding Duke Criteria

EPRI Valve No.	Туре	Mfg	Size	ANSI Class / Material		
3	FWG	Anchor Darling	6	900 cs		
6	FWG	Anchor Darling	18	300 cs		
7	FWG	Borg-Warner	3	1500 cs		
8	FWG	Borg-Warner	6	150 cs		
9	FWG	Borg-Warner	6	1500 cs		
10	FWG	Borg-Warner	12	300 cs		
13	FWG	New Velan	2.5	1500 ss		
14	FWG	Crane	6	900 cs		
19	FWG	Powell	6	150 cs		
21	FWG	Rockwell	2.5	900 cs		
23	FWG	Velan	6	150 cs		
24	FWG	Velan	6	900 cs		
25	FWG	Velan	10	300 cs		
26	FWG	Velan	10	900 cs		
30	FWG	Walworth	6	900 cs		
41	PDG	Anchor Darling	6	900 cs		
43	SWG	Edwards	10	900 cs		
44	Globe	Borg Warner	6	900 cs		
48	Globe	Rockwell / Edwards	2	1500 ss		

Step 2:

This list was further reviewed to determine if MOVs of similar design were in service at Oconee, McGuire or Catawba:

- MOV data bases were searched for a match of manufacturer and valve type.
- MOVs with matching manufacturer and type were further grouped based on size and ANSI pressure class similarity.
 - » An EPRI test valve 6-inches in size may include a review of 4, 6, 8 and 10-inch valves of similar pressure class
 - » Pressure classes of 150/300, and 600/900/1500 were grouped together

Step 2, continued:

- Next, MOV design similarity was determined from a review of the EPRI and Duke valve outline drawings.
 - » Disk shape
 - » Stem-disk connection
 - » Guide configuration
 - » Valve disk materials (for some valve designs)

EPRI - Dallas Update Meeting

Table 2 - EPRI Test Valves Exceeding Duke Criteria and Having Potential Applicability to MOVs in Duke Plants

EPRI Valve No.	Туре	Mfg	Size	ANSI Class / *1aterial
7	FWG	Borg-Warner	3	1500 cs
8	FWG	Borg-Warner	6	150 cs
9	FWG	Borg-Warner	6	1500 cs
10	FWG	Borg-Warner	12	300 cs
14	FWG	Crane	6	900 cs
21	FWG	Rockwell	2.5	900 cs
26	FWG	Velan	10	900 cs
30	FWG	Walworth	6	900 cs
41	PDG	Anchor Darling	6	900 cs
43	SWG	Edwards	10	900 cs
44	Globe	Borg Warner	6	900 cs
48	Globe	Rockwell / Edwards	2	1500 ss

Step 3:

Each valve is individually examined to assess applicability to the EPRI test results:

- MOVs that are not safety-related or included in the Generic Letter 89-10 scope were eliminated from consideration.
- b. MOVs that do not have design-basis requirements similar to the EFRI test conditions that produced the unexpected behavior were eliminated from consideration.
 - » Pumped vs Blowdown
 - » Design-basis stroke direction

Step 3, continued:

- c. Next, Duke in-plant DP and flow test results for MOVs similar to EPRI test valves were reviewed to determine if more favorable results were obtained. For purposes of this evaluation the Duke in-plant test results and not the EPRI test results are considered to be the "best available data" for evaluation purposes.
- d. Finally, if an MOV of concern remains the Duke Problem Investigation Process (PIP) is entered for further action.

46 828 3E 328 JH

Final Results

EPRI

Valve

No.	Disposition
7	No corrective actions
8	Some corrective actions necessary - PIP generated
9	No corrective actions
10	Some corrective actions necessary - PIP generated
14	No corrective actions
21	No corrective actions per letter from manufacturer
26	No corrective actions
30	No corrective actions
41	No corrective actions
43	No corrective actions
44	Some corrective actions necessary - PIP generated
48	No corrective actions

EPRI - Dallas Update Meeting

References

- NMAC, Application Guide for Motor-Operated Valves in Nuclear Power Plants, NP-6660-D, March 1990.
- DPS-1205.19-00-0002, Guideline for Performing Motor Operated Valve Reviews and Calculations.
- NRC Information Notice 89-61, "Failure of Borg-Warner Gate Valves to Close Against Differential Pressure," August 1989.
- 4. EPRI Weekly Status Reports
- EPRI Special Update Notices
- 6. EPR: Program Update Information
- 7. NRC Draft Information Notice on EPRI Test Results
- 8. Letter, Earl Bake of Edward Valves to William Kennedy of EPRI, January 15, 1993.
- Telecopy Message, Earl Bake of Edward Valves to N. Estep of Duke Power, October 25, 1993.

EPRI MOV Performance Prediction Program

OVERVIEW & STATUS

EPRI MOV PROGRAM REVIEW MEETING

DFW Airport Hyatt

December 1, 1993

JOHN F. HOSLER

BACKGROUND

- NRC Generic Letter 89-10
- In Situ Design Basis Testing of MOV's
- Initiation of EPRI MOV Performance Prediction
 Program
 - Formation of Utility Technical Advisory Group (TAG)
 - Establishment of NUMARC/TAG/NRC interface

PROGRAM OBJECTIVES

- Provide Utilities with a validated methodology to analytically predict MOV performance
- Provide a technically defensible alternative to In Situ design basis testing

46 8/4 Sho

Engineering & Operations

APPROACH

- Utilize NMAC MOV Application Guide as starting point
- Develop improved methodology for MOV Performance Prediction to include:
 - fluid system modeling
 - valve computer modeling (gate, globe, and butterfly)
 - methods to apply flow loop/in situ MOV test results to plant specific applications (some gate valve designs)
 - motor-operator dynamic response assessment

Engineering & Operations

APPROACH

- Perform separate effects evaluations to address areas of known uncertainty
 - rate of loading
 - valve design effects
 - friction
 - stem lubrication

APPROACH

- Develop engineering models and software modules to predict MOV performance
 - DP vs stroke position
 - required thrust/torque vs stroke position
 - assessment of potential for gate valve internal damage
 - prediction of motor-operator dynamic response
 - Rate-of-loading effects to be addressed by in situ static test -- validation of test method in progress

Engineering & Operations

46654 At

APPROACH

- Refine engineering models based on results of Separate Effects Testing
- Validate predictive methodology by comparison to flow loop and in situ test results

EPRI/NPD

Summary of All MOV Test Data to be used for Methodology Validation/Assessment

	No. Valves	No. Test Seq.
EPRI Wyle/Siemens Flow Loop Testing	34	62
Duke F/L Testing at Utah State	2	8
EPRI Kalsi Butterfly Valve F/L Testing	10	37
EPRI In-Situ Testing (Fully Enhanced)	28_	28_
	74	135
EPRI In-Situ Tests w/o full enhancement	8_	88
	82	143
INEL/NRC Blowdown Test Program	9_	12
	91	155
		,

Engineering & Operations

AC 624

4478 747 804 POST 1-44

EPRI MOV PERFORMANCE PREDICTION PROGRAM PRODUCTS

Product	DRAFT	FINAL	PUBLISH	
Application Guide for MOV's in Nuclear Power Plants (NMAC Product)*	Complete	Complete	Complete	
Review of INEL Gate Valve Test Program	Complete	Complete	Complete	
n Situ Test Guide*	Complete	Complete	Complete	
MOV Margin Improvement Guide*	Complete	Complete	Complete	
MOV General Information Database*	Complete	Complete	Complete	
Butterrly Application Guide (NMAC Product)*	Complete	Complete	Complete	
Stem Nut Lubricant Test Report	Complete	Complete	Complete	
Methodology Input Specification Draft	Complete	Complete	Complete	
Huntsville Low Pressure Flow Loop Test*	Complete	Complete	Dec. 3, 1993	
Friction Test Report	Complete	Complete	Dec. 3, 1993	
Computational Fluid Dynamics Analysis Report	Complete	Complete	Dec. 15, 1993	
Globe Valve Model Report*	Complete	Dec. 3, 1993	Jan. 31, 1994	
Huntsville Int. Pressure Flow Loop Test*	Dec. 3, 1993	Jan. 7, 1994	Feb. 7, 1994	
Norco Flow Loop Test Report*	Dec. 13, 1993	Jan. 20, 1994	Feb. 20, 1994	
Butterfly Valve Model Report*	Dec. 31, 1993	Jan. 31, 1994 M	Let. 20, 1994	
Siemens/KWU Flow Loop Test Report*	Dec. 17, 1993	Jan. 31, 1994	Feb. 28, 1994	
Butterfly Valve Subscale Test Report	Dec. 3, 1993	Jan. 15, 1994	Mar. 7, 1994	
System Model Report	Dec. 31, 1993	Jan. 31, 1994	Mar. 20, 1994	
In Situ Test Report (Phase 1)*	Dec. 31, 1993	Jan. 31, 1994	Mar. 20, 1994	
Integrated Methodology PC Code*	Mar. 20, 1994 Mar. 20, 1994		Mar. 20, 1994	
Gate Valve Design Effects Report	Dec. 10, 1993	Attet 15, 1994 1	Mater 7, 1994	
Operator Test Report	Feb. 1, 1994	Mar. 1, 1994	Apr. 23, 1994	
Gate Valve Model Report	Feb. 15, 1994	Mar. 15, 1994	May 7, 1994	
PC Code Users Manual*	Feb. 14, 1994	Mar. 15, 1994	May 7, 1994	
Operator Effects Methodology Report*	Feb. 28, 1994	Mar. 31, 1994	May 20, 1994	
In Situ Test Report (Phase 2)*	Mar. 15, 1994	Apr. 15, 1994	June 7, 1994	
Integrated Methodology Assessment Report	Mar. 20, 1994	Apr. 20, 1994	June 10, 199	
Model Implementation Guide*	Mar. 20, 1994	Apr. 20, 1994	June 10, 199	
Empirically Based Methods Reports*	Mar. 31, 1994	Apr. 30, 1994	June 20, 199	
MOV PPP Topical Report (Draft Sections to be issued as completed.)	Oct. 1993 to Apr. 1994	May 15, 1994	July 7, 1994	

^{*} Products which can be directly applied by Utilities in assessing MOV performance capability.

Note: Bolded products are developed under 10CFR50 Appen attention of Ahrs Document were externally generated

and are the best copies available.

This Document is considered acceptable as-is for processing as a QA Record per review IFH in performed by A Shaw date 24/94

EPRI MOV Program Product Distribution

- Two catagories of products
 - Non-Q/A
 - Q/A
- All non-Q/A products will be distributed to MOV Program technical contacts automatically as published
- All Q/A products must be procured directly from Power Computing Corporation in Dallas, Texas via a P.O. which imposes Appendix B and Part 21 requirements
 - A single blanket P.O. will be sufficient to procure all Q/A products
 - Q/A products will be issued as they are published and once P.O. has been received

ATT pat,-4-94 **Power Computing** 930 Hi Line Drive Raboock & Wilcox a McDermott company Dallas Texas 75207 (214) 655-8822 November 2, 1993 EPRI MOV Program Participants - Technical Contacts TO: John Hosler, Electric Power Research Institute FROM: Sarah Scott, Power Computing Company The EPRI MOV Performance Prediction Program will produce a computer program and a number of reports which have been developed under 10CFR50 Appendix B. In addition, some of the work will be reported in non-QA reports. As a participating member of the MOV program, you are entitled to receive all reports and the software. The non-QA reports will be sent to you automatically as they are published by EPRI. Additional copies of all non-QA reports can be ordered from EPRI's Report Distribution Center at (510) 934-4211. The QA reports and software will be distributed for EPRI by the Electric Power Software Center (EPSC), operated by Power Computing Company (PCC) in Dallas, Texas. In order to receive the QA material, each utility should place a purchase order with PCC (nominal cost \$100). The P.O. should request all MOV QA Program Products (shown here as At schment A) and should specify that the terms of the agreement be in accordance with the applicable provisions of 10CFR50 Appendix B and 10CFR21. In addition, the P.O. should specify the name of the utility contact to whom the product should be shipped. It is recommended that a blanket P.O. be placed with PCC for all products shown in Attachment A. In that case, PCC will distribute the products as soon as they are available. It is suggested that sufficient copies of each report be ordered to support utility engineering and each nuclear site. Utilities should minimize the number of Flow Loop Test Reports ordered, since each of these is comprised of approximately 10 volumes with a total of as many as 600 pages per volume. Purchase Orders should be sent to the attention of Sarah L. Scott at PCC at the address above. If you have any questions or need further information, please feel free to contact Ms. Scott at (214) 655-8828.

6+ 1801-21-94 50974

Attachment A

EPRI MOV PERFORMANCE PREDICTION PROGRAM QA PRODUCTS

 MOV Performance Prediction Methodology Computer Code and Supporting Hardcopy Documentation (SW-103242)

The PC-based code will predict the force or torque required to open or close a valve at each position in its stroke. The computer code shall consist of five modules.

- * The <u>System Module</u> will calculate the differential pressure across the valves at each stroke position. Input to this module will include pipe lengths, fluid properties, pump curves, etc.
- Three Valve Modules will be required. The <u>Gate Valve Module</u> and the <u>Globe Valve Module</u> shall calculate the required stem thrust at each stroke position. The <u>Butterfly Valve Module</u> shall calculate the required torque. Input to these modules includes a differential pressure calculated by the System Module as well as valve dimensional parameters, material types, etc. In addition to calculating thrust, the gate valve module shall determine if the valve is likely to exhibit anomalous performance during its stroke.
- * These four modules shall be integrated under the <u>User Interface Module</u> which will handle I/O routines and manage module execution and file maintenance fucntions.
- The code will be delivered with a User's Manual(TR-103243) and a Model Implementation Guide(TR-103244).

28 51 9 7 4 Parini- 4

Attachment A (continued)

EPRI MOV PERFORMANCE PREDICTION PROGRAM QA PRODUCTS

- Additional reports which are being made available as QA controlled documents include:
 - TR 103220 In-Situ Test Report (Phase 1)
 - TR 103224 Butterfly Valve Model Report
 - TR 103225 System Model Report
 - TR 103226 Operator Methodology Report
 - TR 103227 Globe Valve Model Report
 - TR 103229 Gate Valve Model Report
 - TR 103231 Integrated Methodology Assessment Report
 - TR 103237 EPRI MOV Performance Prediction Program Topical Report
 - TR- 103232 Engineering Analysis Report: Anchor/Darling Double Disk Valve
 - TR 103233 Engineering Analysis Report: Westinghouse Gate Valves
 - TR 103234 Engineering Analysis Report: Edward Equivedge Valves
 - TR 103235 Engineering Analysis Report: Aloyco Split-Wedge Valves
 - TR 103236 Engineering Analysis Report: WKM Gate Valves
 - TR 103190 Cold Water Pumped Flow Loop Test Report
 - TR 103239 Cold Water Intermediate Pressure Flow Loop Test Report
 - TR 103240 Norco Flow Loop Test Report
 - TR 103241 Karlstein Flow Loop Test Report
 - TR 103238 In-Situ Test Report (Phase 2)

Review of Flow Loop Test Program Results

EPRI MOV PROGRAM REVIEW MEETING

DFW Airport Hyatt

December 1, 1993

John F. Hosler/W. Kennedy

KEY RESULTS FROM FLOW LOOP TESTING

- Objectives
- Scope
- Gate Valve Preconditioning Approach/Philosophy
- Data analysis Techniques
- Key results

28 53g 74

554974

OBJECTIVES

- Obtain test and inspection data (both valve and operator) for most populous valve designs over a range of size, pressure, △P, and flow conditions to:
 - Provide data for validation of the MOV Performance Prediction Methodology; and
 - Quantify the performance of valves typical of those installed in nuclear power plants under a wide range of media, flow, differential pressure and temperature conditions.

SCOPE

FLOW LOOP FACILITIES (Wyle & Siemens)

- Low pressure, cold water pumped flow at Wyle Laboratories, Huntsville, Alabama. 6" valves tested at DPs up to 250 psi.
- Intermediate pressure, cold water blowdown (simulating pumped flow) at Wyle Laboratories, Huntsville, Alabama. 12" valves tested up to 500 psi, 10" valves tested up to 740 psi.
- High pressure, cold water and hot water pumped flow simulation and hot water and steam blowdown at Wyle Laboratories, Norco, California.
 valves tested up to 1800 psi, 3" valves tested up to 2500 psi.
- High pressure, cold water pumped flow simulation and steam blowdown at Siemens/KWU, Karlstein, Germany. 10" valves tested up to 1800 psi, 18" valves tested up to 500 psi.

SCOPE

Wyle/Siemens Flow Loop Test Program

- Testing completed on 34 valves (62 test sequences) at 4 Wyle/Siemens flow loop facilities.
 - 28 flex or solid wedge or parallel disc gate valves ranging in size from 2-1/2 to 18 inch and 150 to 1500 lb. class
 - 4 globe valves ranging in size from 2-1/2 to 10 inch and 300 to 1500 lb class
 - 2 butterfly valves; 6", 150 lb. class

No	Valve Type	Manufacturer	Size (Inch)	ANSI Class Material	Limitorque Actuator SMB- Type (Note 4)	Ambient Water 15 FPS (Note 6) MAX OP	Ambient Water 50 FPS (Note 5) MAX DP	450 F Water 15 FPS (Note 1) MAX DP	500 F Water Blowdown (Note 2) MAX DP	Sat Steam 200 FPS MAX DP	Sal. Steam Blowdown (Note 2) MAX DP	Alternate Confi- guration Testing Notes
	FWG	Anchor Darling	3	300 cs	00	740 (HI)						
,	FWG		6	150 55	000	250 (HP)						
2	FWG	Ancher Darling	6	900 cs	0	1800 (N)	(N)1800	(N) 1200	(N) 1200			200
4	FWG	Anchor Darling	10	300 ss	0	740 (HI)						B.C. F
r.	FWG	Anchor Darling	10	900 cs	2 150	1800 (S)						-
6	FWG	Anchor Darling	18	300 cs	2	500 (S)						
,	FWG	Borg Warner	3	1500 cs	0.0	2500 (N)	(N) 2500					
B	FWG	Borg-Warner	6	150 cs	Rotork	250 (HP)					-	-
0	FWG	Borg-Warner	6	1500 cs	1	1800 (N)			(N) 1200			
10	FWG	Borg Warner	12	300 cs	1.25	500 (HI)					1	
13	FWG	New Velan	2-1/2	1500 ss	000	2500 (N)	(N) 2500		(N) 2500		-	
14	FWG	Crane	6	900 cs	0	1800 (N)	(N) 1800		(N) 1200			
15	FWG	Walworth/Aloyco	4	150 ss	Rotork	250 (HP)						
16	FWG	Anchor Darling	3	900 cs	0.0	1800 (N)					1	
17	FWG	Pacific	10	150 cs	000	250 (HP)						
18	FWG	Pacific	4	150 cs	Hotork	250 (HP)						
21	FWG	Rockwell	2-1/2	900 cs	000-5	1800 (N)						
23	FWG	Velan	6	150 cs	000	250 (HP)	(HP) 250					
24	FWG	Velan	6	900 cs	0	1800 (N)	(N) 1800	(N) 1200	(N) 1200	(S) 1200	(S) 1200	
25	FWG	Velan	10	300 cs	0	500 (HI)						
26	FWG	Velan	10	900 cs	2	1800 (HI)					(S) :200	ļ
29	FWG	Walworth	6	150 cs	Rotork	250 (HP)						
30	FWG	Walworth	6	900 cs	0	1800 (N)			(N) 1200			
31	FWG	Walworth	12	150 cs	Rotork	250 (HI)						
34	FWG	Westinghouse	3	1500 ss	0.0	2500/750 (N)						G
41	PDG	Anchor/Darling	6	900 cs	0	1800 (N)			(N) 1200		(S) 1200	
43	SWG	Edwards	10	900 cs	2	1800 (HI)					(S) 1200	
4.3	Globe	Borg - Warner	6	900 cs	2	1800 (N)	(N) 1800				-	-
48	Globe	Rockwell/Edwards	2	1500 ss	00	2500 (N)	(N) 2500		(N) 2500		1	
49	Globe	Velan	2-1/2	1500 ss	0.0	2500 (N)						
-	Globe	Anchor Darling	10	300 cs	2	500 (HI)						D
50	BFly	Pratt 1400 Sym	6	150 cs	000 HOBC	150 (HP)						1
54	BFIV	Pratt 1200 Single O/S	6	150 cs	000 HOBC	150 (HP)						D
5.5 XX	FWG	Powell	14	600 cs		500 (HI)						L

THE Wyle Houtsville Pumped How Loop Test Facility

¹³¹ Web Huntsville Intermediate Pressure Lest Facility

N - Wyle Norce High Pressure Test Facility

is somens KWP High Pressure Test Licility

SCOPE

TEST CONFIGURATIONS

- Pump flow simulates opening or closing against the head of an upstream centrifugal pump with some specified downstream resistance
 - Accomplished in each facility by holding test valve upstream pressure nearly constant and providing a throttle in series to limit flow
- Blowdown valve is opened or closed against a storage vessel of hot water or stream whose pressure remain essentially constant and whose piping has low flow resistance

55.974 Rat.

DATA CHANNELS

Stem thrust

Stem torque

Stem position

Valve upstream pressure

Valve downstream pressure

Valve differential pressure

Valve bonnet pressure

Valve under disc pressure

Valve downstream total pressure

Flow rate

Spring pack displacement

Spring pack force

Switch timing (5)

Motor speed

Motor voltage (3 phases)

Motor current (3 phases)

Motor power

Motor power factor

Valve temperature


Fluid temperature

GATE VALVE PRECONDITIONING APPROACH/PHILOSOPHY

- Preconditioning of Flow Loop Gate Valves
 - Objective
 - Precondition (age) test valves prior to test to eliminate stroke effect (reach "plateau" level)
 - Flow loop parametrics would be unaffected by stroke effect
 - Determine relationship between contact stress and number of strokes required to reach plateau
 - Approach
 - Short stroke (~ 10%) open/close MOV in test loop with DP and very low cold water flow until apparent μ reaches "plateau" level
 - DP to be based on max test DP or DP resulting in a contact stress of 20 ksi on seats, whichever is less

27 619 74 600 1-21-94

APPARENT DISC COEFFICIENT OF FRICTION VALVE # 16, PRECONDITIONING



OPEN A CLOSE

BEST AVAILABLE COPY

PRELIMINARY

DATA ANALYSIS TECHNIQUES

 Data sheets are completed on each test stroke to document the values of key parameters at specific "events" in the stroke.


4 12:19


EPRI Gate Valve Test Analysis Data Sheet

(aive #	13-11		Stroke [Direction	1 0 -7	C			
est Description /5	Mrs 1	00% 4	7		THE RESERVE OF THE PERSON NAMED IN COLUMN 2 IS NOT THE PERSON NAME	The state of the s			
aive Mean Seat Diamet	er 3	25		_ in.					
Data File E2014				ata Set	17	Total of Palmer and State			
		140	Current State of Stat	revision Post (clows)	AND THE SPECIAL PROPERTY OF THE PARTY.	Marine Consciour Makes	hu / s	averagent	
Motor Current Start Time* 2 649							24		
Actor Current Stop Time*	/ 7	0.01	1	55 84PASS : 18 20 5 Sec					
Contactor Dropout Time*	successive.	A IL CONTRACTOR AND A STATE OF THE PARTY OF	SEASON SERVICE AND SERVICE ASSESSMENT						
Packing Load at Running	-	441.0							
/enturi/Supply Temp.		82.8		F JUST PRIENT TO THEQUE SWITCHT					
est Valve Inlet Temp.	er annalista	83.6		·F			****		
AND THE PARTY OF T		CI	osed to	Open					
CONTROL OF THE CONTRO	Time (sec)	Thrust (lb.)	Torque (ft-lb)	(kg.)	Mean Upstream Press (psig)	DP PSID	App Disk µ	App Stem µ	
A. At cracking*									
B. Just after cracking									
C. Max after cracking									
D. Running (No DP)			Land.						
E. Limit SW Trip				0 # 6 M					
F. At Flow Initiation		AND THE COLUMN TO THE OWN PARTY.							
THE RESIDENCE OF THE PARTY OF T	des retarentes de la companya de la			CANADA DE CONTRACTOR DE MAN					
partition of the state of the s	fire t	0	pen to C	losed	NAMES AND POST OFFICE AND POST OF THE PERSON NAMES OF THE PERSON N	granatia komu nazvet te renom	Magazini wa mana mana mana ana ana ana ana ana ana		
	Time (sec)	Thrust (lb.)	Torque (ft-lb)	SPDISP (br.)	Meen Upstream Press (pelg)	DP PSID	App Disk µ	App Stem µ	
A. Running (No DP)	4.320	-983.7	7.65	0.0025	781.5	0.75			
B. Max prior to initial wedging	19.158	-3877.4	32.92	0.0693	795.5	772.1	.4316	.1280	
C. At initial wedging	19.243	-3839.8	32.48	0.0693	795.8	772.4	.4242	.1271	
D. TS Trip*	19.478	-80236	CONTRACTOR	0.1738				.1301	
E. Max after wedging	19.526	-	70.04	0.1854.				.1132	
F. Final	20.472	-8734.3	-	0.1851				.0999	
G. At flow isolation	THE PERSON NAMED IN COLUMN TWO IS NOT THE OWNER, THE OW	AND PERSONAL PROPERTY.	28.30	0.0521	790.0	766.2	.3583	.1251	

[&]quot; Values to nearest .001 second, all other values to nearest .01 second.

59 100 1-31-54





Typical Opening Thrust Trace

 $T = T_D + P_D A_s - P_B A_s + \mu \Delta P_B A_o / (\cos \theta + \mu \sin \theta)$

Opening Stroke

T = Siem Thrust lb.

P = Upstream pressure, psi

 $A_s = Stem area. in.^2$

An = Disk mean seat area, in.2

ΔP = Different pressure, psi

μ = Disk coefficient of friction

θ = Half disk angle

Stem $\mu = (24FS \cos \sigma \cdot d \cos \alpha \tan a)/(24FS \tan a + d)$

FS = Torque/thrust ft

d = Stern OD - P/2, in.

p = Pitch. in.


a = Half thread angle

a = Thread lead angle

Stem μ = Stem coefficient of friction

BEST AVAILABLE COPY

65 9 7 4 65 9 7 4



Method Used to Determine Point of Flow Isolation

- Determine change in stem position from cracking peak to flow initiation from hydropump opening stroke
- Determine stem position at initial wedging from a flow/DP stroke
- 3. Subtract change in stem position from (1) above to determine stem position and time of flow isolation

Evaluation of Globe Valve Apparent Valve Factor

$$\mathbf{F}_{R}$$
 (lbs) = $\mathbf{F}_{PACK} + \mathbf{F}_{P} + f(\mathbf{A}_{ontice}) \Delta P$

Where:

 $F_{\scriptscriptstyle R}$ = Maximum stem thrust measured at anytime during stroke

 F_{PACK} = Packing friction load (lbs) - determined from avg of pre/post test static strokes

F_P = Piston Effect load (lbs) - above disk pressure X A stem (valve closed)

f = Valve factor (dimensionless)

(A_{onther}) = Mean seat or guide area (evaluated for both assumptions)

 $\Delta P =$ Pressure difference across the valve (psi) (valve closed)

Butterfly Valves

- Comparison of measured torque to vendor torque predictions not generally possible due to unavailability of vendor methods
 - No conclusion relative to adequacy of current methods possible at this time

Globe Valves

- Incompressible flow (non-flashing)
 - Use of mean seat area and a value factor of 1.0-1.1 found to match data for some valves but found to be significantly non-conservative for others

Globe Valves (Con't)

 Accurate prediction of globe valve thrust requires use of appropriate area for DP application (disc mean seat or guide area).
 Determination of appropriate area for a specific valve design requires evaluation of valve physical design characteristics

45-18-1 AD John Gold

PRINCIPAL FINDINGS

Globe Valves (con't)

- Flashing or compressible flow
 - Data for single valve tested found to exceed even guide area based predictions
 - High thrust requirements attributed to plug side loading due to circumferential pressure variations within valve body

Gate Valves

- Number of strokes to chieve a plateau in apparent disc coefficient of friction during cold water preconditioning varied from 100 to 900 (Initial µ values in 0.1 - 0.4 range)
- Maximum apparent disc µ's during cold water pumped flow testing (after preconditioning) were generally between 0.2 and 0.9, with the exception of one valve

(Industry practice had been to assume a μ of 0.3)

- Disc sliding μ tends to decrease with higher ΔP (higher seat bearing stress) -- supports use of linear extrapolation of reduced DP data -- particularly for non-blowdown applications
- Hot water (450°F, 15 FPS) testing after cold water preconditioning and testing, decreased apparent disc μ to the range of 0.32 to 0.49
- No damage or anomolous performance observed under 15 fps flow conditions except:
 - The disc was pushed through seats allowing leakage above disc on an 18", 3° angle gate valve

73-774 Mas 1-11

- Hot water (530°F) blowdown apparent disc μ's ranged between 0.30 and 0.79 -- some valves sustained significant guide and/or seat damage
- Steam blowdown disc μ 's ranged between 0.33 to 0.72 -- some valves sustained significant guide and/or seat damage
- No measurable effect on apparent disc μ (gate valves) due to upstream elbow orientation or stem orientation