(7-77)

Unit 2

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

| 0 | 1 | TNSNP2 (2) LICENSEE CODE | 00-00000-00 (3) LICENSE NUMBER | 41111 (4) LICENSE TYPE | (5) CAT |

CON'T

| 0 | 1 | REPORT SOURCE: L (6) | DOCKET NUMBER: 05000328 (7) | EVENT DATE: 092182 (8) | REPORT DATE: 102082 (9) |

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 On 09/21/82, during the performance of SI-7.1, "Diesel Generator (D/G) Operability"

0 3 essential raw cooling water (ERCW) valves 1-FCV-67-66 and -68 would not open on

0 4 D/G 1A-A start signal. The valves were then manually opened to provide cooling

0 5 water to the D/G. The circuit breakers to these valves had apparently been left

0 6 open during the performance of SI-251, "Calibration of Thermal Overloads," on

0 7 09/20/82. There was no effect on public health or safety. Previous occurrences -

0 8 none.

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	EE (11)	D (12)	Z (13)	ZZZZZZ (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	82	—	118	/	03	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
G (18)	Z (19)	Z (20)	Z (21)	0000	N (23)	N (24)	Z (25)	Z999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The breakers were closed and D/G 1A-A operability was verified on 09/21/82.

1 1 SI-251 has been revised to record the "as-found" position and to require ASE/SRO

1 2 signoff of the breaker "as-left" position.

1 3

1 4

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	E (28)	100 (29)	NA	B (31)	Surveillance testing

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	000 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	000 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	NA

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	NA	

8210260196 821020
PDR ADOCK 05000328
S PDR

Name of Preparer: W. D. Romine /M. R. Harding Phone: (615) 751-0349