

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

April 20, 1983

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, NW
Atlanta, Georgia 30303


Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - REPORTABLE OCCURRENCE
REPORT BFRO-50-259/83017

The enclosed report provides details concerning diesel-generator 1D being
declared inoperable to repair a lube oil circulating pump motor. This
report is submitted in accordance with Browns Ferry unit 1 Technical
Specification 6.7.2.b(2).

Very truly yours,

TENNESSEE VALLEY AUTHORITY


H. J. Green
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

NRC Inspector, Browns Ferry

03 APR 22 A10:02

ATLANTA REGION
ATLANTA, GEORGIA

8304260354 830420
PDR ADDCK 05000259
S PDR

OFFICIAL COPY

IE 22