



Telegram

1983 APR 18 AM 11:59

50-255

1-008666C108 04/18/83  
ICS IPMMVID MVN  
02521 04-18 1143A CST MVTB  
ICS IPMMVIZ

1-007044C108 04/18/83  
TLX CONSPower JKN

161 CONSUMERS POWER JACKSON MI 11:48 EST 04-18  
PKS

U S NUCLEAR REGULATORY COMMISSION  
PALIS PLANT SECT CHIEF  
799 ROOSEVELT AVENUE  
GLEN ELLYN IL 60137

312 932-2500

MSG # MLB547

14/D.C.  
4/18/83 122P  
mail

TO: U S NUCLEAR REGULATORY COMMISSION  
ATTN: PALISADES PLANT SECTION CHIEF  
799 ROOSEVELT AVENUE  
GLEN ELLYN, ILLINOIS

FROM: R M KRICH, PALISADES

CC: R B DEWITT, P-26-117B, JACKSON

W.U. 1201-SF (R5-69)



Telegram

H D J VANDEWALLE, P-24-614B, JACKSON

THIS CONFIRMS PROMPT NOTIFICATION OF AN OCCURRENCE REPORTABLE PER TS 6.9.2.4.2. ON APRIL 15, 1983, AT APPROXIMATELY 2000 HD PS, SAFETY INJECTION TANK T-82D FELL BELOW THE 18 1/2 INCH REQUIREMENT OF TS 3.3.1 .B AND REMAINED IN THIS CONDITION FOR GREATER THAN THE ONE HOUR LIMIT OF TS 3.3.2.A. SIT T-82D LEVEL WAS RESTORED AT 2103 HOURS ON APRIL 15, 1983. INITIAL REPORT MADE VIA NRC HOT LINE ON APRIL 15, 1983. NOTIFICATION TO THE PALISADES NRC SENIOR RESIDENT INSPECTOR WAS MADE ON APRIL 15, 1983.

1236 EST

1253 EST

IE29 -

8304260370 830418  
PDR ADDCK 05000255  
S PDR

APR 20 1983

W.U. 1201-SF (R5-69)