



EDISON DRIVE  
AUGUSTA, MAINE 04336  
(207) 623-3521

October 18, 1982  
MN-82-204

JHG-82-192

United States Nuclear Regulatory Commission  
Directorate of Regulatory Operations  
Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Reference: License DPR-36 (Docket No. 50-309)

Subject: Maine Yankee Reportable Occurrence 82-29/01T-0

Dear sir:

Pursuant to the requirements of Technical Specification 5.9.1.6.c, the Maine Yankee Atomic Power Company reports the following:

Scheduled eddy current tests of the #2 steam generator tubes conducted during the current refueling shutdown resulted in identification of a small number of tubes which exceed the tube plugging limit defined in Technical Specification 4.10.

Very truly yours,

MAINE YANKEE ATOMIC POWER COMPANY

A handwritten signature in cursive script that reads "John Garrity".

John H. Garrity, Senior Director,  
Nuclear Engineering & Licensing

JHG:pjp

cc: Mr. Robert A. Clark  
Mr. Ronald C. Haynes  
Mr. Paul A. Swetland

8210260327 821018  
PDR ADOCK 05000309  
S PDR

0046L - JHG

Handwritten initials "IE29" with two arrows pointing from the text towards the top right corner of the page.