



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

OCT 28 1982

MEMORANDUM FOR: Thomas M. Novak, Assistant Director for  
Licensing, DL

FROM: James P. Knight, Assistant Director for  
Components & Structures Engineering, DE

SUBJECT: REVIEW OF LASALLE INTERIM REPORT FOR  
INDEPENDENT HVAC SYSTEM REVIEW

- References: 1. Letter from C. W. Schroeder to T. M. Novak, dated  
September 20, 1982 with attachment
2. Memorandum from T. M. Novak to J. P. Knight, et al,  
dated October 13, 1982

We have reviewed the interim report on the LaSalle independent HVAC system review performed by C. F. Braun. The primary objective of the design review is to provide verification that the HVAC installation by the Zack Company is in accordance with the Sargent & Lundy design. However, because the Sargent & Lundy design is not in question, the scope of work will not include a review of the Sargent & Lundy design. Thus, from a mechanical design standpoint, the only major concern would be if significant as-built design changes were found. In the interim report, C. F. Braun has stated that if their review results in safety concerns involving significant as-built design changes, then the as-built changes will be evaluated against the S&L design document. Based on the above commitment, we find the interim report to be acceptable and conclude that, from a mechanical design standpoint, the interim report is consistent with the Technical Proposal dated August 25, 1982.

James P. Knight, Assistant Director for  
Components & Structures Engineering  
Division of Engineering

- cc: R. Vollmer  
R. Bosnak  
A. Bournia  
H. Brammer  
D. Terao

8211090596 XA

XA Copy Has Been Sent to PDR