

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

May 24, 1994

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 94-303
MPW/EJW
Docket Nos. 50-338
50-339
License Nos. NPF-4
NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNITS 1 AND 2
FIRE PUMP OUT OF SERVICE GREATER THAN 7 DAYS
SPECIAL REPORT

Pursuant to the North Anna Power Station Technical Requirements Manual, Specification TR 7.1.1.B.1, a Special Report is required because the motor driven fire pump was out of service for greater than 7 days. On April 27, 1994, at 0158 hours, the motor driven fire pump, 1-FP-P-1, was tagged out and removed from service to facilitate maintenance activities on the "B" Circulating Water (CW) pump, 1-CW-P-1B.

The fire pump takes suction from the "B" CW bay and, as such, is removed from service to drain the bay prior to maintenance activities being performed. The motor driven fire pump remained out of service until maintenance on the "B" CW pump was completed. To provide for a loss of redundancy, with 1-FP-P-1 out of service, another motor driven fire pump, 1-FP-P-11, was maintained operable and aligned to the plant fire loop. Fire pump 1-FP-P-1 was returned to service on May 10, 1994.

This Special Report has been reviewed by the Station Nuclear Safety and Operating Committee and will be provided to the Management Safety Review Committee.

Should you have any questions regarding this report, please contact us.

Very truly yours,



J. P. O'Hanlon
Vice President - Nuclear Operations

160026

9406170076 940524
PDR ADOCK 05000338
S PDR

JE22 1/0

cc: U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N.W.
Suite 2900
Atlanta, Georgia 30323

Mr. R. T. McWhorter
NRC Senior Resident Inspector
North Anna Power Station