



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
PHILADELPHIA ELECTRIC COMPANY
DELMARVA POWER AND LIGHT COMPANY
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-272

SALEM NUCLEAR GENERATING STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 49
License No. DPR-70

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated June 22, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-70 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 49, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 5, 1982

ATTACHMENT TO LICENSE AMENDMENT NO. 49

FACILITY OPERATING LICENSE NO. DPR-70

DOCKET NO. 50-272

Revise Appendix A as follows:

Remove Page

3/4 7-42

Insert Page

3/4 7-42

PLANT SYSTEMS

3/4.7.11 PENETRATION FIRE BARRIERS

LIMITING CONDITION FOR OPERATION

3.7.11 All fire barrier penetrations (including cable penetration barriers, firedoors and fire dampers), in fire zone boundaries, protecting safety related areas shall be functional.

APPLICABILITY: At all times.

ACTION:

- a. With one or more of the above required fire barrier penetrations non-functional, within one hour either establish a continuous fire watch on at least one side of the affected penetration, or verify the OPERABILITY of fire detectors on at least one side of the non-functional fire barrier and establish an hourly fire watch patrol. Restore the non-functional fire barrier penetration(s) to functional status within 7 days or, in lieu of any other report required by Specification 6.9.1, prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within the next 30 days outlining the action taken, the cause of the non-functional penetration and plans and schedule for restoring the fire barrier penetration(s) to functional status.
- b. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.7.11 Each of the above required penetration fire barriers shall be verified to be functional:

- a. At least once per 18 months by a visual inspection, and
- b. Prior to returning a penetration fire barrier to functional status following repairs or maintenance by the performance of a visual inspection of the affected penetration fire barrier(s).