## NOTICE OF DEVIATION

Commonwealth Edison Company Dresden Station Unit 1 Docket No. 50-010 License No. DPR-2

During an NRC inspection conducted on January 27 through February 18, 1994, a deviation from commitments made by the licensee was identified in a letter dated May 18, 1990. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Action," 10 CFR Part 2, Appendix C, the deviation is listed below:

In a letter dated May 18, 1990, the licensee stated, in part, that the "Dresden Station Unit 1 Fuel Pool Noble Gas Monitor (Eberline Model SPING-3A) will be operational by March 1, 1991.

Contrary to the above, as of January 25, 1994, the Dresden Station Unit 1 Fuel Pool Noble Gas Monitor was not operational.

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region III, 801 Warrenville Road, Lisle, Illinois 60532-4351, and a copy to the NRC Resident Inspector at the Dresden Station in writing within 30 days of the date of this Notice, the reason(s) for the deviation, the corrective steps which have been taken and the results achieved, the corrective steps which will be taken to avoid further deviations, and the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

Dated at Rockville, Maryland this 13th day of June 1994

9406170155 940613 PDR ADDCK 05000010 Q PDR Commonwealth Edison Company

DISTRIBUTION: SECY CA JTaylor, EDO JMilhoan, DEDR JLieberman, OE LChandler, OGC JGoldberg, OGC WRussell, NRR LReyes, NRR LTre.nper, OC Enforcement Coordinators RI, RII, RIV JBeall, OE FIngram, GPA/PA DWilliams, OIG BHayes, OI EJordan, AEOD EA File (2) DCS State of Illinois RAO:RIII SLO:RIII PAO:RIII IMS:RIII

OE, Jg	RA: RITTLe tione con	D: OE APA	DEDR
JGray	JMartin	JLieberman	JMilhoan
06/13/94	06/13/94	06/13/94	06//3/94

Doc Name: 6:\OECASES\94044RE2.JRG