



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379-2000

Ken Powers
Vice President, Sequoyah Nuclear Plant

June 7, 1994

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)
Tennessee Valley Authority) Docket No. 50-327

SEQUOYAH NUCLEAR PLANT (SQN) - NRC BULLETIN 88-11, PRESSURIZER SURGE LINE
THERMAL STRATIFICATION (TAC NO. 72166)

- References:
1. TVA letter to NRC dated January 28, 1991, "Sequoyah Nuclear Plant (SQN) - NRC Bulletin 88-11, Pressurizer Surge Line Thermal Stratification (TAC Nos. 72166/72167)"
 2. TVA letter to NRC dated December 6, 1991, "Sequoyah Nuclear Plant (SQN) - NRC Bulletin 88-11, Pressurizer Surge Line Thermal Stratification (TAC Nos. 72166/72167)"

The purpose of this letter is to notify NRC that the Unit 1 pressurizer surge line has been modified as discussed in References 1 and 2. This modification was completed during the recent Unit 1 Cycle 6 refueling outage. Additionally, Unit 1 now meets the American Society of Mechanical Engineers Code Equation 12 stress limits as required in the subject bulletin.

Please direct questions concerning this issue to W. C. Ludwig at (615) 843-7460.

Sincerely,

Ken Powers

cc: See page 2

JE30 1/0

U.S. Nuclear Regulatory Commission

Page 2

June 7, 1994

cc: Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323-2711