



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

April 21, 1983

83 APR 25 AID: 13

REGIONAL ADMINISTRATOR

JAMES P. McGAUGHY, JR.  
VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Special Report 83-019/0 - Fire  
Barriers Opened to Support  
Planned Work  
AECM-83/0249

On March 17 and 19, 1983, several fire barriers in the Control Building and Auxiliary Building were opened to support implementation of design change packages.

Hourly fire watches were established in accordance with Technical Specification 3.7.7. All penetrations are expected to be restored by June 30, 1983. This is submitted as a Special Report pursuant to Technical Specification 6.9.2 since the seven day LCO time limit of Technical Specification 3.7.7 was exceeded.

Yours truly,

*J.P. McGaughy, Jr.*  
FOR J.P. McGaughy, Jr.

JPM:sap

- cc: Mr. J. B. Richard  
Mr. R. B. McGehee  
Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

OFFICIAL COPY

IE 22

8304280046 830421  
PDR ADOCK 05000416  
S PDR