

# NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY  
THE HARTFORD ELECTRIC LIGHT COMPANY  
WESTERN MASSACHUSETTS ELECTRIC COMPANY  
HOLYOKE WATER POWER COMPANY  
NORTHEAST UTILITIES SERVICE COMPANY  
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
(203) 666-6911

April 22, 1983  
MP-4989

Mr. James M. Allan  
Acting Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission Regional Office  
631 Park Avenue  
King of Prussia, PA. 19406

Reference: Facility Operating License DPR-65  
Docket No 50-336  
Reportable Occurrence RO-50-336/83-13/3L-0

Dear Mr. Allan:

This letter forwards the Licensee Event Report 83-13/3L-0 required to be submitted within thirty days pursuant to Millstone Unit 2 Appendix A Technical Specifications, Section 6.9.1.9.a, reactor protection system instrument settings found to be less conservative than those required in the Technical Specifications but which do not prevent the fulfillment of the functional requirements of the effected system. An additional three copies of the report are enclosed.

Yours truly,

NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in cursive script, appearing to read 'E. J. Mrocčka'.

E. J. Mrocčka  
Station Superintendent  
Millstone Nuclear Power Station

EJM/KD:ejl

Attachment: LER RO-50-336/83-13/3L-0

cc: Director, Office of Inspection and Enforcement Washington,  
D. C. (30)  
Director, Office of Management Information and Program  
Control, Washington, D.C. (3)  
U.S. Nuclear Regulatory Commission, c/o Document Management  
Branch, Washington, D.C. 20555

8304280055 830422  
PDR ADOCK 05000336  
S PDR

IE22