JUN 8 1994

Docket No. 50-213

Mr. John F. Opeka
Executive Vice President - Nuclear
Connecticut Yankee Atomic Power Company
P.O. Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: HADDAM NECK INSPECTION 94-12

This letter refers to the inspection conducted by Mr. Brian J. McDermott of this office between May 9 - 13, 1994, at the Haddam Neck Nuclear Power Station. The purpose of this inspection was to evaluate your corrective actions in response to previous findings; specifically, work control and valve issues. This inspection also addressed residual heat removal heat exchanger capacity and high pressure safety injection (HPSI) inservice testing. At the conclusion of the onsite inspection, the preliminary results were discussed with Mr. John D. Haseltine and other members of your staff.

In general, the inspector found your corrective actions acceptable. Improvements were noted in the quality of work package documentation and in the area of work preparation/control using the Integrated Team approach. The motor-operated valve (MOV) issues were satisfactorily addressed through revision of the program manual.

No response to this letter is required, and your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed Dys

Eugene M. Kelly, Chief Systems Section Division of Reactor Safety

Enclosure: NRC Region I Inspection Report No. 50-213/94-12 w/Attachment 1

9406170257 940608 PDR ADDCK 05000213 PDR 1601 ,

cc w/encl:

S. E. Scace, Vice President, Nuclear Operations Services

J. P. Stetz, Vice President, Haddam Neck Station

J. Solymossy, Director, Nuclear Quality and Assessment Services

J. J. LaPlatney, Director, Nuclear Unit

R. M. Kacich, Director, Nuclear Planning, Licensing and Budgeting

Gerald Garfield, Esquire

Nicholas Reynolds, Esquire

K. Abraham, PAO (2)

Public Document Room (PDR)

Local Public Document Room (LPDR)

Nuclear Safety Information Center (NSIC)

NRC Resident Inspector

State of Connecticut SLO

bcc w/encl:

Region I Docket Room (with concurrences)

bcc w/encl (VIA E-MAIL):

J. Stolz, NRR/PD I-4

W. Dean, OEDO

A. Wang, PM, NRR

M. Shannon, NRR/ILPB

C. Beardslee, DRS, SALP Coordinator

GRI: DRS McDermott

6/7/94

RI:DRS Buckley

6/6-7

RI: DRS Kelly/

6/ 194

OFFICIAL RECORD COPY A:HN9412.INS