

NOV 08 1982

Docket No. 50-364
50-348

DISTRIBUTION
Docket
NRC PDR
L PDR
NSIC
ORB #1 Rdg
Deisenhut
OELD
JMTaylor
ELJordan
ACRS-10
CParrish
EReeves
JTBeard
Gray

Mr. F. L. Clayton
Senior Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

Dear Mr. Clayton:

We have completed our review of Multiplant Action Item (MPA) C-14, "Seismic Qualification of Auxiliary Feedwater Systems" for Joseph M. Farley Nuclear Plant, Units 1 and 2. Your letters dated October 9, 1981 and July 16, 1982 responded to our Generic Letter No. 81-14 dated February 10, 1981 and our letter dated April 2, 1982, respectively.

Your submittals were reviewed by our consultant, Lawrence Livermore National Laboratory. The consultant's Technical Evaluation Report concludes that the AFW Systems at the Farley site would provide the safety-related functions to assure safe shutdown following an Safe Shutdown Earthquake without system modification or upgrading. We concur with this conclusion.

Therefore, our concerns expressed in MPA Item C-14 are resolved. Our Safety Evaluation is enclosed.

Sincerely,

Original signed by:
S. A. Varga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosures:

- 1. Safety Evaluation
- 2. Technical Evaluation Report

cc w/enclosures:
See next page

8211170082 821108
PDR ADDCK 05000348
P PDR

OFFICE	ORB #1: DL <i>EReeves</i>	ORB #2: DL <i>SVarga</i>					
SURNAME	EReeves:dm	SVarga					
DATE	11/8/82	11/8/82					

Mr. F. L. Clayton, Jr.
Alabama Power Company

cc: Mr. W. O. Whitt
Executive Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

Ruble A. Thomas, Vice President
Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Robert A. Buettner, Esquire
Balch, Bingham, Baker, Hawthorne,
Williams and Ward
Post Office Box 306
Birmingham, Alabama 35201

Resident Inspector
U. S. Nuclear Regulatory Commission
Post Office Box 24-Route 2
Columbia, Alabama 36319

Mr. R. P. McDonald
Vice President - Nuclear Generation
Alabama Power Company
P.O. Box 2641
Birmingham, Alabama 35291

James P. O'Reilly
Regional Administrator - Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303