

NOV 04 1982

Docket No. 50-271

Mr. J. B. Sinclair  
Licensing Engineer  
Vermont Yankee Nuclear Power  
Corporation  
1671 Worcester Road  
Framingham, Massachusetts 01701

DISTRIBUTION:

Docket File  
NRC PDR  
Local PDR  
ORB #2 Rdg.  
D. Eisenhut  
OELD  
E. L. Jordan  
V. Rooney  
S. Norris  
R. Ferguson (50)  
NSIC  
J. M. Taylor

ACRS (10)  
J. Heltemes, AEOD  
FRC  
RPrevatte

Dear Mr. Sinclair:

Re: Vermont Yankee Station Electrical Distribution System Voltages

We have reviewed your letter dated September 7, 1982 dealing with adequacy of station electrical distribution system voltages, and find that additional information is needed in order to complete our review.

Please provide a proposed Technical Specification change to require that with only one startup transformer available, the startup transformer tap be changed to 112 kv and the 4160/480 volt station service transformers taps be changed to the 4060/480 volt tap.

We request that this information be provided within 30 days of receipt of this letter. The need for this information has previously been discussed with your staff.

If you have any questions, please contact the assigned Project Manager.

The request for information contained in this letter affects fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

*Original signed by*

Domenic B. Vassallo, Chief  
Operating Reactors Branch #2  
Division of Licensing

cc: See next page

8211170125 821104  
PDR ADOCK 05000271  
P PDR

OFFICE	ORB #2	ORB #2	ORB #2				
SURNAME	Norris	Rooney/tcm	Vassallo				
DATE	11/4/82	11/4/82	11/4/82				

Mr. J. B. Sinclair

cc:

Mr. W. F. Conway  
President & Chief Executive Officer  
Vermont Yankee Nuclear Power Corp.  
R.D. 5, Box 169  
Ferry Road  
Brattleboro, Vermont 05301

Mr. Louis Heider, V. P.  
Vermont Yankee Nuclear Power Corp.  
1671 Worcester Road  
Framingham, Massachusetts 01701

John A. Ritscher, Esquire  
Ropes & Gray  
225 Franklin Street  
Boston, Massachusetts 02110

New England Coalition on Nuclear  
Pollution  
Hill and Dale Farm  
R.D. 2, Box 223  
Putney, Vermont 05346

Mr. Walter Zaluzny  
Chairman, Board of Selectman  
P.O. Box 116  
Vernon, Vermont 05354

J. P. Pelletier, Plant Manager  
Vermont Yankee Nuclear Power Corp.  
P.O. Box 157  
Vernon, Vermont 05354

Raymond N. McCandless  
Vermont Division of Occupational  
& Radiological Health  
Administration Building  
10 Baldwin Street  
Montpelier, Vermont 05602

Honorable John J. Easton  
Attorney General  
State of Vermont  
109 State Street  
Montpelier, Vermont 05602

W. P. Murphy, Vice President &  
Manager of Operations  
Vermont Yankee Nuclear Power Corp.  
R. D. 5, Box 169  
Ferry Road  
Brattleboro, Vermont 05301

U.S. Environmental Protection Agency  
Region I Office  
Regional Radiation Representative  
JFK Federal Building  
Boston, Massachusetts 02203

Public Service Board  
State of Vermont  
120 State Street  
Montpelier, Vermont 05602

Vermont Yankee Decommissioning  
Alliance  
53 Frost Street  
Brattleboro, Vermont 05301

Vermont Yankee Decommissioning  
Alliance  
5 State Street  
Box 1117  
Montpelier, Vermont 05602

Resident Inspector  
c/o U.S. NRC  
P.O. Box 176  
Vernon, Vermont 05453

Vermont Public Interest Research  
Group, Inc.  
43 State Street  
Montpelier, VT 05602

Ronald C. Haynes  
Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

November 4, 1982

Docket No. 50-271

Mr. J. B. Sinclair  
Licensing Engineer  
Vermont Yankee Nuclear Power  
Corporation  
1671 Worcester Road  
Framingham, Massachusetts 01701

Dear Mr. Sinclair:

Re: Vermont Yankee Station Electrical Distribution System Voltages

We have reviewed your letter dated September 7, 1982 dealing with adequacy of station electrical distribution system voltages, and find that additional information is needed in order to complete our review.

Please provide a proposed Technical Specification change to require that with only one startup transformer available, the startup transformer tap be changed to 112 kv and the 4160/480 volt station service transformers taps be changed to the 4060/480 volt tap.

We request that this information be provided within 30 days of receipt of this letter. The need for this information has previously been discussed with your staff.

If you have any questions, please contact the assigned Project Manager.

The request for information contained in this letter affects fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

A handwritten signature in cursive script, appearing to read "D. B. Vassallo".

Domenic B. Vassallo, Chief  
Operating Reactors Branch #2  
Division of Licensing

cc: See next page