

DES

JUN 10 1994

Docket Nos. 50-245
50-336

Mr. John F. Opeka
Executive Vice President - Nuclear
Northeast Nuclear Energy Company
P. O. Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: COMBINED INSPECTION REPORT NOS. 50-245/94-11 AND 50-336/94-08

This refers to the announced safety inspection conducted by Mr. R. Bhatia of this office from April 4-22, 1994, at Millstone Units 1 and 2, in Waterford, Connecticut, and at the corporate office in Berlin, Connecticut. Mr. Bhatia discussed the results of this inspection with Mr. H. Risley and other members of your staff at the conclusion of this inspection.

The inspection was focussed on activities important to public health and safety. Areas examined during this inspection included the resolution and corrective actions taken for open items identified previously during the electrical distribution system functional inspections (EDSFI). Within this scope, the inspection consisted of selective examinations of design documents, procedures and representative records, interviews with personnel, and observations by the inspector.

The inspector determined that a significant effort had been completed to address the EDSFI unresolved items. In general, the calculations and analyses developed to address these issues were technically sound and thorough. The corrective actions completed for 13 unresolved items were reviewed during this inspection. The corrective actions completed for eight Unit 1 and four Unit 2 unresolved items were adequate, and these items are closed. There was one Unit 2 unresolved item regarding the adequacy of voltage for the charging pump motor control centers control circuits that was left open pending the implementation of a modification to resolve this design deficiency.

170041

9406170323 940610
PDR ADDCK 05000245
Q PDR

1E01 / 1


Mr. John F. Opeka

2

JUN 10 1994

Your cooperation with us in this matter is appreciated.

Sincerely,



James M. Trapp, Acting Chief
Electrical Section
Division of Reactor Safety

Enclosure: Combined Inspection Report Nos.
50-245/94-11 and 50-336/94-08 w/Attachment 1

cc w/encl:

J. P. Stetz, Vice President, Haddam Neck Station
G. H. Bouchard, Nuclear Unit Director
R. M. Kacich, Director, Nuclear Licensing
J. Solymossy, Director, Nuclear Quality and Assessment Services
S. E. Scace, Vice President, Nuclear Operations Services
D. B. Miller, Senior Vice President, Millstone Station
H. F. Haynes, Nuclear Unit Director
Gerald Garfield, Esquire
Nicholas Reynolds, Esquire
K. Abraham, PAO (2)
NRC Resident Inspector
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
State of Connecticut SLO Designee

Mr. John F. Opeka

3

JUN 10 1994

bcc w/encl:

Region I Docket Room (with concurrences)

bcc w/encl (VIA E-MAIL):

W. Dean, OEDO

G. Vissing, PM, NRR

J. Stolz, NRR/PDI-4

V. McCree, OEDO

D. Jaffe, PM, NRR

J. Andersen, NRR

M. Shannon, NRR/ILPB

RI:DRS

Bhatia/ajk/dmg

05/16/94

RI:DRS

Trapp

06/6/94

OFFICIAL RECORD COPY

A:M12-1108.INS