

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

April 21, 1983

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Suite 2900  
101 Marietta Street, NW  
Atlanta, Georgia 30303


Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 2 - DOCKET  
NO. 50-260 - FACILITY OPERATING LICENSE DPR-52 - REPORTABLE OCCURRENCE  
REPORT BFRO-50-260/83012

The enclosed report provides details concerning use of a non-conservative  $K_f$  factor to calculate the minimum critical power ratio limit. This report is submitted in accordance with Browns Ferry unit 2 Technical Specification 6.7.2.b(3).

Very truly yours,

TENNESSEE VALLEY AUTHORITY



H. J. Green  
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Records Center  
Institute of Nuclear Power Operations  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339

NRC Inspector, Browns Ferry

8304280163 830421  
PDR ADDCK 05000260  
S PDR

OFFICIAL COPY

IF 22