(7-77)

Unit 2

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	T N S N P 2 (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)		(5)
	LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT	

CON'T

0 1	REPORT SOURCE L (6)	0 5 0 0 0 3 2 8 (7)	0 3 2 4 8 3 (8)	0 4 2 2 8 3 (9)
		DOCKET NUMBER	EVENT DATE	REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 Unit 1 in mode 1 at 98% Rx power. At 1700 hours, an ice condenser intermediate
0 3 deck door in bay 11 was found frozen closed during a routine inspection. This
0 4 event required entry into LCO 3.6.5.3. There was no effect on public health
0 5 and safety. Previous occurrences to be provided in an updated report.
0 6
0 7
0 8

0 9	SYSTEM CODE S B (11)	CAUSE CODE X (12)	CAUSE SUBCODE Z (13)	COMPONENT CODE X X X X X X (14)	COMP. SUBCODE C (15)	VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 3	—	0 4 9	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURE
X (18)	X (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	N (25)	X 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The ice was chipped off the door and removed from the ice condenser. The door
1 1 was declared operable at 2100 hours. The ice resulted from leaks in the condensate
1 2 drain lines of air handling units 13 and 14. The root cause for these leaks is
1 3 not known at present. An update report will be sent when additional information
1 4 is available after the leaks are repaired.

1 5	FACILITY STATUS E (28)	% POWER 0 9 8 (29)	OTHER STATUS (30) NA	METHOD OF DISCOVERY B (31)	DISCOVERY DESCRIPTION (32) Operator observation

1 6	ACTIVITY RELEASED Z (33)	CONTENT OF RELEASE Z (34)	AMOUNT OF ACTIVITY (35) NA	LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES

1 7	NUMBER 0 0 0 (37)	TYPE Z (38)	DESCRIPTION (39) NA

PERSONNEL INJURIES

1 8	NUMBER 0 0 0 (40)	DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (4

1 9	TYPE Z (42)	DESCRIPTION NA

8304280173 830422
PDR ADOCK 05000328
S PDR

PUBLICITY

2 0	ISSUED N (44)	DESCRIPTION (45) NA	NRC USE ONLY

Name of Preparer: A.M. Carver /M. R. Harding Phone: (615) 870-6422