

RECEIVED
APR 18 1983

Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

April 12, 1983
ANPP-23470-BSK/RQT

U. S. Nuclear Regulatory Commission
Region V
Creekside Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. D. M. Sternberg, Chief
Reactor Projects Branch 1

Subject: Time Extension For Report - DER 82-68
A 50.55(e) Potentially Reportable Deficiency Relating to
Underground Cables To Startup Transformers May Not Carry
Full-Load Current At Maximum Site Soil Temperature
File: 83-019-026; D.4.33.2

- Reference:
- (A) Telephone Conversation between J. Eckhardt and J. Cook on November 26, 1982
 - (B) ANPP-22521, dated December 13, 1982 (Interim Report)
 - (C) ANPP-23025, dated February 16, 1983 (Time Extension)
 - (D) ANPP-23347, dated March 24, 1983 (Time Extension)


Dear Sir:

The NRC was notified of a potentially reportable deficiency in Reference (A), an Interim Report was transmitted by Reference (B), Time Extensions were requested by Reference (C) and Reference (D). At that time, it was estimated that a Final Report would be available by April 14, 1983.

Due to the extensive evaluation required, it is now expected that this information will be finalized by May 10, 1983, when a complete report will be submitted.

There is no change to the Interim Report at this time.

Very truly yours,



E. E. Van Brunt, Jr.
APS Vice President
Nuclear Projects Management
ANPP Project Director

EEVB/RQT:db
cc: See Page 2

8304280193 830412
PDR ADOCK 05000528
S PDR

1E27

Mr. D. M. Sternberg
ANPP-23470-RQT/BSK
April 12, 1983
Page 2

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
G. C. Andognini
J. A. Roedel
D. B. Fasnacht
A. C. Rogers
B. S. Kaplan
W. E. Ide
J. Vorees
J. R. Bynum
P. P. Klute/D. D. Green
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
R. M. Grant
D. R. Hawkinson
L. E. Vorderbrueggen
G. A. Fiorelli

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339