



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

April 21, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-021/0 - Fire
Barriers in Auxiliary
Building Opened to Support
Planned Maintenance
Activities
AECM-83/0251

On March 15 and 16, 1983, five fire doors in the Auxiliary Building were blocked open to allow performance of planned maintenance activities. Hourly fire watches were established and maintained at all times during performance of the planned maintenance tasks in accordance with Technical Specification 3.7.7.

All maintenance activities were completed by 2130 on April 15, 1983. Upon completion, the doors were closed and their alarm circuits were activated. This is a Special Report submitted pursuant to Technical Specification 6.9.2.

Yours truly,

J.P. McGaughey Jr.
FOR J.P. McGaughey JR.

JPM:sap

cc: (See Next Page)

8304280194 830421
PDR ADOCK 05000416
S PDR

OFFICIAL COPY
IC 22

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0251

Page 2

cc: Mr. J. F. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555