



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

April 20, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - Fire Rated
Barriers in the Control
Building and Auxiliary
Building Opened to Perform
Planned Maintenance
Activities
LER 83-011/99 X-1
AECM-83/0229

This is an update to a previous report submitted on February 3, 1983. The events for which the report was submitted occurred from January 3 to January 24, 1983, when certain fire rated barriers in the Control Building and Auxiliary Building were opened to perform planned maintenance activities. Fire watches were established in accordance with Technical Specification 3.7.7.a.

The estimated restoration date for the barriers in the previous report was April, 1983. The barriers are now expected to be restored by June 15, 1983. Attached is LER 83-011/99 X-1, which is a final report.

Yours truly,

J.P. McGaughey Jr.
J.P. McGaughey Jr.

JPM:sap
Attachment

cc: (See Next Page)

8304280211 830420
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

IE 22

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0229

Page 2

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555