

June 15, 1994

Docket No. 50-461

Clinton Power Station
ATTN: Mr. Richard F. Phares
Director - Licensing
Post Office Box 678
Mail Code V920
Clinton, Illinois 61727

Dear Mr. Phares:

SUBJECT: NRC BULLETIN 90-01 SUPPLEMENT 1, "LOSS OF FILL-OIL IN TRANSMITTERS
MANUFACTURED BY ROSEMOUNT" - CLINTON POWER STATION, UNIT NO. 1
(TAC NO. M85373)

NRC Bulletin 90-01, Supplement 1, was issued on December 22, 1992, to inform addressees of activities taken by the NRC staff and the industry in evaluating Rosemount Transmitters, and to request licensees to take actions to resolve this issue. Your letters of March 5, 1993 (U-602106), and January 27, 1994 (U-6022244), responded to the Bulletin Supplement.

The staff and its contractor, EG&G Idaho, Inc., have reviewed your responses and conclude that it conforms to the Requested Actions of NRC Bulletin 90-01, Supplement 1, and completes the reporting requirements. The staff's Safety Evaluation and the contractor's Technical Evaluation Report, EGG-ERTP-11234, are enclosed for your information.

Sincerely,

ORIGINAL SIGNED BY

Douglas V. Pickett, Senior Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Safety Evaluation
- 2. Technical Evaluation Report EGG-ERTP-11234

cc: See next page

DISTRIBUTION:

- Docket File
- PDR & Local PDRs
- PDIII-3 Reading File
- J. Roe 013E4
- J. Zwolinski 013H24
- M. Rushbrook
- D. Pickett
- J. Hannon
- OGC 02G5
- ACRS (10) P315
- E. Greenman, RIII
- D. Spaulding

170058

NRC FILE CENTER COPY

LA:PDIII-3	PM:PDIII-3	D:PDIII-3
M. Rushbrook	D. Pickett:lm	J. Hannon
6/14/94	6/15/94	6/15/94
YES/NO	YES/NO	YES/NO

NAME: G:\Clinton\TAC85373.1tr

9406200043 940615
PDR ADDCK 05000461
PDR

DFD

Mr. Richard F. Phares
Illinois Power Company

Clinton Power Station
Unit No. 1

cc:

Mr. John Cook
Vice President
Clinton Power Station
Post Office Box 678
Clinton, Illinois 61727

Illinois Department
of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Mr. J. A. Miller
Manager Nuclear Station
Engineering Department
Clinton Power Station
Post Office Box 678
Clinton, Illinois 61727

Resident Inspector
U.S. Nuclear Regulatory Commission
RR#3, Box 229 A
Clinton, Illinois 61727

Mr. R. T. Hill
Licensing Services Manager
General Electric Company
175 Curtner Avenue, M/C 481
San Jose, California 95125

Regional Administrator, Region III
801 Warrenville Road
Lisle, Illinois 60532-4351

Chairman of DeWitt County
c/o County Clerk's Office
DeWitt County Courthouse
Clinton, Illinois 61727

Mr. Robert Neumann
Office of Public Counsel
State of Illinois Center
100 W. Randolph, Suite 11-300
Chicago, Illinois 60601

Mr. J. W. Blattner
Project Manager
Sargent & Lundy Engineers
55 East Monroe Street
Chicago, Illinois 60603