



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

April 18, 1983

Mr. J.M. Allan  
Acting Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSEE EVENT REPORT 83-046/03L-0  
ER 100450 FILE 841-23  
PLA 1629

---

Dear Mr. Allan:

Attached please find a copy of Licensee Event Report No. 83-046/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that during the performance of a monthly surveillance test on the "D" Diesel Generator, a fuel oil leak developed at the 1L cylinder and the diesel was shutdown and declared inoperable.

H.W. Keiser  
Superintendent of Plant-Susquehanna

JTT/pjg

cc: Director of Nuclear Reactor Regulation  
Attention: Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

G.G. Rhoads  
Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 52  
Shickshinny, PA 18655

8304280241 830418  
PDR ADDCK 05000387  
S PDR

IE22