

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | s | c | v | c | s | l | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 0 | 0 | 0 | 4 | 5

CON'T
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 9 | 5 | 7 | 0 | 4 | 0 | 6 | 8 | 3 | 8 | 0 | 4 | 2 | 0 | 8 | 3 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 | On April 6, 1983, with the Plant in Mode 5, a potential substantial safety hazard
03 | concerning certain critical dimensions of the undervoltage (UV) trip device on
04 | Westinghouse Mode DS-416 Reactor Trip Breakers was identified. An out-of-tolerance
05 | measurement was found between the moving core and rolling bracket in addition to a
06 | missing lock ring on the shaft pin of the UV trip device of Reactor Trip Breaker
07 | RTA. The potential existed for either intermittent operation or total failure of
08 | the device.

09 | I | A | 11 | B | 12 | B | 13 | C | K | T | B | R | K | 14 | A | 15 | Z | 16

17 | LER/RO REPORT NUMBER | 8 | 3 | 21 | - | 22 | 0 | 2 | 8 | 23 | / | 24 | 0 | 1 | 25 | T | 26 | - | 27 | 0

18 | ACTION TAKEN | Z | 19 | C | 20 | Z | 21 | Z | 22 | 0 | 0 | 0 | 0 | 23 | Y | 24 | N | 25 | N | 26 | W | 27 | I | 28 | 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 | The cause is attributed to manufacturing variations of the UV trip devices.
11 | The licensee is presently in an outage and expects to replace the UV trip
12 | devices on all Reactor Trip Breakers upon receipt of material from the
13 | manufacturer. The control room operators have been directed to actuate the
14 | the manual reactor trip when a demand for an automatic trip is observed.

15 | FACILITY STATUS | D | 28 | 0 | 0 | 0 | 29 | N/A | 30 | C | 31 | Westinghouse Notification | 32

16 | ACTIVITY CONTENT RELEASED OF RELEASE | Z | 33 | Z | 34 | N/A | 35 | N/A | 36

17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | Z | 38 | N/A | 39

18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | N/A | 41

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | N/A | 43

20 | PUBLICITY ISSUED DESCRIPTION | N | 44 | N/A | 45

8304280289 830420
PDR ADOCK 05000395
S PDR

NRC USE ONLY

NAME OF PREPARER C. J. McKinney
C. J. McKinney

PHONE: (803) 345-5209