Rys gua

Date: October 3, 1980

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE-PNO-I-80- 143

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by IE staff on this date.

Facility: Boston Edison Company

Pilgrim Unit 1 (DN 50-293) Plymouth, Massachusetts

Subject: PLANT SHUTDOWN EXTENDED

The plant remains in cold shutdown following the Reactor trip on October 1, 1980. Continuing analysis, initiated by Inspection and Enforcement Bulletin 79-14, identified the need to reinforce a Low Pressure Coolant Injection pipe hanger to insure its operability. The plant is expected to remain shutdown for this modification until October 8, 1980.

Media interest is possible. Neither the licensee or NRC plan to make a press release. The Commonwealth of Massachusetts has been informed. (0.0) 10/3

NRC, Region 1 (Philadelphia) received notification of this event by telephone from the Nuclear Operations Manager (Pilgrim Station) at 10:00 A.M. on October 3, 1980.

T. Martin Contact: Section Chief 488-1255

Branch Chief 488-1240

<u>DISTRIBUTION</u>: (Facsmile Transmission Times Noted)

H ST BLDG MARYLAND NATIONAL IE: XOOS Chairman Ahearne BANK BUILDING NRC/TMI Program W. J. Dircks, EDO Office Commissioner Gilinsky C. Michelson, AEOD Commissioner Bradford J. J. Fouchard, PA Region II Commissioner Hendrie N. M. Haller, MPA Region III Region IV ACRS R. G. Ryan, OSP S. J. Chilk, SECY H. K. Shapar, ELD Region V C. C. Kammerer, CA (For Distribution) WILLSTE BLDG RI Resident Sites J. G. Davis, NMSS PHILLIPS BLDG R. Budnitz, RES H. R. Denton, NRR LANDOW BLDG (Fax by HQ) R. H. Vollmer, NRR (MAIL) R. J. Mattson, NRR (6 MIN/PAGE) R. Minogue, SD D. F. Ross, NRR J. J. Cummings, OIA IE: XOOS D. Eisenhut, NRR Document Mgt. Br.

Region I Form 83 (Rev. June 1980)

S. H. Hanauer, NRR

PRELIMINARY NOTIFICATION 8304280293 831003 PDR I&E PNO-I-80-143 PDR

1E34