

**GEORGIA POWER COMPANY
INSERVICE TEST PROGRAM**

(ISI-P-008)

FOR

**VOGTLE ELECTRIC GENERATING PLANT
UNIT 1**

PREPARED BY
SOUTHERN NUCLEAR OPERATING COMPANY
INSPECTION AND TESTING SERVICES GROUP

REV	DATE	DESCRIPTION	SNC				GPC	
			PREP'D BY (ITS)	REV'D BY (ITS)	APPV. BY (ITS)	APPV. VOGTLE PROJECT NMS	APPV MGR. TECH SUPP	APPV GEN. MGR.
0	6/30/86	ISSUED FOR PST/IST INSPECTION						
1	10/21/88	REVISED PER NRC COMMENTS PRESSURE TESTS						
2	5/1/87	GENERAL UPDATE COMMITMENTS						
3	11/9/87	REVISED RHR TESTING RR-52, 53, 54						
4	9/7/88	INCORPORATE PCRS 88-005, 88-006, AND 88-007						
5	2/5/90	REFER TO REVISION 5 SUMMARY OF CHANGES						
6	2/28/91	REFER TO REVISION 6 SUMMARY OF CHANGES						
7	3/22/93	REFER TO REVISION 7 SUMMARY OF CHANGES						
8	3/30/94	INCORPORATE PCRS 93-008, 93-009, 93-013, 93-023, AND 93-025	<i>DLG</i>	<i>DMS</i>	<i>MB</i>	<i>alpr</i>	<i>ZWA</i>	<i>AB</i>

VOGTLE ELECTRIC GENERATING PLANT - UNIT 1
INSERVICE TEST (IST) PROGRAM

ISI-P-008

Revision 8 Summary of Changes

List of Effective Pages	Revised to indicate the current revision number of each page in the program document. See below for pages affected.
Drawings ISI-D-221 & ISI-D-222	Revised per PCR 93-008. (CVCS Section)
Figures 3f-1 and 3f2.	Revised per PCR 93-009. (CVCS Section)
Page 4-22	Revised Valve Test List to indicate a change in test frequency for valve HV8804B from quarterly to a cold shutdown frequency per PCR 93-023.
Page 4-23	The Valve Test List was revised to show RHR check valves 1-1205-U6-001 and 002 to be partially stroke exercised quarterly per PCR 93-013.
Page 6-35	Cold Shutdown Justification CS-35 withdrawn per PCR's 93-013 and 93-025.
Page 6-36	Cold Shutdown Justification CS-36 rewritten per PCR 93-013.
Page 6-41	Added Cold Shutdown Justification CS-41 to justify testing valve HV8804B at cold shutdown frequency per PCR 93-023.

VEGP-1 ISI-P-008

List of Effective Pages

Distribution List, Rev. 8

Table of Contents, Rev. 4

Introduction:

Page 1-1, Rev. 0

Page 1-2, Rev. 5

Page 1-3, Rev. 6

Pumps:

Page 2-1, Rev. 4

Page 2-2, Rev. 0

Page 2-3, Rev. 1

Page 2-4, Rev. 2

Page 2-5, Rev. 2

Page 2-6, Rev. 0

Page 2-7, Rev. 0

Page 2-8, Rev. 2

Page 2-9, Rev. 5

Page 2-10, Rev. 2

Page 2-11, Rev. 0

NSCW:

Table 3a-1, Rev. 4

Table 3a-2, Rev. 4

Table 3a-3, Rev. 5

Table 3a-4, Rev. 5

Table 3a-5, Rev. 5

Table 3a-6, Rev. 5

Table 3a-7, Rev. 5

Table 3a-8, Rev. 5

Table 3a-9, Rev. 5

Table 3a-10, Rev. 5

Drawings - ISI-D-201, Rev. 1

ISI-D-202, Rev. 1

ISI-D-203, Rev. 1

ISI-D-204, Rev. 1

ISI-D-205, Rev. 1

ISI-D-206, Rev. 1

ISI-D-207, Rev. 2

ISI-D-208, Rev. 2

Figures - 3a-1, Rev. 0

3a-2, Rev. 0

3a-3, Rev. 0

3a-4, Rev. 0

3a-5, Rev. 0

3a-6, Rev. 0

3a-7, Rev. 0

3a-8, Rev. 0

CCW:

Page 3b-1, Rev. 4
Table 3b-1, Rev. 4
Table 3b-2, Rev. 5
Table 3b-3, Rev. 5
Table 3b-4, Rev. 5
Table 3b-5, Rev. 5
Table 3b-6, Rev. 5
Table 3b-7, Rev. 5
Drawings - ISI-D-209, Rev. 1
 ISI-D-210, Rev. 1
 ISI-D-211, Rev. 1
 ISI-D-212, Rev. 1
 ISI-D-213, Rev. 1
 ISI-D-214, Rev. 1
Figures - 3b-1, Rev. 0
 3b-2, Rev. 0
 3b-3, Rev. 0
 3b-4, Rev. 0
 3b-5, Rev. 0
 3b-6, Rev. 0

SI:

Page 3c-1, Rev. 4
Table 3c-1, Rev. 7
Table 3c-2, Rev. 5
Table 3c-3, Rev. 5
Drawings - ISI-D-215, Rev. 2
 - ISI-D-216, Rev. 2
Figures - 3c-1, Rev. 0
 - 3c-2, Rev. 0

RHR:

Page 3d-1, Rev. 4
Table 3d-1, Rev. 5
Table 3d-2, Rev. 5
Table 3d-3, Rev. 5
Drawings - ISI-D-217, Rev. 5
 ISI-D-218, Rev. 5
Figures - 3d-1, Rev. 0
 3d-2, Rev. 0

CS:

Page 3e-1, Rev. 4
Table 3e-1, Rev. 4
Table 3e-2, Rev. 5
Table 3e-3, Rev. 5
Drawings - ISI-D-219, Rev. 2
 ISI-D-220, Rev. 2
Figures - 3e-1, Rev. 0
 3e-2, Rev. 0

CVCS

Page 3f-1, Rev. 4
Table 3f-1, Rev. 4
Table 3f-2, Rev. 5
Table 3f-3, Rev. 5
Table 3f-4, Rev. 4
Table 3f-5, Rev. 5
Table 3f-6, Rev. 5

CVCS: (continued)

Drawings - ISI-D-221, Rev. 3
 ISI-D-222, Rev. 3
 ISI-D-228, Rev. 2
 ISI-D-229, Rev. 2
Figures - 3f-1, Rev. 1
 3f-2, Rev. 1
 3f-3, Rev. 0
 3f-4, Rev. 0

AFW:

Page 3g-1, Rev. 4
Page 3g-2, Rev. 4
Table 3g-1, Rev. 4
Table 3g-2, Rev. 4
Table 3g-3, Rev. 5
Table 3g-4, Rev. 5
Table 3g-5, Rev. 5
Drawings - ISI-D-223, Rev. 1
 ISI-D-224, Rev. 1
 ISI-D-225, Rev. 1
Figures - 3g-1, Rev. 0
 3g-2, Rev. 0
 3g-3, Rev. 0

ESF:

Page 3h-1, Rev. 4
Table 3h-1, Rev. 4
 3h-2, Rev. 5
 3h-3, Rev. 5
Drawings - ISI-D-226, Rev. 2
 ISI-D-227, Rev. 2
Figures - 3h-1, Rev. 0
 3h-2, Rev. 0

Pump Relief Requests:

Page 3-1, Rev. 5
Page 3-2, Rev. 5
Page 3-3, Rev. 2
Page 3-4, Rev. 5
Page 3-5, Rev. 6

Valves:

Page 4-1, Rev. 0
Page 4-2, Rev. 0
Page 4-3, Rev. 0
Page 4-4, Rev. 1
Page 4-5, Rev. 2
Page 4-6, Rev. 2
Page 4-7, Rev. 2
Page 4-8, Rev. 1
Page 4-9, Rev. 0
Page 4-10, Rev. 0
Page 4-11, Rev. 2
Page 4-12, Rev. 2
Page 4-13, Rev. 2
Page 4-14, Rev. 1
Page 4-15, Rev. 0
Page 4-16, Rev. 1

Valves: (continued)

Page 4-17, Rev. 1
Page 4-18, Rev. 1
Page 4-19, Rev. 1
Page 4-20, Rev. 1
Page 4-21, Rev. 1
Page 4-22, Rev. 8
Page 4-23, Rev. 8
Page 4-24, Rev. 2
Page 4-25, Rev. 6
Page 4-26, Rev. 4
Page 4-27, Rev. 2
Page 4-28, Rev. 7
Page 4-29, Rev. 5
Page 4-30, Rev. 7
Page 4-31, Rev. 1
Page 4-32, Rev. 1
Page 4-33, Rev. 2
Page 4-34, Rev. 2
Page 4-35, Rev. 6
Page 4-36, Rev. 6
Page 4-37, Rev. 1
Page 4-38, Rev. 1
Page 4-39, Rev. 7
Page 4-40, Rev. 0
Page 4-41, Rev. 2
Page 4-42, Rev. 1
Page 4-43, Rev. 2
Page 4-44, Rev. 2
Page 4-45, Rev. 6
Page 4-45a, Rev. 6
Page 4-46, Rev. 1
Page 4-47, Rev. 0
Page 4-48, Rev. 1
Page 4-49, Rev. 2
Page 4-50, Rev. 2
Page 4-51, Rev. 1
Page 4-52, Rev. 1
Page 4-53, Rev. 0
Page 4-54, Rev. 6
Page 4-55, Rev. 1
Page 4-56, Rev. 1
Page 4-57, Rev. 2
Page 4-58, Rev. 5
Page 4-59, Rev. 1
Page 4-60, Rev. 2
Page 4-61, Rev. 2
Page 4-62, Rev. 4

Valve Relief Requests:

Page 5-1, Rev. 2
Page 5-2, Rev. 0
Page 5-3, Rev. 2
Page 5-4, Rev. 1
Page 5-5, Rev. 5

Valve Relief Requests: (continued)

Page 5-6, Rev. 5
Page 5-7, Rev. 1
Page 5-8, Rev. 0
Page 5-9, Rev. 0
Page 5-10, Rev. 0
Page 5-11, Rev. 1
Page 5-12, Rev. 1
Page 5-13, Rev. 1
Page 5-14, Rev. 7
Page 5-15, Rev. 1
Page 5-16, Rev. 2
Page 5-17, Rev. 1
Page 5-18, Rev. 1
Page 5-19, Rev. 1
Page 5-20, Rev. 1
Page 5-21, Rev. 0
Page 5-22, Rev. 1
Page 5-23, Rev. 7
Page 5-24, Rev. 1
Page 5-25, Rev. 1
Page 5-26, Rev. 2
Page 5-27, Rev. 4
Page 5-28, Rev. 7

Valve Cold Shutdown Justifications:


Page 6-1, Rev. 0
Page 6-2, Rev. 1
Page 6-3, Rev. 1
Page 6-4, Rev. 1
Page 6-5, Rev. 1
Page 6-6, Rev. 1
Page 6-7, Rev. 5
Page 6-8, Rev. 1
Page 6-9, Rev. 1
Page 6-10, Rev. 0
Page 6-11, Rev. 1
Page 6-12, Rev. 0
Page 6-13, Rev. 0
Page 6-14, Rev. 1
Page 6-15, Rev. 1
Page 6-16, Rev. 0
Page 6-17, Rev. 6
Page 6-18, Rev. 1
Page 6-19, Rev. 1
Page 6-20, Rev. 0
Page 6-21, Rev. 0
Page 6-22, Rev. 0
Page 6-23, Rev. 0
Page 6-24, Rev. 1
Page 6-25, Rev. 0
Page 6-26, Rev. 1
Page 6-27, Rev. 1
Page 6-28, Rev. 1
Page 6-29, Rev. 1
Page 6-30, Rev. 1

Valve Cold Shutdown Justifications: (continued)

Page 6-31, Rev. 7
Page 6-32, Rev. 1
Page 6-33, Rev. 2
Page 6-34, Rev. 5
Page 6-35, Rev. 8
Page 6-36, Rev. 8
Page 6-37, Rev. 2
Page 6-38, Rev. 2
Page 6-39, Rev. 4
Page 6-40, Rev. 6
Page 6-41, Rev. 8

DISTRIBUTION LIST

<u>HOLDER</u>	<u>MANUAL NUMBER</u>
L. Rowe	1
J. G. Aufdenkampe	2
T. M. Hickox	6
Document Control Supv.	18
L. A. Ward	20
Operations Manager	22
C. L. Coursey	23
L. K. Mathews	24
Deleted	28
Work Planning Supv.	29
Performance Supervisor	30



NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&I.D. FOR DETAILS


REV.	DATE	BY	CHK'D	DESCRIPTION	APPR. 1	APPR. 2	APPR. 3	APPR. 4	APPR. 5	REMARKS
0	5-24-89	WJS	WJS	ISSUED FOR PST						
1	7-24-89	WJS	WJS	UPDATED TO 1X4DB116-2 REV.10						
2	10-18-88	WJS	WJS	ADDED PI 8891, 8892						
3	12-19-91	WJS	DRG	ADDED FO 1011B AND FO 10122.						

Southern Company Services, Inc. FOR Georgia Power Company

VOGTLÉ ELECTRIC GENERATING PLANT UNIT 1

PUMP INSERVICE TESTING LOOP FOR CENTRIFUGAL CHARGING PUMP 1-1208-P6-002

DESIGNED FT	DRAWN DRC		
TYPED	CHECKED WJS		
SCALE NONE	CONTINUED ON SHEET		
PROJ. I.D.	DRAWING NUMBER	SHEET	REV.
N/A	N/A	JSJ-D-221	1 OF 1 3



NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&I.D. FOR DETAILS

REV.	DATE	BY	CHK'D	DESCRIPTION	APPR. 1	APPR. 2	APPR. 3	APPR. 4	APPR. 5	REMARKS
0	5-20-84	WS	WS	ISSUED FOR PST						
1	7-24-86	WS	WS	UPDATED TO IS4DB116-2 REV. 10						
2	6-18-88	WS	WS	ADDED PI 8891, 8892						
3	12-16-93	WS	WS	ADDED FO-1011B AND FO-1012Z						

Southern Company Services, Inc. FOR Georgia Power Company

VOGTLE ELECTRIC GENERATING PLANT UNIT 1


PUMP INSERVICE TESTING LOOP FOR CENTRIFUGAL CHARGING PUMP 1-1208-P6-003

DESIGNED	ET	DRAWN	DRC
TYPED		CHECKED	WS
SCALE	NONE	CONTROLLED ON SHEET	
PROJ. I.D.	N/A	DRAWING NUMBER	ISI-D-222
SHEET	1 OF 1		3

CONTRACTOR VESTINGHOUSE
 CUSTOMER VESTINGHOUSE
 ITEM NO. GPE-01/2 P.O. MM-73893-D
 IMPELLER PATTERN M-8863 M-8864
 MAXIMUM DIAMETER 8.250 8.250
 RATED DIAMETER 8.250 8.250
 MINIMUM DIAMETER 7.250 7.250

ORIGINAL

TEST PERFORMANCE CURVE NO. 52233/4
 SIZE 2.5" RL TYPE IJ STAGES 11
 R.P.M. 4820 DATE 12/24/86
 PUMP NUMBER 52233/4
 PERFORMANCE ALSO APPLIES TO PUMP
 NUMBER NE-91063




DOC. NO. 262-NH-43258SP2

DRESSER PUMP DIVISION
 Dresser
 Huntington Park, CALIFORNIA

Contractor _____
 Customer Wastingshausen
 Item No. CSAPCH
 P. O. No. MA 49487-D
 Pump Serial Number 38033-SP2
 Curve Number 38033-SP2
 Rel. Job B-50033; s/n 52233/4

Size 2.5 BL Type II Stages 11 R.P.M. 4817
 Date 6/19/52 Impeller Eye Area (sq. in.) 12.37
 Impeller Pattern Radial
 Suction M-727A M-6534
 Maximum Diameter (in.) 8.250
 Rated Diameter (in.) 8.1875
 Minimum Diameter (in.) 7.250

Test Engr. [Signature]
 Witness _____



U. S. Gallons per Minute @ S. G. 1.0200 and 300°F

VEGP Unit No. 1
Valve Test List
System:

Residual Heat Removal - System No. 1205

008 REV 8

Sheet 1 of 2

Valve Number	Class		P&ID (Coord.)	Valve			Act. Type	Position			Act. or Pass.	Relief					Req. or C. S. Just.	Description and Notes
	ISI	Proj.		Cat	Size (in.)	Type		Norm	Fail	Safety		PI	ET	SI	FSV	LI		
HV 8716A	2	212	1X40B122 (F-7)	B	8.00	GA	MO	O	AI	O/C	A	Y	Q	Q				RHR Train A Hot Leg Isolation
HV 8716B	2	212	1X40B122 (D-7)	B	8.00	GA	MO	O	AI	O/C	A	Y	Q	Q				RHR Train B Hot Leg Isolation
HV 8804A	2	212	1X40B122 (F-8)	B	8.00	GA	MO	C	AI	O/C	A	Y	CS	CS			CS-39 RR-2	RHR Heat Exchanger (HX) Train A to CVCS Charge Pump Suction
HV 8804B	2	212	1X40B122 (B-8)	B	8.00	GA	MO	C	AI	O/C	A	Y	CS	CS			CS-41 RR-2	RHR HX Train B to Safety Injection Pump Suction
HV 8811A	2	212	1X40B122 (B-3)	B	14.00	GA	MO	C	AI	O/C	A	Y	Q	Q				Containment Sump Isolation
HV 8811B	2	212	1X40B122 (B-3)	B	14.00	GA	MO	C	AI	O/C	A	Y	Q	Q				Containment Sump Isolation
HV 8812A	2	212	1X40B122 (F-4)	B	12.00	GA	MO	O	AI	O/C	A	Y	Q	Q				RHR Pump P6-001 Inlet From RWST
HV 8812B	2	212	1X40B122 (C-4)	B	12.00	GA	MO	O	AI	O/C	A	Y	Q	Q				RHR Pump P6-002 Inlet From RWST
PSV 8708A	2	212	1X40B122 (H-3)	C	3.00	SR	S	C	N/A	O/C	A		T					RHR Pump P6-001 Inlet
PSV 8708B	2	212	1X40B122 (E-3)	C	3.00	SR	S	C	N/A	O/C	A		T					RHR Pump P6-002 Inlet

VEGP Unit No. 1
Valve Test List
System:

Residual Heat Removal - System No. 1205

008 REV 8

Sheet 2 of 2

Valve Number	Class		P&ID (Coord.)	Valve		Act. Type	Position			Act. or Pass.	Relief					Req. or C. S. Just.	Description and Notes	
	ISI	Proj.		Size (in.)	Type		Norm	Fail	Safety		PI	ET	ST	FSV	LI			Tests and Freq.
U4 122	2	212	1X4DB122 (C-3)	C	14.00	CK	S	C	N/A	O/C	A		Q					RHR Sump Suction (Note 3)
U4 123	2	212	1X4DB122 (B-3)	C	14.00	CK	S	C	N/A	O/C	A		Q					RHR Sump Suction (Note 3)
U6 001	2	212	1X4DB122 (F-4)	C	12.00	CK	S	C	N/A	O/C	A		PQCS				CS-36 RR-2	RWST to RHR Pump Suction
U6 002	2	212	1X4DB122 (C-4)	C	12.00	CK	S	C	N/A	O/C	A		PQCS				CS-36 RR-2	RWST to RHR Pump Suction
U6 009	2	212	1X4DB122 (G-5)	C	8.00	CK	S	C	N/A	O	A		PQCS				CS-37 RR-2	RHR Pump P6-001 Discharge Check
U6 010	2	212	1X4DB122 (D-5)	C	8.00	CK	S	C	N/A	O	A		PQCS				CS-37 RR-2	RHR Pump P6-002 Discharge Check
FV 0610	2	212	1X4DB122 (H-5)	B	3.00	GA	MO	O	AI	O/C	A	Y	Q	Q				RHR Pump P6-001 Miniflow
FV 0611	2	212	1X4DB122 (E-5)	B	3.00	GA	MO	O	AI	O/C	A	Y	Q	Q				RHR Pump P6-002 Miniflow

COLD SHUTDOWN JUSTIFICATION

CS-35

SYSTEM: Residual Heat Removal - System No. 1205
VALVE(S): 1205-HV-8716A, 1205-HV-8716B
CATEGORY: B
CLASS: 2
FUNCTION: These valves are used as necessary to align the residual heat removal system.

QUARTERLY TEST
REQUIREMENT: Exercise and Time.

COLD SHUTDOWN
TEST JUSTIFICATION: The Westinghouse plant ECCS analysis assumes low-head safety injection into all four cold legs. The analysis also assumes that one residual heat removal pump may fail to operate during an accident. If one pump fails, the other pump is required to inject into all four cold legs. This requires that valves HV-8716A and HV-8716B be open to support injection into all four cold legs. Closing these valves for surveillance testing during plant operation will place the plant in an unanalyzed condition outside its established design basis assuming failure of one pump.

QUARTERLY PARTIAL
STROKE TESTING: None

COLD SHUTDOWN
TESTING: Exercise and Time.

Testing of these valves is now performed on a quarterly frequency. Therefore, GPC has withdrawn this Cold Shutdown Justification.

COLD SHUTDOWN JUSTIFICATION

CS-36

SYSTEM: Residual Heat Removal - System No. 1205

VALVE(S): 1205-U6-001, 1205-U6-002

CATEGORY: C

CLASS: 2

FUNCTION: These check valves open to allow flow from the refueling water storage tank to the residual heat removal pumps. These valves close to prevent reverse flow to the refueling water storage tank.

QUARTERLY TEST

REQUIREMENT: Verify forward flow operability and reverse flow closure.

COLD SHUTDOWN

TEST JUSTIFICATION: During normal operation, the RHR pumps cannot overcome RCS operating pressure. Forward flow operability of these normally closed check valves during normal operation can be verified only by aligning the RHR system to circulate water to and from the RWST. However, this alignment provides only partial flow through the check valves. Reverse flow closure will be verified quarterly.

QUARTERLY PARTIAL STROKE TESTING:

These valves will be partial stroke exercised quarterly.

COLD SHUTDOWN TESTING:

These valves will be tested during cold shutdown. The maximum required flowrate through each valve will be verified.

GENERIC LETTER 89-04 REVIEW:

This justification complies with the full-stroke testing requirements for check valves as described in position 1 of Generic Letter 89-04.

COLD SHUTDOWN JUSTIFICATION

CS-41

SYSTEM: Residual Heat Removal - System No. 1205
VALVE: 1205-HV-8804B
CATEGORY: B
CLASS: 2
FUNCTION: This normally closed valve opens to provide a flow path to the suction of the SI pumps from the RHR system. While closed it directs flow from the RHR pumps to the RCS for low pressure injection and shutdown cooling.

QUARTERLY TEST
REQUIREMENT: Exercise and Time (IWV-3412 and IWV-3413)

COLD SHUTDOWN
TEST JUSTIFICATION: Testing this valve during normal operation requires defeating the associated ECCS interlocks. To defeat the interlock, a jumper must be installed across energized terminals. Installation of electrical jumpers across energized terminals during normal operation is undesirable because of the possibility of shorting the terminals and causing undesirable effects.

In addition, during the time the valve is opened and coincident with a small break LOCA the potential to overpressurize the SI suction piping exists. With the valve open and coincident with a large break LOCA and one or both RHR pumps running the potential exists to runout either or both of the RHR pumps. Either one of these cases could cause component damage and place the plant in an undesirable condition.

QUARTERLY PARTIAL
STROKE TESTING: None for same reasons provided above.

COLD SHUTDOWN
TESTING: Exercise and Time

ENCLOSURE 2
(REVISION 5 TO VEGP-2 IST PROGRAM DOCUMENT ISI-P-016)

TO

GEORGIA POWER COMPANY
LETTER LCV-0389,
"REVISIONS TO INSERVICE INSPECTION PROGRAMS"

VOGTLE ELECTRIC GENERATING PLANT
NRC DOCKET NOS. 50-424, 50-425