



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

November 3, 1982

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-037/01P-0
ER 100450 FILE 841-23
PLA- 1378

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

This transmission confirms the telephone report of November 1, 1982, by F.T. Eisenhuth to E. McCabe of your staff, regarding exceeding the number of allowable cycles the Reactor Recirculation pump discharge valves are permitted, per the SER Supplement 3. A license amendment request will be submitted to change the number of allowable cycles to 25, based on manufacturer's recommendations. Plant operation will continue, based on anticipated receipt of the amendment.

This condition is considered reportable in accordance with Operating License Item 2.G(a).

H.W. Keiser
Superintendent of Plant-Susquehanna

DGM/cw

cc: Richard C. DeYoung - Director, Office of Inspection & Enforcement
Norman H. Haller - Director, Office of Management and Program Control
U.S.N.R.C. - Resident Inspector, Susquehanna SES

8211180314 821103
PDR ADOCK 05000387
S PDR

TEL