

NOV 08 1982

Docket No. 50-443

Public Service Company of New Hampshire
ATTN: Mr. W. C. Tallman
Chairman and Chief Executive Officer
1000 Elm Street
Manchester, New Hampshire 03105

Gentlemen:

Subject: Inspection No. 50-443/82-06

This refers to your letter dated September 27, 1982, in response to our letter dated August 24, 1982.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a future inspection of your licensed program.


Further, based on a telephone conversation between Messrs. R. Gallo and J. Durr of this office and Mr. A. Shepherd of your staff on October 15, 1982, we understand that additional actions to prevent further violations will be completed.

Specifically, regarding Item E of our letter we understand that Field Procedure, FGCP-2, will be revised to include distribution of weekly updates to the ECA change log to controlled drawing stations. In addition, the monthly ECA change log will be marked to indicate that weekly updates to the ECA change log are available at controlled drawing stations.

Regarding Item G, we understand that Pullman-Higgins auditors have received additional training concerning reaudit requirements of deficient areas.

Your cooperation with us is appreciated.

Sincerely,


Thomas T. Martin, Director,
Division of Engineering and
Technical Programs

cc w/encl:
John DeVincentis, Project Manager
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of New Hampshire

8211180321 821108
PDR ADOCK 05000443
G PDR

OFFICIAL RECORD COPY


1001

NOV 08 1982

bcc w/enci:
Region I Docket Room (with concurrences)
R. M. Gallo, Chief, RPS

RI:DPRP
Durr:as
10/20/82
11/5/82


RI:DPRP
Gallo
10/9/82


RI:DPRP
Ebner
11/5/82

OFFICIAL RECORD COPY