

JUN 10 1994

Docket No. 50-213

Mr. John F. Opeka
Executive Vice President - Nuclear
Connecticut Yankee Atomic Power Company
P.O. Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: Inspection No. 50-213/94-13

This letter refers to the safety inspection conducted by Ms. Laurie Peluso of this office on May 23 - 27, 1994, of activities authorized by NRC License No. DPR-61 at the Haddam Neck Station, East Haddam, Connecticut, and to the discussions of our findings held by Ms. Peluso with Mr. Nevelos and other members of your staff at the conclusion of the inspection.

Areas examined during this inspection, involving your radioactive liquid and gaseous effluent control programs, are important to public health and safety and are described in the NRC Region I Inspection Report that is enclosed with this letter. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Within the scope of this inspection, we noted that implementation of the radioactive liquid and gaseous effluent control programs continued to be very good. Your calibration technique for the radiological calibrations of the effluent radiation monitoring systems was noteworthy. Also noteworthy was your initiative to upgrade certain effluent/process radiation monitoring systems. No safety concerns or violations of regulatory requirements were identified.

No response to this letter is required. Your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed By:
James H. Joyner

James H. Joyner, Chief
Facilities Radiological Safety
and Safeguards Branch
Division of Radiation Safety
and Safeguards

200017

OFFICIAL RECORD COPY

IE-06

9406210026 940610
PDR ADOCK 05000213
G PDR

Connecticut Yankee Atomic Power Company 2

Enclosure: NRC Region I Inspection No. 50-213/94-13

cc w/encl:

S. E. Scace, Vice President, Nuclear Operations Services

J. P. Stetz, Vice President, Haddam Neck Station

D. B. Miller, Senior Vice President, Millstone Station

J. Solymossy, Director, Nuclear Quality and Assessment Services

J. J. LaPlatney, Director, Nuclear Unit

R. M. Kacich, Director, Nuclear Planning, Licensing and Budgeting

Gerald Garfield, Esquire

Nicholas Reynolds, Esquire

K. Abraham, PAO (2)

Public Document Room (PDR)

Local Public Document Room (LPDR)

Nuclear Safety Information Center (NSIC)

NRC Resident Inspector

State of Connecticut SLO

Connecticut Yankee Atomic Power Company 3

bcc w/encl:
Region I Docket Room (with concurrences)

bcc w/encl (VIA E-MAIL):
J. Stolz, NRR/PD I-4
W. Dean, OEDO
A. Wang, PM, NRR
M. Shannon, NRR/ILPB
C. Beardslee, DRS, SALP Coordinator

RI:DRSS
PELUSO



06/08/94

RI:DRSS



06/8/94

RI:DRSS
JOYNER



06/10/94