

LICENSEE EVENT REPORT

CONTROL BLOCK / / / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

/0/1/ /V/A/N/A/S/2/ (2) /0/0/-/0/0/0/0/0/-/0/0/ (3) /4/1/1/1/1/ (4) / / / (5)

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT
/0/1/ REPORT SOURCE /L/ (6) /0/5/0/0/0/3/3/9/ (7) /0/3/3/1/8/3/ (8) /0/4/2/0/8/3/ (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

/0/2/ / On March 31, 1983 with the Unit in Mode 1, it was discovered that the Steam Gen-
/0/3/ / erator "B" Water Level, Channel I, High-High Turbine Trip/Feedwater Isolation /
/0/4/ / setpoint was greater than the allowable value of 76 percent required by T.S. /
/0/5/ / 3.3.2.1 (5.a.). Since the affected channel was placed in the trip condition and /
/0/6/ / the two redundant water level channels for "B" steam generator were operable, /
/0/7/ / the health and safety of the public were not affected. This event is reportable /
/0/8/ / pursuant to T.S. 6.9.1.9.a. /

SYSTEM CAUSE CAUSE COMP. VALVE
CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE

/0/9/ /I/B/ (11) /E/ (12) /E/ (13) /I/N/S/T/R/U/ /Y/ /Z/
LER/RO EVENT YEAR SEQUENTIAL OCCURRENCE REPORT REVISION
(17) REPORT NUMBER /8/3/ /- / 0/2/5/ / / /0/3/ /L/ /- /0/

ACTION FUTURE EFFECT SHUTDOWN ATTACHMENT NPRD-4 PRIME COMP. COMPONENT
TAKEN ACTION ON PLANT METHOD HOURS SUBMITTED FORM SUB. SUPPLIER MANUFACTURER
/A/ (18) /Z/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /N/ (23) /N/ (24) /N/ (25) /W/1/2/0/
(26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

/1/0/ / The cause of this event was a malfunctioning comparator card. The High-High /
/1/1/ / level comparator card was replaced, calibrated to the correct setpoint and the /
/1/2/ / channel was returned to service. This event has no generic implications. /
/1/3/ / / /
/1/4/ / / /

FACILITY STATUS %POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
/1/5/ /E/ (28) /1/0/0/ (29) / NA / (30) /B/ (31) / Surveillance Test /

ACTIVITY CONTENT AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
/1/6/ /Z/ (33) /Z/ (34) / NA / / NA /

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
/1/7/ /0/0/0/ (37) /Z/ (38) / NA /

PERSONNEL INJURIES NUMBER DESCRIPTION (41)
/1/8/ /0/0/0/ (40) / NA /

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43) 8305030283 830420
/1/9/ /Z/ (42) / NA / PDR ADOCK 05000339 S PDR

PUBLICITY ISSUED DESCRIPTION (45) NRC USE ONLY
/2/0/ /N/ (44) / NA / / / / / / / / / / / / /
NAME OF PREPARER E. WAYNE HARRELL PHONE (703) 894-5151