



**CENTERIOR
ENERGY**

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 440
(216) 259-3737

Mail Address:
PO BOX 97
PERRY, OHIO 44081

Robert A. Stratman
VICE PRESIDENT - NUCLEAR

June 10, 1994
PY-CEI/LCDU-0025L

Lake County Department of Utilities
c/o Gary Long, Mentor Waste Facility
P.O. Box 490
Painesville, Ohio 44077-0490

Dear Mr. Long,

Enclosed are the Quarterly Self-Monitoring Reports for the Perry Nuclear Power Plant sanitary waste system for the months of March, April and May. All required samples were collected and analyzed in accordance with the self-monitoring program.

If you have questions or require additional information, please contact Donna Tizzano at (216) 280-5514 if.

Sincerely,

RAS:DGT

Enclosure

cc: NRC Project Manager
NRC Resident Inspector Office
NRC Document Control Desk
NRC Region III

200043

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

9406210216 940531
PDR ADOCK 05000440
R PDR

JE23

INDUSTRIAL PRETREATMENT
QUARTERLY SELF-MONITORING RESULTS

Perry Nuclear Power Plant
10 Center Rd.
Perry, Ohio 44081

Permit No.: 1004911
Report Date: 3/22/94
Laboratory: Wadsworth/Alert

Date of Sample: 3/3 to 3/4/94
Sample Location: Sewage Pump Station

Time of sample: 0930
Name of Sampler: Greg Newman


Laboratory Address: 1401 Shuffel Dr.
North Canton OH 44720

Date of Analysis: 3/4 to 3/18/94
Flow: 33,000 gpd

Name of Analyst: Lois Ezzo

PARAMETER	SAMPLE TYPE	EPA METHOD	ANALYSIS DATE	ANALYSIS RESULT
COD	Composite	410.4	3/18	290 mg/L
BOD	Composite	405.1	3/4 to 3/9	260 mg/L
TSS	Composite	160.2	3/9 to 3/10	180 mg/L
Silver	Composite	200.7	3/10 to 3/17	None Detected
pH	Grab	150.1	3/4	8.8 s.u.
Oil/Grease Gravimetric	Grab	413.1	3/17 to 3/18	9 mg/L

I certify under penalty of law that I have personally examined and I am familiar with the information in this report and that, based on my inquiry of those persons immediately responsible for obtaining the information contained in this report, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.


Signature _____ Date 3/13/94 Title Vice President - Nuclear

INDUSTRIAL PRETREATMENT
QUARTERLY SELF-MONITORING RESULTS

Perry Nuclear Power Plant
10 Center Rd.
Perry, Ohio 44081

Permit No.: 1004911
Report Date: 4/18/94
Laboratory: Wadsworth/Alert

Date of Sample: 3/31 to 4/1/94
Sample Location: Sewage Pump Station

Time of sample: 0900
Name of Sampler: Greg Newman


Laboratory Address: 1401 Shuffel Dr.
North Canton OH 44720

Date of Analysis: 4/1 to 4/13/94
Flow: 33,000 gpd

Name of Analyst: D. Cuson

PARAMETER	SAMPLE TYPE	EPA METHOD	ANALYSIS DATE	ANALYSIS RESULT
COD	Composite	410.4	4/13	260 mg/L
BOD	Composite	405.1	4/2 to 4/7	130 mg/L
TSS	Composite	160.2	4/6 to 4/7	120 mg/L
Silver	Composite	200.7	4/7 to 4/11	None Detected
pH	Grab	150.1	4/1	8.8 s.u.
Oil/Grease Gravimetric	Grab	413.1	4/14	38.0 mg/L

I certify under penalty of law that I have personally examined and I am familiar with the information in this report and that, based on my inquiry of those persons immediately responsible for obtaining the information contained in this report, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.


Signature _____ Date 4/13/94 Title Vice President - Nuclear

INDUSTRIAL PRETREATMENT
QUARTERLY SELF-MONITORING RESULTS

Perry Nuclear Power Plant
10 Center Rd.
Perry, Ohio 44081

Permit No.: 1004911
Report Date: 5/27/94
Laboratory: Wadsworth/Alert

Date of Sample: 5/12 to 5/13
Sample Location: Sewage Pump Station

Time of sample: 0915
Name of Sampler: Greg Newman


Laboratory Address: 1401 Shuffel Dr.
North Canton OH 44720

Date of Analysis: 5/13 to 5/25/94
Flow: 33,000 gpd

Name of Analyst: K. Graves

PARAMETER	SAMPLE TYPE	EPA METHOD	ANALYSIS DATE	ANALYSIS RESULT
COD	Composite	410.4	5/17	1700 mg/L
BOD	Composite	405.1	5/13 to 5/18	490 mg/L
TSS	Composite	160.2	5/17 to 5/18	1000 mg/L
Silver	Composite	200.7	5/23 to 5/25	None Detected
pH	Grab	150.1	5/13	8.6 s.u.
Oil/Grease Gravimetric	Grab	413.1	5/18 to 5/19	24 mg/L

I certify under penalty of law that I have personally examined and I am familiar with the information in this report and that, based on my inquiry of those persons immediately responsible for obtaining the information contained in this report, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.


Signature _____ Date 5/23/94 Title Vice President - Nuclear