

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004

JOHN D. SIEBER
Senior Vice President and
Chief Nuclear Officer
Nuclear Power Division

(412) 393-5255
Fax (412) 643-8069

June 2, 1994

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555


Subject: Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPP-73
Proposed Operating License Change Request Nos. 211 and 77

Pursuant to 10 CFR 50.90, Duquesne Light Company requests an amendment to the above licenses in the form of changes to the technical specifications. The proposed changes will revise Specification 3.4.6.1 titled "Leakage Detection Instrumentation" and Specification 3.4.6.2 titled "Operational Leakage", and the associated Bases for each, to address reactor coolant system leakage detection in accordance with NUREG-1431, "Standard Technical Specifications, Westinghouse Plants." In addition, related changes resulting from the above have been made to revise various Index pages and Definition Section 1.0. A new specification with associated Bases for each Unit titled "Seal Injection Flow" has also been included.

The proposed technical specification changes for Unit No. 1 and Unit No. 2 are presented in Attachments A-1 and A-2, respectively. The safety analysis (including the no significant hazards evaluation) is presented in Attachment B. The typed replacement technical specification pages are presented in Attachments C-1 and C-2.

This change has been reviewed by the Onsite Safety Committee and Offsite Review Committee. The change was determined to be safe and does not involve a significant hazard consideration as defined in 10 CFR 50.92 based on the attached safety analysis.

Sincerely,


J. D. Sieber

cc: Mr. L. W. Rossbach, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. G. E. Edison, Project Manager
Mr. W. P. Dornsife, Director BPP/DER
Mr. R. J. Barkanic, BRP/DER

9406210264 940602
PDR ADOCK 05000334
P PDR

A001
114



