

# LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N Y I P S 2 2 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 1 4 5  
9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 58

0 1 REPORT SOURCE L 6 0 5 0 0 0 2 4 7 7 0 3 1 6 8 3 8 0 4 1 5 8 3 9  
60 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal operation the reactor cavity continuous sump level monitor indicated  
0 3 approximately 21 ft. (3 ft. above normal). No level alarms annunciated. A  
0 4 containment entry was made and the reactor cavity sump was found dry. The reactor  
0 5 cavity continuous level monitoring system was declared inoperable. However, the  
0 6 independent reactor cavity level alarm remained operable in accordance with Tech.  
0 7 Spec. 3.1.F.b(5). The health and safety of the public were unaffected.

0 9 SYSTEM CODE C J 11 CAUSE CODE E 12 CAUSE SUBCODE E 13 COMPONENT CODE I N S T R U 14  
COMP. SUBCODE T 15 VALVE SUBCODE X 16

17 LER/RO REPORT NUMBER 8 3 21 EVENT YEAR 8 3 22 SHUTDOWN METHOD Z 20 HOURS 0 0 0 0 22  
ACTION TAKEN Z 18 FUTURE ACTION E 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 ATTACHMENT SUBMITTED N 23  
NPRD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER B o r h 47

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The output from the reactor cavity level transmitter IT 3302 had drifted in the  
1 1 conservative direction. The transmitter was recalibrated within the time limit  
1 2 allowed by the Technical Specifications. Manufacturer's data; Barton Model 764.  
1 3 No previous similar LER's.

1 5 FACILITY STATUS E 28 % POWER 0 9 7 25 OTHER STATUS NA 30 METHOD OF DISCOVERY R 31 DISCOVERY DESCRIPTION Visual Inspection 32

1 6 ACTIVITY RELEASED Z 33 CONTENT Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE 38 DESCRIPTION NA 39

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

ISSUED N 11 DESCRIPTION NA 12 PUBLICITY S 13

8305030407 830415  
PDR ADDCK 05000247  
S PDR