NRC FORM 366 U.S. NUCLEAR REGULATORY COMMISSION (7.77) Update Report: LICENSEE EVENT REPORT Previous Report Date: 11-23-82 CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) 2 2 0 0 0 0 0 0 0 0 - 0 0 3 4 LICENSE NUMBER 25 26 0 1 CON'T REPORT L 6 0 5 0 - 0 3 2 4 7 1 0 2 4 8 2 8 0 4 2 2 8 D DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 0 1 SOURCE DOCKET NUMBER EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) Routine surveillance during plant startup operations revealed that SLCS piping heat 0 2 tracing on the lines between the system accumulators, 2-C41-A003A and B and common 0 3 discharge line was inoperable. Routine surveillance during plant operation on 10-25-83 0 4 revealed that SLCS piping heat tracing, on the common discharge line from the system 0 5 accumulators to each system squib valve, 2-C41-F004A and B, was inoperable. Neither 0 6 event affected the health and safety of the public. 0 7 Technical Specifications 4.1.5a.2, 6.9.1.9b 0 8 COMP SYSTEM CAUSE CAUSE VALVE CODE SUBCODE COMPONENT CODE SUBCODE RB E (12) A (13) E A T E P (14) Z (15) H Z (16) (11 18 OCCURRENCE REVISION SEQUENTIAL REPORT REPORT NO. CODE EVENT YEAR TYPE NO. LER/RO REPORT 2 6 0 3 8 L 1 1 NUMBER 30 32 COMPONENT MANUFACTURER ACTION EFFECT ON PLANT METHOD ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. FUTURE ACTION (22 HOURS SUPPLIER 0 0 N (23) Y (24) F Z 0 18 A Z (21 L (25) (26)18) CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) The subject heat tracing sections had electrically failed. Following each event, the 1 0 | involved section, Model No. FP-10, was replaced. Plant modifications are presently 1 1 | under development which will improve the reliability of the SLCS heat tracing on 1 2 each unit, with planned installation on Unit No. 1 during a future outage and on 1 3 Unit No. 2 during the next refueling outage. 1 4 80 METHOD OF FACILITY (30)DISCOVERY DESCRIPTION (32) % POWER OTHER STATUS C (28) Operator Surveillance 0 0 0 (29) NA A (31) 15 80 ACTIVITY CONTENT AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36) OF RELEASE RELEASED NA Z 33 Z 34 NA 6 45 44 80 PERSONNEL EXPOSURES DESCRIPTION (39) NUMBER TYPE NA 0101 0 (37) Z (38) 7 80 PERSONNEL INJURIES DESCRIPTION (41) NUMBER NA 0 0 8 01 (40 80 8305030419 830422 LOSS OF OR DAMAGE TO FACILITY (43) PDR ADOCK 05000324 DESCRIPTION Z (42) S PDR 19 PUBLICITY NRC USE ONLY DESCRIPTION (45 SSUED NA N (44) 1111111 68 69 80 919-457-9521 M. J. Pastva, Jr. PHONE -NAME OF PREPARER -