

GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

April 20, 1983
4410-83-L-0083

Office of Inspection and Enforcement
Attn: Mr. J. M. Allen
Acting Regional Administrator
Region I
US Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406


Dear Sir:

Three Mile Island Nuclear Station, Unit 2 (TMI-2)
Operating License No. DPR-73
Docket No. 50-320
Licensee Event Report 83-010/01L-0

Attached please find Licensee Event Report 83-010/01L-0 concerning the failure of Incore Thermocouple H13 on March 22, 1983.

This event is a violation of Section 3.3.3.6, Table 3.3-10, Item 10 and is reportable under Section 6.9.1.8 of the Interim Recovery Technical Specifications.

Sincerely,


B. K. Kanga
Director, TMI-2

BKK/SDC/jep

Attachments

CC: Mr. L. H. Barrett, Deputy Program Director - TMI Program Office
Dr. B. J. Snyder, Program Director - TMI Program Office

8305030527 830420
PDR ADOCK 05000320
S PDR