

NOTICE OF VIOLATION

Illinois Power Company
Clinton Power Station

Docket No. 50-461
License No. NPF-62

During an NRC inspection conducted on April 5 through May 16, 1994, two violations of NRC requirements were identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violations are listed below:

1. Technical Specification 6.2.2.6 requires that while in Operational Condition (OC) 1, 2, or 3 at least one licensed senior reactor operator shall be in the control room.

Contrary to the above, during a brief period on April 13, 1994, with the unit in OC 1, no senior reactor operators were present in the control room.

This is a Severity Level IV violation (Supplement I).

2. 10 CFR Part 50, Appendix B, Criterion XVI, Corrective Action, requires that measures shall be established to assure that conditions adverse to quality and non-conformance are promptly identified and corrected.

Contrary to the above, on May 3, 1994, a condition adverse to quality, emergency diesel generator air start system indicated pressure greater than the air start motor maximum design pressure of 200 psig, was identified. The same condition, as observed during an inspection conducted in March through June 1992, was not promptly corrected.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Illinois Power Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the U.S. Nuclear Regulatory Commission, Region III, 801 Warrenville Road, Lisle, IL 60532-4351, and a copy to the NRC resident inspector at the Clinton Power Station, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or a demand for information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Lisle, Illinois
this 10th day of June 1994