



GPU Nuclear Corporation
Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

C321-94-2005
June 15, 1994

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station (OCNGS)
Operating License No. DPR-16
Docket No. 50-219

Technical Specification Change Request (TSCR) No. 216
RE: LIMITING SAFETY SYSTEM SETTINGS
Technical Specification 2.3.D, "Reactor High Pressure, Relief
Valve Initiation" Limiting Safety System Setpoint Change

Pursuant to 10 CFR 50.90, GPU Nuclear Corporation (GPUN), operator of the Oyster Creek Nuclear Generating Station (OCNGS), Operating License No. DPR-16, requests a change to the Appendix A of the license.

Also enclosed is one signed copy of the Certificate of Service for this request which confirms service to the senior official of the township in which the facility is located.

The proposed amendment changes the setpoints of Technical Specification 2.3.D, "Reactor High Pressure, Relief Valve Initiation" by increasing the setpoint value by 15 psig for each of the Electromatic Relief Valves (EMRVs) in the Automatic Depressurization System (ADS).

This change request has been reviewed in accordance with Section 6.5 of the OCNGS Technical Specifications. Using the standards in 10 CFR 50.92 we have concluded that these proposed changes do not constitute a significant hazards consideration.


21000-
9406220142 940615
PDR ADOCK 05000219
P PDR

A001
11

GPUN would like to implement this change during the upcoming refueling outage 15R, scheduled to start on September 10, 1994; and, if possible, would request that this TSCR be reviewed and approved at your earliest opportunity. However, approval of this TSCR is not operation limiting and the change will be implemented and made effective within 60 days following receipt of the license amendment.

Pursuant to 10 CFR 50.91 (b) (1), a copy of this change request has been sent to the State of New Jersey Department of Environmental Protection.

Sincerely,



John J. Barton
Vice President and Director
Oyster Creek

JJB\GMG

Enclosures: 1) Technical Specification Change Request No. 216.
2) Certificate of Service for Technical Specification Change Request No. 216.
3) GPUN Topical Report, TR-101, "Considerations Associated with Changing EMRV Setpoints."

cc: OCNGS NRC Project Manager
Administrator, Region I
OCNGS NRC Sr. Resident Inspector

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the matter)
GPU Nuclear Corporation)


Docket No. 50-219

CERTIFICATE OF SERVICE

This is to certify that a copy of Technical Specification Change Request No. 216 for Oyster Creek Nuclear Generating Station Technical Specifications, filed with the U.S. Nuclear Regulatory Commission on June 15, 1994, has this day of June 15, 1994, been served on the Major of Lacey Township, Ocean County, New Jersey by deposit in the United States mail, addressed as follows:

The Honorable Theodore J. Hutler
Mayor of Lacey Township
818 West Lacey Road
Forked River, NJ 08731

By


John J. Barton
Vice President and Director
Oyster Creek