METROPOLITAN EDISON COMPANY Subsidiary of General Public Utilities Corporation

Tile

Subject Plant Status - Unit II Location TMI/U-2 Site Ops TMI-II-R-29576

Date

September 25, 1980

To

R. C. Arnold, Sr. Vice President, Met-Ed

P. R. Clark, Executive Vice President, Nuclear

F. Glickman, Director Administration

R. W. Heward, Director Radiological & Environmental Controls

G. K. Hovey, Director, TMI-2

R. L. Long, Acting Director Maintenance & Construction

F. F. Manganaro, Director Maintenance & Construction

W. A. Verrochi, Prospective President, Met-Ed

R. F. Wilson, Director Technical Functions

Plant Status: Plant in an outage from 0800 September 24, 1980 to 0800 September 25, 1980.

- Primary Plant Condition
 - Pressure PSIG-88 using Standby Pressure Control System.
 - Temperature 136.10F B.
 - Cooling Mode Natural Circulation "A" OTSG C.
 - D. Water Level - N/A
 - Boron Concentration 3765 ppm E.
- Steam Plant Condition

Generator - Wet - Steaming "A" OTSG-Level 416"

Turbine - On Jacking Gear

- 3. Tech. Spec. Clock Items
 - Deluge/Sprinkler System for Reactor Building Purge Filter isolated, reported July 9, 1980. Licensing is preparing Tech. Spec change.
 - Reactor Cooling System Flow Instrumentation out of calibration B . at 1400 on September 9, 1980, 30 day limit.
 - A Nuc River Header O.O.S. September 23, 1980 72 hour clock
 - Fire Service Pump 0.0.S.September 23, 1980 7 day clock D.
- Reportable Events None
- Actual radiation release (based on preliminary data):

Kr-85 - No detectable reading.

Particulate - No detectable reading.

- 6. Planned Release or Discharge Next Period None
- 7. Radiological Waste Shipments
 - A. Special Limits on Shipment None
 - B. Shipments Past Period (Last Working Day)

 18 LSA Boxes to Richland, Wash. September 24, 1980.
 - C. Planned Shipments Next Period (Next two (2) working days):

 Reactor Building Instrument HP-R 211 to Sandia, NM

September 25, 1980, delayed because shipment required additional shielding.

- 8. Major Evolutions, Next 24 Hours
 - A. Installation of seismic support for MDHR continues.
- 9. Problems None
- 10. Progress vs. Schedule

Functional Testing of MDHR - complete September 18, 1980.

- Sjected operational date September 26, 1980.
- a) Core Drilling seismic support and installation;
- b) demonstration of dry run filter changeout and resolving problems scheduled following the above.
- 11. N/A
- 12. Potential Public Interest Items

Reactor Building Purge Cancelled. Reactor Building Entry Cancelled.

13. Non-routine NRC Audits - None

I. J. Barton

JJB:1h

cc: J. W. Brasher

J. T. Collins, U.S. NRC

J. C. DeVine

B. D. Elam

S. Polon

File