

*File
IE Inspection
Reports*

METROPOLITAN EDISON COMPANY Subsidiary of General Public Utilities Corporation

Subject TMI UNIT 1 NRC INSPECTION EXIT -
INSPECTION REPORT 79-24

Location TMI NUCLEAR STATION

Date JANUARY 14, 1980

To ACTION PARTIES

ATTENDEES:

- G. P. Miller - Unit 1 Met-Ed
- W. E. Potts - Met-Ed - Manager HP Unit 1
- D. R. Haverkamp - Unit 1 Resident Inspector (Acting)
- K. E. Plumlee - Senior Radiation Specialist (Acting)
- J. T. Collins - Deputy Director, TMI Support

- - - - -

1. This inspection covered Unit 1 operations and Health Physics through the period November 28, 1979 to January 4, 1980. The inspection included plant tours, inspections by shift NRC personnel, records and document searches.
2. The Operations Area was found acceptable with no items of non-compliance.
3. Past Open Item 78-06-01 relative to work inside steam generators -- NRC concern is in relation to the fact that Met-Ed owes a response and action. Met-Ed, by letter dated 12/11/79 - GQL 1510, committed a response on this item by 12/31/79 and this response has not been forwarded to date. To resolve this item:
 - (a) Met-Ed owes a response Action: Harding/Potts
 - (b) Until HP will look at the Unit 2 commitment in this area and will resolve the items with the NRC Action: Potts

4. Health Physics reviewed:
- (a) Cleanliness
 - (b) Housekeeping
 - (c) Epicor I
 - (d) Waste Solidification
 - (e) Surveying and Frisking
 - (f) Respiratory Program
 - (g) Work Requests/RWP's
 - (h) Logs/Records

These areas found acceptable at this time.

5. This Inspection Report and the next one will be issued for Units 1 and 2. The NRC intends to separate the Units' inspection reports in the future.



G. P. Miller

GPM/jl

cc: Attendees

- T. M. Hawkins - SU/T
- C. E. Hartman - PORC Chairman for review with PORC as applicable.
- J. J. Colitz
- D. Dyckman
- L. W. Harding
- M. J. Ross
- D. M. Shovlin
- R. S. Harbin - 1. Inform G. Troffer
2. You have the follow-up action.