

NRC Research and/or Technical Assistance Rept

PDR

EGG-EA-6074


OCTOBER 1982

QUICK LOOK AT LICENSEE EVENT REPORTS OF BATTERIES AND
BATTERY CHARGERS AT U.S. COMMERCIAL NUCLEAR POWER PLANTS
JANUARY 1, 1976 TO DECEMBER 31, 1981

S. R. Brown
M. Trojovsky

Idaho National Engineering Laboratory

Operated by the U.S. Department of Energy



This is an informal report intended for use as a preliminary or working document

Prepared for the
U.S. NUCLEAR REGULATORY COMMISSION
Under DOE Contract No. DE-AC07-76ID01570
FIN No. A6276

 **EG&G** Idaho

8212010474 821031
PDR RES
8212010474 PDR



FORM EG&G-398
(Rev. 03-82)

INTERIM REPORT

Accession No. _____

Report No. EGG-EA-6074

Contract Program or Project Title:

LER Evaluations

Subject of this Document:

Quick Look at Licensee Event Reports of Batteries and Battery Chargers
at U.S. Commercial Nuclear Power Plants, January 1, 1976 to December 31, 1981

Type of Document:

Data Summary Report

Author(s):

S. R. Brown
M. Trojovsky

Date of Document:

October 1982

Responsible NRC Individual and NRC Office or Division:

R. C. Robinson, Division of Risk Analysis

This document was prepared primarily for preliminary or internal use. It has not received full review and approval. Since there may be substantive changes, this document should not be considered final.

EG&G Idaho, Inc.
Idaho Falls, Idaho 83415

Prepared for the
U.S. Nuclear Regulatory Commission
Washington, D.C.
Under DOE Contract No. DE-AC07-76 ID01570
NRC FIN No. A6276

INTERIM REPORT

ABSTRACT

This report presents data summaries of Licensee Event Reports (LERs) of batteries and battery chargers at U.S. commercial nuclear power plants from January 1, 1976, through December 31, 1981. The LERs are sorted according to plant, system, failure modes, failure causes, human factors, and activity resulting in discovery. In addition, common cause and recurring events are identified. Summary tables are provided.

NRC FIN No. A6276

SUMMARY

In support of the Nuclear Regulatory Commission's (NRC's) effort to gather and analyze failure data concerning nuclear power plants, EG&G Idaho's Reliability and Statistics Branch reviewed Licensee Event Reports (LERs) (both qualitatively and quantitatively) in an attempt to extract reliability information. LERs submitted from the utilities to the NRC from January 1, 1976, through December 31, 1981, are the source of information used in this report. This report focuses on LERs pertaining to batteries and battery chargers in all systems of commercial nuclear power plants within the United States--with the exception of four plants considered atypical.

A computerized data base of component/system operational experiences (LERs) categorized by standard reliability characteristics was developed to provide an efficient and accurate way of retrieving and sorting the various reliability data. The data base contains a coded description of the original LERs. The plant reporting the event, the date of the event, the failure mode and cause, and the type of component are just a few of the different types of reliability information contained in the computer data file. Data summaries relating to batteries and battery chargers categorized by NSSS vendor, plant, year, system, failure modes and causes, activity resulting in discovery, type of event, and event classification are provided.

Of the 21,021 LERs screened, 169 described battery and battery charger events considered within the scope of this report. From these 169 LERs, 212 one-line descriptions were derived and entered into the data base. However, 48 of the one-line descriptions have "test not performed" as the failure mode and hence do not represent true faults. Of the remaining 164 one-line descriptions, 109 describe events involving a total of 120 batteries. The remaining 55 one-line descriptions describe events involving a total of 61 battery chargers.

Because subjective judgments had to be made regarding pertinence of recorded events, and because some component faults may not be recorded in the LERs, the component faults summarized in this report should be interpreted as only tentative gross indicators of true fault trends. The individual analyst must validate the applicability of the LER faults for specific uses.

FOREWORD

This report was prepared by EG&G Idaho's Reliability and Statistics Branch for the U.S. Nuclear Regulatory Commission's (NRC's) Office of Nuclear Regulatory Research, Division of Risk Analysis (DRA), Risk Methodology and Data Branch, under NRC FIN No. A6276. The project was undertaken at the request of personnel in the Reactor Risk Branch of DRA who are studying battery and battery charger events. They will be generating failure rate estimates for these events using the results of this study. Therefore, this report differs from the Licensee Event Report "Data Summary" NUREGs in that it is just a "quick look" at the data and does not contain failure rate estimates.

ACKNOWLEDGMENTS

Sincere appreciation is expressed to the following persons for their assistance in the preparation of this report:

C. D. Gentillon for her helpful suggestions.

K. Culbertson and B. Munson for their conscientious and timely efforts in word processing and text composition.

CONTENTS

ABSTRACT	iii
SUMMARY	iv
FOREWORD	vi
ACKNOWLEDGMENTS	vii
NOMENCLATURE	xi
Terms	xi
Acronyms and Abbreviations	xii
INTRODUCTION	1
LER EVALUATION AND CODING METHODOLOGY	3
Scope	3
Component Boundaries	3
Battery	3
Battery Charger	3
LER Selection	3
LER Classification	4
NSSS Vendor (NSSS)	5
Plant (PLANT)	6
Control Number (CONTROL NUMBER)	6
Event Date (EVENT DATE)	6
Component Type (COMP)	7
System (SYSTEM)	7
Failure Code (FAILURE CODE)	7
Failure Mode	8
Failure Cause	9
Failure Subcause	10
Activity Resulting in Discovery (ACTIVITY)	10
Type of Event (TYPE)	10
Event Classification (CLASS)	12
Number of Failed Components (FAIL #)	13
Failure Mode Description (FAILURE MODE DESCRIPTION)	13
Failure Cause Description (FAILURE CAUSE DESCRIPTION)	13
Additional Information	14
Manufacturer Code (MANUFACTURER CODES)	14

Voltage Rating (VOLTAGE RATING)	15
Repair Time (REPAIR TIME)	15
Flagging (FLAGGING)	15
Number of Affected Cells (CELL #)	15
Plant LER Number	15
Report Type	15
SUMMARY OF RESULTS	16
REFERENCES	36
APPENDIX A--DISCUSSION OF THE CAUSES OF VARIATIONS IN LER REPORTING	37
APPENDIX B--GENERAL PLANT INFORMATION	43
APPENDIX C--ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY NSSS VENDOR	51
APPENDIX D--ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY COMPONENT	63
APPENDIX E--ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY SYSTEM	75
APPENDIX F--ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE MODE	87
APPENDIX G--ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE CAUSE	99
APPENDIX H--ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS CAUSED BY HUMAN FACTORS	111
APPENDIX I--ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY ACTIVITY RESULTING IN DISCOVERY	119
APPENDIX J--ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS FOUND IN NUREG-0666	131
APPENDIX K--ADDITIONAL INFORMATION CONTAINED IN BATTERY AND BATTERY CHARGER ONE-LINE DESCRIPTIONS	137

TABLES

1. Summary of battery and battery charger events by component and NSSS vendor	18
2. Summary of battery and battery charger events by component and plant	19

3.	Summary of battery and battery charger events by component and year	23
4.	Summary of battery and battery charger events by component and system	24
5.	Summary of battery and battery charger events by component and failure mode	26
6.	Summary of battery and battery charger events by component and failure cause	27
7.	Summary of battery and battery charger events by component and failure subcause	29
8.	Summary of battery and battery charger events by component and activity resulting in discovery	31
9.	Summary of battery and battery charger events by component and type of event	32
10.	Summary of battery and battery charger events by component and event classification	33
11.	Codes used in one-line descriptions	34

NOMENCLATURE

Terms

Component	A component is the largest entity of hardware for which data are most generally collected and expected to be available (for example, pump with motor, valve with operator, amplifier, pressure transmitter). It is generally an off-the-shelf item procured by the system designer as a basic building block for his system. It would be distinguished from seals, bearings, nuts, bolts, and other piece parts from which the component is manufactured.
System	A system is a collection of components arranged so as to provide a desired function (for example, Containment Spray System, Residual Heat Removal System, High Pressure Coolant Injection System).
Fault	A fault is any undesired state of a component or system. A fault does not necessarily require failure (for example, a battery charger might not charge properly because of some other component input or human error--a "command fault").
Command Fault	A command fault is an event in which the component did not function as required, not because of a failure in the component, but because of inputs or lack of inputs to the component as supplied by personnel, other components, or the environment external to the component. This is a reversible state of the component that can be corrected once the faulty input is corrected. No component repair is required.
Failure	A failure is a subset of a fault and represents an irreversible state of a component such that it must be repaired in order for it to perform its design function. Failures are sometimes classified as primary or secondary failures. A primary failure is the so-called "random failure" found in the literature. It results from no external cause. A secondary failure results when the component is subject to conditions that exceed its design envelope (for example, excessive voltage, pressure, shock, vibration, temperature). However, for this report, no distinction has been made between these two failure classifications.
Common Cause Failure	Common cause failures are two or more redundant components failing together or having the potential to fail within a relatively short period of time

because of a single cause. The common cause events that cause multiple failures are usually secondary failures. Human errors are a special type of failure cause that are usually considered common cause for multiple failures.

Failure Cause The identified cause that prevented the component from performing its intended function.

Failure Mode The description of the manner in which a component ceases to perform its intended function.

Acronyms and Abbreviations

admin	Administrative
adq	Adequate
AFWP	Auxiliary Feed Water Pump
AH, A.H.	Amp-hours
assoc	Associated
avail, avl	Available
batt, bttry	Battery
bkr, brkr	Breaker
bdg	Building
BWR	Boiling Water Reactor
chrg, chrgr	Charger
ckt	Circuit
cktbrk	Circuit breaker
cnctr	Connector
cntct	Contact
cntrl	Control
con	Conditions
connect	Connections/Connector
decrs	Decrease

det	Detector
dfctv	Defective
DG, D/G	Diesel Generator
dischr	Discharge
DP, D/P	Differential Pressure
DRA	Division of Risk Analysis
elec	Electrolyte
elec. strat.	Electrolyte stratification
emer	Emergency
equal, equalzg	Equalizing
freq	Frequency
grnd	Ground
HV	High Voltage
hydrom	Hydrometer
ICV	Individual Cell Voltage
inadq	Inadequate
incrs	Increase
inop	Inoperable
instal	Installation/Installment
instr	Instrument
invest	Investigate
LCO	Limited Condition for Operation
LER	Licensee Event Report
lmt	Limit
lmtr	Limiter
min	Minimum
NRC	Nuclear Regulatory Commission

NSIC	Nuclear Safety Information Center
NSSS	Nuclear Steam Supply System
op	Operate/Operation
OOS	Out of Service
OOT	Out of Tolerance
pers, person	Personnel
proc	Procedure
prox	Proximity
PWR	Power/Pressurized Water Reactor
rdg	Reading
recom	Recommend
reg	Regulator
repl, rplc, rplcd	Replace/Replaced
req	Required
rng	Range
SD, S/D	Shutdown
SG, S.G.	Specific Gravity
sig	Signal
st	Station
surv	Surveillance
SW	Service Water
sys	System
temp	Temperature/Temporary
term	Terminal
trp, trpd	Trip/Tripped
tech spec, T.S.	Technical Specification
UPS	Uninterruptible Power System

volt, voltg

Voltage

wrng

Wiring/Wrong

xstr

Transistor

QUICK LOOK AT LICENSEE EVENT REPORTS
OF BATTERIES AND BATTERY CHARGERS
AT U.S. COMMERCIAL NUCLEAR POWER PLANTS
JANUARY 1, 1976 TO DECEMBER 31, 1981

INTRODUCTION

In support of the Nuclear Regulatory Commission's (NRC's) effort to gather and analyze failure data concerning nuclear power plants, Licensee Event Reports (LERs) are being reviewed (both qualitatively and quantitatively) in an attempt to extract reliability information. LERs submitted from the utilities to the NRC from January 1, 1976, through December 31, 1981, are the source of information used in this report. This report focuses on LERs pertaining to batteries and battery chargers in all systems of commercial nuclear power plants within the United States--with the exception of four plants considered atypical.

The reliability information gleaned from these LERS was encoded into a data file and then stored in a computer. The data file contains a coded description of the original LERs. The plant reporting the event, the date of the event, the failure mode and cause, and the type of component are just a few of the different types of reliability information contained in the computer data file. These features make the data file an efficient and accurate means of obtaining various statistics for use in this report and future analyses. Data summaries relating to batteries and battery chargers categorized by standard reliability characteristics are provided.

The data summaries reported herein are based on the component faults reported in the LER system. These faults do not necessarily consist of all faults for any given component. Plant status (at power, cold shutdown, refueling, etc.) and system or subsystem impact are two factors which can determine whether or not a fault is reported.

In this report are the assumptions, definitions, and limitations used in carrying out the analysis. Appendix A discusses a few causes (though not all) of the variations in LER reporting. Appendix B gives general

plant information. Appendices C through J contain sorts of the LERs by NSSS vendor, component, system, failure mode, failure cause, human factors, activity resulting in discovery, and records contained in NUREG-0666.¹ Appendix K contains a sort by NSSS vendor containing additional information (manufacturer, voltage rating, etc.) not presented in the previous sorts.

LER EVALUATION AND CODING METHODOLOGY

Scope

Component Boundaries

Battery. Where an output breaker was provided between the battery and its load as found in major battery bank systems (i.e., station and switchyard battery systems), the output breaker and all components required for the proper operation of the battery or battery bank were considered within the bounds of the battery or battery bank. In smaller battery systems such as engine starting battery systems, only the battery, associated cables, and connectors between the battery and its load were considered within the battery boundaries.

Battery Charger. All electrical and mechanical components between the battery charger's supply breaker and output breaker and any external controls required for the proper operation of the battery charger were considered part of the battery charger. The supply breaker was not considered part of the battery charger, while the output breaker was considered part of the battery charger.

LER Selection

In order to ensure the completeness of the LERs pertaining to batteries and battery chargers the entire NRC LER file was reviewed for the period covering January 1, 1976, to December 31, 1981. The total number of LERs reviewed for this report was 21,021. The LERs were screened and excluded for the following reasons:

1. The LERs pertained to other components outside the scope of this report.
2. The LERs were submitted by plants considered atypical. These plants were Fort St. Vrain (gas-cooled), Humboldt Bay (BWR/1,

63 megawatts), and LaCrosse (the only plant with Allis-Chalmers as the NSSS vendor). Indian Point 1 also differs from the 72 plants evaluated in this report. It is considered atypical because it was shutdown October 31, 1974, and was subsequently defueled. Dresden 1 is considered in this report, but any events after October 31, 1978, were not considered because of the extended shutdown which started on October 31, 1978, and which was still in effect on December 31, 1981. Three Mile Island 1 and 2 were considered in this report; however, events associated with these plants after the accident on March 28, 1979, were not considered. Three Mile Island 2 is still shutdown, and on December 31, 1981, Three Mile Island 1 was still shutdown due to a restraining order.

3. The LERs were submitted prior to the date of initial criticality for the respective plant.

Of the 21,021 LERs screened 169 described battery and battery charger events considered within the scope of this report. Details of the results of the screening process are included in a later section of this report.

LER Classification

The purpose of this report is to provide quantitative and qualitative reliability data on selected batteries and battery chargers in commercial nuclear power plants. A computerized data base of component/system operational experiences (LERs) categorized by standard reliability characteristics was developed to provide an efficient and accurate way of retrieving and sorting the various reliability data.

The NRC LER system contains a centralized source of component/system operational experiences of off-normal events in the nuclear industry. The NRC LER file, however, is not a reliability data base. Therefore, direct transcription of these LERs for reliability-data purposes is not usually possible. At times, there is some correlation between what is coded in a LER and what would be desired in our data base. In these cases, a direct

transcription was made. However, the descriptive text of the LER provided the bulk of the information needed for the data base. A discussion of the assumptions and definitions used in coding our data is provided below.

The data base consists of one-line descriptions of battery and battery charger events contained in the LERs. Although most LERs contain only a single report involving one event (a failure or a command fault), some LERs contain multiple reports, each involving either single or multiple events. For the case where there exists multiple reports in the LER, an appropriate one-line data record was created in the data base for each report contained in the LER. For the case where the LER describes multiple failures involving like components, information was encoded into the one-line data record to account for the number of events.

In order to extract as much pertinent information as possible from the information provided in the original LER, and, at the same time, to restrict the information to one line of computer output per LER, the following coding scheme was developed. The order of discussion that follows is the order in which the various fields appear in the printed one-line descriptions of the battery and battery charger events. The headings used for the corresponding fields in the one-line descriptions are contained in parentheses following the topic headings used below.

NSSS Vendor (NSSS)

The NSSS field indicates the vendor associated with the plant submitting the LER report. A single-character field is used to store and display the vendor code. This field can be used as a sort key. The following list gives the code and corresponding NSSS vendor.

<u>Code</u>	<u>NSSS Vendor</u>
B	Babcock & Wilcox
C	Combustion Engineering
W	Westinghouse
G	General Electric

Plant (PLANT)

A three-character field was used to identify the commercial power plant responsible for submitting each LER. Because of the relatively large number of plants used in the report, a list of the plants and codes will not be given here. Appendix B provides this information. This field can be used as a sort key.

Control Number (CONTROL NUMBER)

To identify each one-line record within the data file, and to provide a cross-reference with the actual LER submitted to the NRC, the unique six-digit control number assigned to the report by the NRC was entered into the CONTROL NUMBER field. There were some instances of several different reports being listed in the narrative summary of a single LER. To accommodate this situation, an alphabetic character was added to the six-digit number in order to separately identify each report. Thus, traceability back to the original LER number was maintained, yet each report remained unique. When a single LER reported more than one instance of the same event (e.g., "no output from all UPS battery banks") in the summary description, an asterisk (*) was placed after the control number to flag the coded one-line description as containing multiple events. The corresponding number of events was then entered in the FAIL # field so that each event could be accounted for. The CONTROL NUMBER field can be used as a sort field, but it is intended for data record identification within the data file.

Event Date (EVENT DATE)

The event date in the one-line data record corresponds to the event date reported in the LER (i.e., the date the failure was discovered). A six-digit field was used to record the date of the event: two digits each, for month, day, and year. The month, day, or year can be used as sort keys.

Component Type (COMP)

Each component was identified by a two-character field: BA and BC were used to code batteries and battery chargers, respectively.

System (SYSTEM)

A three-character field was used to record the reactor type and system: a one-character subfield containing an A or a B (which is not printed in the one-line description), for a PWR or BWR reactor, respectively, and a two-character subfield containing the system code. Either of these subfields can be used as sort keys. The following is a list of system codes and descriptions.

<u>Code</u>	<u>System</u>
AM	Area monitor
DB	Emergency diesel generator
ES	Engineered safety feature
FP	Fire protection system
FW	Feedwater system
NM	Neutron monitoring battery
NN	Unknown/Unspecified/Other
SA	Automatic (reactor) depressurization (ADS)
SP	Special use batteries
ST	Station batteries/chargers
SW	Service water building batteries/chargers
SY	Switchyard batteries/chargers
UP	Uninterruptible power system (UPS)

Failure Code (FAILURE CODE)

Failures are summarized by a five-character alphanumeric field made up of: an alphabetic field for failure mode, a two-digit field for failure cause, and a two-digit field for subcause. The subcause field was added in this report because of the possibility of several events resulting in the final outcome.

Failure Mode. A single-character field was used to indicate the failure mode. The following list gives the failure mode codes and descriptions.

<u>Code</u>	<u>Failure Mode</u>
A	Reduced capability
B	No output
C	Unknown/Unspecified/Other
D	High current/voltage output
E	Low output voltage
G	High AC ripple on DC output
M	Maintenance replacement
T	Test not performed

Failure mode codes A through C were used in coding batteries, while codes A through G were used in coding battery chargers. Codes M and T were applicable in coding both battery and battery charger events. This field can be used as a sort key.

The failure modes should be self-explanatory, with the possible exception of the following:

1. Maintenance Replacement--LERs occasionally reported events that were potential problems. Examples of potential problems are, "battery cell voltage found below minimum" and "one cell of RDS battery found below minimum specific gravity." Although the batteries in these examples are still able to perform their designed functions and are, therefore, not failed, the reporting plant either recharged, repaired, or replaced them because it was felt that they might fail in the immediate future. Note that if the LER stated that full battery capacity was still available then "maintenance replacement" was used as the failure mode. Otherwise, "reduced capability" was used in low voltage or specific gravity situations that involved batteries.
2. Test Not Performed--This mode refers to failures of plant personnel to perform their duties concerning battery and battery

charger related directives and procedures. Examples of some "test not performed" events are as follows:

<u>Mode Description</u>	<u>Cause Description</u>
Surveillance not performed when required	Procedural deficiency
Individual float cell voltage measurement not done in the Station Battery Test	Personnel oversight

Events involving this mode are considered nonfailures in that the consequence of these omitted acts do not immediately affect the component's ability to perform its function.

Failure Cause. A two-digit field was used to indicate failure cause. This field can be used as a sort key. The following list gives the failure cause codes and descriptions.

<u>Code</u>	<u>Failure Cause</u>
00	Unknown
01	Personnel operation
02	Personnel maintenance
03	Personnel testing
04	Design/Fabrication/Construction/Quality control
05	Defective procedures
06	Extreme environment
08	Corrosion
10	Normal wear/Natural end of life
11	Electrical malfunction
12	Mechanical malfunction
13	Piece part failure
14	Low specific gravity
15	Stratification
16	High electrolyte solution level
17	Low electrolyte solution level
18	Insufficient charge
20	Defective/Weak cells
21	Voltage regulator malfunction
22	Current limiter malfunction
23	Current controller malfunction
24	Voltage limiter malfunction
25	Thermal overload protection
26	Cooling fan/Ventilation malfunction

<u>Code</u>	<u>Failure Cause</u>
27	Charge control malfunction
28	Charge control timer malfunction
29	Rectifier problem
30	Short circuit
32	Electrolyte dilution
33	Faulty cable/connectors
34	Charger malfunction

Failure Subcause. A two-digit field was used to indicate failure subcause, which uses the same codes and descriptions as the failure cause field. This field can be used as a sort key.

Activity Resulting in Discovery (ACTIVITY)

This single-character alphanumeric field contains a code indicating the activity taking place that led to the discovery of the event. This field can be used as a sort key. The codes and activities are listed as follows:

<u>Code</u>	<u>Activity</u>
A	Testing (unspecified)
B	Normal load testing
C	Monthly testing
D	Weekly testing
E	Quarterly testing
F	Refueling testing
G	18-month testing
H	5-year testing
M	Maintenance
N	Normal plant operation
R	Records review
U	Unknown

Type of Event (TYPE)

The type of event was coded in a single-character field. The following is the list of the codes corresponding to the type of events:

<u>Code</u>	<u>Type of Event</u>
B	Recurring common cause
C	Common cause
R	Recurring
S	Command fault
T	Recurring command fault
U	Common cause command fault
V	Recurring common cause command fault
Blank	Random

In addition to random events, we were able to identify events as being either recurring, common cause, or command faults, as well as combinations of these three types.

Recurring in this report means two or more LERs from a plant (unit) or plants at one site (for example, Quad-Cities 1 and 2) reporting problems of a similar enough nature that some note should be taken. No attempt is made to compare events at Quad-Cities 1 with events at Zion 1 (that is, to identify intersite failures). An example which illustrates recurring failures would be two separate LERs from one plant stating that, "battery charger output breaker, No. 2, failed open due to excessive heat caused by a thermal overload." Both of these events would be classified as recurring. One other criterion for classifying an event as recurring is to have an LER state, "this is a recurring failure," or "similar failures have been reported on this component."

A common cause failure classifies not only simultaneous faults of two or more components, but also includes single faults where the potential for two or more component failures exists. The latter are considered common cause candidates. If there was any doubt as to whether an event was common cause or not common cause, then the event was coded as common cause. If the same common cause was reported more than once at one plant, this was coded as recurring common cause.

A command fault is a fault where there is no actual physical failure of the component, but where the component is in the wrong state because of factors external to the component. External factors, such as human error or failure of a component that interfaces with the faulted component,

account for most command faults. For example, if a battery charger's AC supply breaker failed, leaving the battery charger inoperable, it is not a battery charger failure; the battery charger would operate satisfactorily if power were available. However, if there was any doubt as to whether the fault was a command fault or failure, then the fault was considered a failure. Recurring command faults describe events that include the criteria for both recurring and command faults. Common cause command faults occur when two or more components are affected by a single command fault. As before, these components do not experience an actual failure, but are in the wrong state due to input (or lack of input) from other components. When the reported problem was a recurring command fault, the appropriate code was used. When the event was both a recurring and common cause command, we used the recurring common cause command code to identify the fault.

Type of event can be used as a sort key.

Event Classification (CLASS)

When possible, events were classified as Frequency-of-Use-Related or Age-Related. In some cases, we could not specifically classify an event as either Frequency or Age; these events are coded Unknown. However, due to the limited information contained in the LERs, it was difficult to extract the necessary information directly from the LER narrative. Therefore, the classification method is subjective and care should be used in drawing conclusions from these data. This field can be used as a sort key. The following list shows the coding used for event classification.

<u>Code</u>	<u>Event Classification</u>
D	Frequency
T	Age
U	Unknown

Number of Failed Components (FAIL #)

The FAIL # field is a two-digit field used to store the number of components in each one-line data record. A blank in this field implies that the value in the field is one. This field is used for counting events or reports rather than sorting them.

Reports involving more than one component failure are assigned a number indicating how many components were involved in the report. Thus, the "Number of Failed Components" data are important because there is not a one-to-one relationship between the number of reports and the number of components in the data file. Where the LER was not explicit on the number of failed components, the number appearing in FAIL # was subjectively assigned and noted in the flagging field (described below).

Failure Mode Description (FAILURE MODE DESCRIPTION)

A short, concise description of the LER failure mode was condensed into a 50-character alphanumeric field called FAILURE MODE DESCRIPTION. FAILURE MODE DESCRIPTION is not a sort field.

Failure Cause Description (FAILURE CAUSE DESCRIPTION)

A short, concise description of the LER failure cause was condensed into a 41-character alphanumeric field called FAILURE CAUSE DESCRIPTION. FAILURE CAUSE DESCRIPTION is not a sort field.

Both the FAILURE MODE DESCRIPTION and FAILURE CAUSE DESCRIPTION may contain information in addition to that appearing in coded form. The battery identification number, such as "radiation monitor 2R12A battery pack"; or a series of failure causes, such as "broken terminal on shutdown board battery because of maintenance error due to procedural problems"; or the "as found" condition of related equipment that may have affected the proper operation of the battery or battery charger, such as "supply breaker for a battery charger found open", are examples of additional information contained in these fields.

Additional Information

The items discussed so far are all that can be printed on a single line of computer printout. Additional information is available, however, and is discussed below. All fields, with the exception of CELL NO., in the following section can be used as sort keys.

Manufacturer Code (MANUFACTURER CODES). The MANUFACTURER field is a four-character alphanumeric field used to store component manufacturer data. The manufacturers' names and codes were obtained from Exhibit J of Reference 2. LERs obtained from the Nuclear Safety Information Center (NSIC) Data Base have no manufacturer listed other than those found in the descriptions. Some LERs failed to report any manufacturer and were coded as blanks in the MANUFACTURER field. The following is a list of manufacturer codes and names for this report.

<u>Code</u>	<u>Manufacturer</u>
C173	C&D Batteries, Division of Eltra Corp.
C742	Cummins Engine Co., Inc.
E147	Electro-Motive Division of G.M.
E226	Eltra Corporation (Eletra)
E355	Exide Industrial Division
E359	Exxon Chemical Company
F013	Fairchild Hiller Products
G080	General Electric Company
G185	Gould-National Batt
G190	Goulds Manufacturing
G195	Goulds Company (Goulds)
L015	La Marche Mfg. Co.
P319	Power Conversion Products, Inc.
U125	Universal Industries
V115	Victoreen Instrument Division
W059	Waukesha Elec. Mach. Mfg. Company
W120	Westinghouse Electric Corporation
Blank	Manufacturer not specified

One should be cautious in using this manufacturer information because in many LERs the manufacturer listed was not the manufacturer of interest but was the manufacturer of a particular piece part or subcomponent.

Voltage Rating (VOLTAGE RATING). The VOLTAGE RATING field is a three-digit field used to store component voltage data when the LER provided this information.

Repair Time (REPAIR TIME). The REPAIR TIME field is a three-digit field used to store component repair time when available in hourly units.

Flagging (FLAGGING). Each one-line data record was evaluated to determine whether or not the event might need to be "flagged" for possible future evaluation. The following is a list of the codes and descriptions used in the FLAGGING field.

<u>Code</u>	<u>Flagging</u>
A	Failed component caused an accident or scram
B	Component failed to mitigate an accident or scram
C	Safety significance
D	Unknown component failure number
E	Unknown cell number
F	Unknown component failure and cell numbers
N	LERs obtained from the NSIC data base's NUREG/CR-2000
Y	Events found in NUREG-0666

Number of Affected Cells (CELL #). The CELL # field is a two-digit field used to store the number of battery cells affected by a given event.

Plant LER Number. In addition to a plant docket number, each plant assigns a number to each LER that it submits. This number is assigned sequentially within each calendar year to every LER submitted by the plant. At the end of the calendar year the plant LER number will start again with 001 for the next year.

Report Type. LERs are either (a) two-week reports, (b) 30-day reports, or (c) other. This information was coded and stored for possible future use. This information was not found in the NSIC data base's NUREG/CR-2000.

SUMMARY OF RESULTS

As was mentioned earlier, there were 21,021 LERs screened for this report. Of these LERs, 169 were selected for use in this analysis. From these 169 LERs, 212 one-line descriptions were derived and entered into the data base. However, 48 of the one-line descriptions have "test not performed" as the failure mode and hence do not represent true faults. Of the remaining 164 one-line descriptions, 109 describe events involving a total of 120 batteries. The remaining 55 one-line descriptions describe events involving a total of 61 battery chargers.

The 212 one-liners used to produce sorts on the various data base fields are contained in Appendices C through I as follows:

<u>Appendix</u>	<u>Field</u>
C	NSSS vendor
D	Component
E	System
F	Failure mode
G	Failure cause
H	Human factors
I	Activity resulting in discovery

In addition, events found within the scope of both this report and the report, "A Probabilistic Safety Analysis of DC Power Supply Requirements for Nuclear Power Plants" (NUREG-0666),¹ are listed in Appendix J for those who wish to compare the two reports. Data concerning manufacturer, voltage rate, repair time, flagging, and cell number can be found in Appendix K.

Summary tables were generated from the 164 one-line descriptions having failure modes other than "test not performed." Tables 1 through 10 summarize battery and battery charger events by component and, respectively, the following fields: NSSS vendor, plant, year, system, failure mode, failure cause, failure subcause, activity resulting in discovery, type of event, and event classification. Table 11 presents the codes used in the one-liners and will precede each sort of the one-line

data records. These sheets provide a convenient reference for decoding the one-line data records.

Because subjective judgments had to be made regarding pertinence of recorded events, and because some component faults may not be recorded in the LERs, the component faults summarized in this report should be interpreted as only tentative gross indicators of true fault trends. The individual analyst must validate the applicability of the LER faults for specific uses.

TABLE 1. SUMMARY OF BATTERY AND BATTERY CHARGER EVENTS BY COMPONENT AND NSSS VENDOR

NSSS VENDOR	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Batteries</u>						
Babcock & Wilcox	5	4.24%	--	--	5	4.16%
Combustion Engineering	4	3.53%	3	42.85%	7	5.83%
Westinghouse	29	25.66%	2	28.57%	31	25.83%
General Electric	75	66.37%	2	28.57%	77	64.16%
COMPONENT SUBTOTALS	<u>113</u>		<u>7</u>	TOTAL	<u>120</u>	
<u>Battery Chargers</u>						
Babcock & Wilcox	2	4.00%	--	--	2	3.27%
Combustion Engineering	6	12.00%	1	9.09%	7	11.47%
Westinghouse	19	38.00%	6	54.54%	25	40.98%
General Electric	23	46.00%	4	36.36%	27	44.26%
COMPONENT SUBTOTALS	<u>50</u>		<u>11</u>	TOTAL	<u>61</u>	

TABLE 2. SUMMARY OF BATTERY AND BATTERY CHARGER EVENTS BY COMPONENT AND PLANT

PLANT	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Batteries</u>						
Babcock & Wilcox Plants						
Crystal River 3	1	0.88%	--	--	1	0.83%
Davis-Besse 1	3	2.65%	--	--	3	2.50%
Oconee 3	1	0.88%	--	--	1	0.83%
Combustion Engineering Plants						
Calvert Cliffs 1	2	1.76%	--	--	2	1.66%
Calvert Cliffs 2	--	--	1	14.28%	1	0.83%
Millstone 2	1	0.88%	--	--	1	0.83%
Palisades	1	0.88%	2	28.57%	3	2.50%
Westinghouse Plants						
Beaver Valley 1	3	2.65%	--	--	3	2.50%
Donald C. Cook 2	2	1.76%	--	--	2	1.66%
Joseph M. Farley 1	7	6.19%	--	--	7	5.83%
McGuire 1	1	0.88%	--	--	1	0.83%
North Anna 1	1	0.88%	--	--	1	0.83%
North Anna 2	2	1.76%	--	--	2	1.66%
H. B. Robinson 2	2	1.76%	--	--	2	1.66%
Salem 1	2	1.76%	--	--	2	1.66%
Salem 2	1	0.88%	--	--	1	0.83%
Sequoyah 1	3	2.65%	--	--	3	2.50%
Surry 2	2	1.76%	--	--	2	1.66%
Trojan	1	0.88%	--	--	1	0.83%

TABLE 1. (CONT.)

PLANT	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
Batteries (Cont.)						
Westinghouse Plants (Cont.)						
Turkey Point 3	1	0.88%	--	--	1	0.83%
Yankee Rowe	1	0.88%	--	--	1	0.83%
Zion 1	--	--	2	28.57%	2	1.66%
General Electric Plants						
Browns Ferry 1	1	0.88%	--	--	1	0.83%
Browns Ferry 2	1	0.88%	1	14.28%	2	1.66%
Big Rock Point	45	39.82%	--	--	45	37.50%
Brunswick 1	2	1.76%	--	--	2	1.66%
Dresden 1	2	1.76%	--	--	2	1.66%
Dresden 3	2	1.76%	1	14.28%	3	2.50%
Edwin I. Hatch 2	8	7.07%	--	--	8	6.66%
James A. Fitzpatrick	8	7.07%	--	--	8	6.66%
Monticello	1	0.88%	--	--	1	0.83%
Oyster Creek 1	1	0.88%	--	--	1	0.83%
Peach Bottom 3	1	0.88%	--	--	1	0.83%
Quad-Cities 1	1	0.88%	--	--	1	0.83%
Vermont Yankee	2	1.76%	--	--	2	1.66%
COMPONENT SUBTOTALS	<u>113</u>		<u>7</u>		TOTAL <u>120</u>	

TABLE 2. (CONT.)

PLANT	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Battery Chargers</u>						
Babcock & Wilcox Plants						
Three Mile Island 2	2	4.00%	--	--	2	3.27%
Combustion Engineering Plants						
Arkansas Nuclear One 2	3	6.00%	1	9.09%	4	6.55%
Palisades	1	2.00%	--	--	1	1.63%
St. Lucie	2	4.00%	--	--	2	3.27%
Westinghouse Plants						
Beaver Valley 1	5	10.00%	--	--	5	8.19%
Donald C. Cook 1	--	--	1	9.09%	1	1.63%
Haddam Neck	2	4.00%	--	--	2	3.27%
Indian Point 3	2	4.00%	2	18.18%	4	6.55%
Joseph M. Farley 1	--	--	1	9.09%	1	1.63%
Prairie Island 1	1	2.00%	--	--	1	1.63%
Prairie Island 2	1	2.00%	--	--	1	1.63%
Salem 1	2	4.00%	--	--	2	3.27%
Salem 2	1	2.00%	1	9.09%	2	3.27%
Surry 2	2	4.00%	--	--	2	3.27%
Turkey Point 3	1	2.00%	--	--	1	1.63%
Yankee Rowe	2	4.00%	--	--	2	3.27%
Zion 1	--	--	1	9.09%	1	1.63%

TABLE 2. (CONT.)

PLANT	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
Battery Chargers (Cont.)						
General Electric Plants						
Big Rock Point	1	2.00%	--	--	1	1.63%
Brunswick 1	1	2.00%	--	--	1	1.63%
Cooper Station	2	4.00%	1	9.09%	3	4.91%
Duane Arnold	1	2.00%	--	--	1	1.63%
Dresden 1	1	2.00%	--	--	1	1.63%
Dresden 3	1	2.00%	--	--	1	1.63%
Edwin I. Hatch 1	2	4.00%	--	--	2	3.27%
Edwin I. Hatch 2	6	12.00%	--	--	6	9.83%
Monticello	--	--	1	9.09%	1	1.63%
Oyster Creek 1	1	2.00%	--	--	1	1.63%
Pilgrim 1	3	6.00%	--	--	3	4.91%
Quad-Cities 2	1	2.00%	1	9.09%	2	3.27%
Vermont Yankee	3	6.00%	1	9.09%	4	6.55%
	COMPONENT SUBTOTALS	<u>50</u>	<u>11</u>	TOTAL	<u>61</u>	

TABLE 3. SUMMARY OF BATTERY AND BATTERY CHARGER EVENTS BY COMPONENT AND YEAR

YEAR	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Batteries</u>						
1976	17	15.04%	1	14.28%	18	15.00%
1977	25	22.12%	1	14.28%	26	21.66%
1978	15	13.27%	--	--	15	12.50%
1979	9	7.96%	1	14.28%	10	8.33%
1980	20	17.69%	--	--	20	16.66%
1981	<u>27</u>	23.89%	<u>4</u>	57.14%	<u>31</u>	25.83%
	COMPONENT SUBTOTALS	<u>113</u>	<u>7</u>		TOTAL <u>120</u>	
<u>Battery Chargers</u>						
1976	8	16.00%	1	9.09%	9	14.75%
1977	8	16.00%	1	9.09%	9	14.75%
1978	9	18.00%	2	18.18%	11	18.03%
1979	4	8.00%	2	18.18%	6	9.83%
1980	8	16.00%	1	9.09%	9	14.75%
1981	<u>13</u>	26.00%	<u>4</u>	36.36%	<u>17</u>	27.86%
	COMPONENT SUBTOTALS	<u>50</u>	<u>11</u>		TOTAL <u>61</u>	

TABLE 4. SUMMARY OF BATTERY AND BATTERY CHARGER EVENTS BY COMPONENT AND SYSTEM

SYSTEM	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Batteries</u>						
PWR Systems						
Area Monitor System	1	0.88%	--	--	1	0.83%
Emergency Diesel Generator	6	5.30%	--	--	6	5.00%
Fire Protection System	5	4.42%	--	--	5	4.16%
Feedwater System	1	0.88%	--	--	1	0.83%
Unknown/Unspecified/Other	12	10.61%	3	42.85%	15	12.50%
Station Batteries/Chargers	6	5.30%	2	28.57%	8	6.66%
Service Water Building Batteries/Chargers	7	6.19%	--	--	7	5.83%
BWR Systems						
Area Monitor System	1	0.88%	--	--	1	0.83%
Emergency Diesel Generator	3	2.65%	--	--	3	2.50%
Fire Protection System	9	7.96%	--	--	9	7.50%
Neutron Monitoring Battery	2	1.76%	1	14.28%	3	2.50%
Unknown/Unspecified/Other	8	7.07%	1	14.28%	9	7.50%
Automatic (Reactor) Depressurization (ADS)	34	30.08%	--	--	34	28.33%
Special Use Batteries	1	0.88%	--	--	1	0.83%
Station Batteries/Chargers	10	8.84%	--	--	10	8.33%
Switchyard Batteries/Chargers	1	0.88%	--	--	1	0.83%
Uninterruptible Power System (UPS)	6	5.30%	--	--	6	5.00%
COMPONENT SUBTOTALS	<u>113</u>		<u>7</u>		TOTAL <u>120</u>	

TABLE 4. (CONT.)

SYSTEM	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Battery Chargers</u>						
PWR Systems						
Fire Protection System	2	4.00%	--	--	2	3.27%
Unknown/Unspecified/Other	23	46.00%	6	54.54%	29	47.54%
Station Batteries/Chargers	2	4.00%	--	--	2	3.27%
Service Water Building Batteries/Chargers	--	--	1	9.09%	1	1.63%
BWR Systems						
Fire Protection System	1	2.00%	--	--	1	1.63%
Unknown/Unspecified/Other	7	14.00%	4	36.36%	11	18.03%
Station Batteries/Chargers	9	18.00%	--	--	9	14.75%
Switchyard Batteries/Chargers	3	6.00%	--	--	3	4.91%
Uninterruptible Power System (UPS)	3	6.00%	--	--	3	4.91%
COMPONENT SUBTOTALS	<u>50</u>		<u>11</u>		TOTAL <u>61</u>	

TABLE 5. SUMMARY OF BATTERY AND BATTERY CHARGER EVENTS BY COMPONENT AND FAILURE MODE

FAILURE MODE	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Batteries</u>						
Reduced Capability	68	60.17%	--	--	68	56.66%
No Output	31	27.43%	6	85.71%	37	30.83%
Unknown/Unspecified/Other	--	--	1	14.28%	1	0.83%
Maintenance Replacement	14	12.38%	--	--	14	11.66%
COMPONENT SUBTOTALS	<u>113</u>		<u>7</u>	TOTAL	<u>120</u>	
<u>Battery Chargers</u>						
Reduced Capability	6	12.00%	--	--	6	9.83%
No Output	33	66.00%	9	81.81%	42	68.85%
Unknown/Unspecified/Other	3	6.00%	--	--	3	4.91%
High Current/Voltage Output	2	4.00%	1	9.09%	3	4.91%
Low Output Voltage	3	6.00%	1	9.09%	4	6.55%
High AC Ripple on DC Output	1	2.00%	--	--	1	1.63%
Maintenance Replacement	2	4.00%	--	--	2	3.27%
COMPONENT SUBTOTALS	<u>50</u>		<u>11</u>	TOTAL	<u>61</u>	

TABLE 6. SUMMARY OF BATTERY AND BATTERY CHARGER EVENTS BY COMPONENT AND FAILURE CAUSE

FAILURE CAUSE	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Batteries</u>						
Unknown	7	6.19%	--	--	7	5.83%
Personnel Operation	--	--	3	42.85%	3	2.50%
Personnel Maintenance	1	0.88%	2	28.57%	3	2.50%
Defective Procedures	2	1.76%	1	14.28%	3	2.50%
Normal Wear/Natural End of Life	2	1.76%	--	--	2	1.66%
Low Specific Gravity	41	36.28%	--	--	41	34.16%
High Electrolyte Solution Level	4	3.53%	--	--	4	3.33%
Low Electrolyte Solution Level	13	11.50%	--	--	13	10.83%
Insufficient Charge	4	3.53%	--	--	4	3.33%
Defective/Weak Cells	14	12.38%	--	--	14	11.66%
Short Circuit	3	2.65%	--	--	3	2.50%
Faulty Cable/Connectors	13	11.50%	1	14.28%	14	11.66%
Charger Malfunction	9	7.96%	--	--	9	7.50%
COMPONENT SUBTOTALS	<u>113</u>		<u>7</u>	TOTAL	<u>120</u>	

TABLE 6. (CONT.)

FAILURE CAUSE	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Battery Chargers</u>						
Unknown	14	28.00%	--	--	14	22.95%
Personnel Operation	--	--	3	27.27%	3	4.91%
Extreme Environment	--	--	1	9.09%	1	1.63%
Mechanical Malfunction	2	4.00%	--	--	2	3.27%
Piece Part Failure	7	14.00%	2	18.18%	9	14.75%
Voltage Regulator Malfunction	7	14.00%	3	27.27%	10	16.39%
Current Limiter Malfunction	4	8.00%	--	--	4	6.55%
Current Controller Malfunction	2	4.00%	--	--	2	3.27%
Voltage Limiter Malfunction	2	4.00%	1	9.09%	3	4.91%
Thermal Overload Protection	2	4.00%	--	--	2	3.27%
Cooling Fan/Ventilation Malfunction	1	2.00%	--	--	1	1.63%
Charge Control Malfunction	2	4.00%	--	--	2	3.27%
Charge Control Timer Malfunction	1	2.00%	--	--	1	1.63%
Rectifier Problem	5	10.00%	--	--	5	8.19%
Faulty Cable/Connectors	1	2.00%	1	9.09%	2	3.27%
COMPONENT SUBTOTALS	<u>50</u>		<u>11</u>	TOTAL	<u>61</u>	

TABLE 7. SUMMARY OF BATTERY AND BATTERY CHARGER EVENTS BY COMPONENT AND FAILURE SUBCAUSE

FAILURE SUBCAUSE	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Batteries</u>						
Personnel Operation	1	2.17%	--	--	1	2.13%
Personnel Maintenance	11	23.9%	1	100.00%	12	25.53%
Design/Fabrication/Construction/ Quality Control	7	15.22%	--	--	7	14.89%
Defective Procedures	3	6.52%	--	--	3	6.38%
Corrosion	3	6.52%	--	--	3	6.38%
Normal Wear/Natural End of Life	3	6.52%	--	--	3	6.38%
Electrical malfunction	1	2.17%	--	--	1	2.13%
Piece Part Failure	3	6.52%	--	--	3	6.38%
Low Specific Gravity	1	2.17%	--	--	1	2.13%
Stratification	1	2.17%	--	--	1	2.13%
Defective/Weak Cells	8	17.39%	--	--	8	17.02%
Electrolyte Dilution	3	6.52%	--	--	3	6.38%
Charger Malfunction	1	2.17%	--	--	1	2.13%
COMPONENT SUBTOTALS	<u>46</u> ^a		<u>1</u>	TOTAL	<u>47</u> ^a	

TABLE 7. (CONT.)

FAILURE SUBCAUSE	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Battery Chargers</u>						
Personnel Operation	1	4.76%	2	66.67%	3	12.50%
Design/Fabrication/Construction/ Quality Control	2	9.52%	1	33.33%	3	12.50%
Extreme Environment	4	19.05%	--	--	4	16.67%
Normal Wear/Natural End of Life	2	9.52%	--	--	2	8.33%
Electrical Malfunction	1	4.76%	--	--	1	4.17%
Piece Part Failure	3	14.29%	--	--	3	12.50%
Current Limiter Malfunction	3	14.29%	--	--	3	12.50%
Current Controller Malfunction	1	4.76%	--	--	1	4.17%
Short Circuit	1	4.76%	--	--	1	4.17%
Faulty Cable/Connectors	3	14.29%	--	--	3	12.50%
COMPONENT SUBTOTALS	<u>21</u> ^b		<u>3</u>	TOTAL	<u>24</u> ^b	

a. 47 rather than 120 battery events are described in this table because no failure subcause was indicated in the LERs for the other 73 events.

b. 24 rather than 61 battery charger events are described in this table because no failure subcause was indicated in the LERs for the other 37 events.

TABLE 8. SUMMARY OF BATTERY AND BATTERY CHARGER EVENTS BY COMPONENT AND ACTIVITY RESULTING IN DISCOVERY

ACTIVITY	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Batteries</u>						
Testing (Unspecified)	26	23.00%	--	--	26	21.66%
Normal Load Testing	4	3.53%	--	--	4	3.33%
Monthly Testing	22	19.46%	--	--	22	18.33%
Weekly Testing	8	7.07%	--	--	8	6.66%
Quarterly Testing	7	6.19%	--	--	7	5.83%
Refueling Testing	1	0.88%	--	--	1	0.83%
Maintenance	3	2.65%	2	28.57%	5	4.16%
Normal Plant Operation	32	28.31%	2	28.57%	34	28.33%
Unknown	10	8.84%	3	42.85%	13	10.83%
COMPONENT SUBTOTALS	<u>113</u>		<u>7</u>	TOTAL	<u>120</u>	
<u>Battery Chargers</u>						
Testing (Unspecified)	5	10.00%	2	18.18%	7	11.47%
Normal Load Testing	6	12.00%	--	--	6	9.83%
18 Month Testing	5	10.00%	--	--	5	8.19%
Maintenance	2	4.00%	1	9.09%	3	4.91%
Normal Plant Operation	29	48.00%	8	72.72%	37	60.65%
Unknown	3	6.00%	--	--	3	4.91%
COMPONENT SUBTOTALS	<u>50</u>		<u>11</u>	TOTAL	<u>61</u>	

TABLE 9. SUMMARY OF BATTERY AND BATTERY CHARGER EVENTS BY COMPONENT AND TYPE OF EVENT

TYPE OF EVENT	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Batteries</u>						
Random	73	64.60%	--	--	73	60.83%
Common Cause	18	15.92%	--	--	18	15.00%
Recurring	22	19.46%	--	--	22	18.33%
Command Fault	--	--	1	14.28%	1	0.83%
Common Cause Command Fault	--	--	6	85.71%	6	5.00%
COMPONENT SUBTOTALS	<u>113</u>		<u>7</u>	TOTAL	<u>120</u>	
<u>Battery Chargers</u>						
Random	41	82.00%	--	--	41	67.21%
Common Cause	1	2.00%	--	--	1	1.63%
Recurring	8	16.00%	--	--	8	13.11%
Command Fault	--	--	5	45.45%	5	8.19%
Common Cause Command Fault	--	--	6	54.54%	6	9.83%
COMPONENT SUBTOTALS	<u>50</u>		<u>11</u>	TOTAL	<u>61</u>	

TABLE 10. SUMMARY OF BATTERY AND BATTERY CHARGER EVENTS BY COMPONENT AND EVENT CLASSIFICATION

EVENT CLASSIFICATION	FAILURES		COMMAND FAULTS		TOTALS	
	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	NUMBER OF EVENTS	PERCENTAGE OF COMPONENT SUBTOTAL	EVENTS	PERCENTAGE OF COMPONENT TOTAL
<u>Batteries</u>						
Frequency	40	35.39%	7	100.00%	47	39.16%
Age	11	9.73%	--	--	11	9.16%
Unknown	62	54.86%	--	--	62	51.66%
COMPONENT SUBTOTALS	<u>113</u>		<u>7</u>	TOTAL	<u>120</u>	
<u>Battery Chargers</u>						
Frequency	7	14.00%	8	72.72%	15	24.59%
Age	4	8.00%	--	--	4	6.55%
Unknown	39	78.00%	3	27.27%	42	68.85%
COMPONENT SUBTOTALS	<u>50</u>		<u>11</u>	TOTAL	<u>61</u>	

TABLE 11. CODES USED IN ONE-LINE DESCRIPTIONS

NSSS VENDOR		FAILURE CAUSE		TYPE EVENT	
CODE	DESCRIPTION	CODE	DESCRIPTION	CODE	DESCRIPTION
B	BABCOCK & WILCOX	00	UNKNOWN	B	RECURRING COMMON CAUSE
C	COMBUSTION ENGINEERING	01	PERSONNEL OPERATION	C	COMMON CAUSE
M	WESTINGHOUSE	02	PERSONNEL MAINTENANCE	R	RECURRING
G	GENERAL ELECTRIC	03	PERSONNEL TESTING	S	COMMAND FAULT
-----		04	DESIGN/FABRICATION/CONSTRUCTION/QUALITY CONTROL	T	RECURRING COMMAND FAULT
EVENT CLASSIFICATION		05	DEFECTIVE PROCEDURES	U	COMMON CAUSE COMMAND FAULT
-----		06	EXTREME ENVIRONMENT	V	RECURRING COMMON CAUSE COMMAND FAULT
CODE	DESCRIPTION	08	CORROSION	BLANK	RANDOM
D	FREQUENCY	10	NORMAL WEAR/NATURAL END OF LIFE	-----	
T	AGE	11	ELECTRICAL MALFUNCTION	ACTIVITY RESULTING IN DISCOVERY	
U	UNKNOWN	12	MECHANICAL MALFUNCTION	CODE	DESCRIPTION
-----		13	PIECE PART FAILURE	A	TESTING(UNSPECIFIED)
COMPONENT		14	LOW SPECIFIC GRAVITY	B	NORMAL LOAD TESTING
-----		15	STRATIFICATION	C	MONTHLY TESTING
CODE	DESCRIPTION	16	HIGH ELECTROLYTE SOLUTION LEVEL	D	WEEKLY TESTING
BA	BATTERY	17	LOW ELECTROLYTE SOLUTION LEVEL	E	QUARTERLY TESTING
BC	BATTERY CHARGER	18	INSUFFICIENT CHARGE	F	REFUELING TESTING
-----		19	DEFECTIVE/WEAK CELLS	G	18 MONTH TESTING
		20	VOLTAGE REGULATOR MALFUNCTION	H	3 YEAR TESTING
		21	CURRENT LIMITER MALFUNCTION	M	MAINTENANCE
		22	CURRENT CONTROLLER MALFUNCTION	N	NORMAL PLANT OPERATION
		23	VOLTAGE LIMITER MALFUNCTION	R	RECORDS REVIEW
		24	THERMAL OVERLOAD PROTECTION	U	UNKNOWN
		25	COOLING FAN/VENTILATION MALFUNCTION	-----	
		26	CHARGE CONTROL MALFUNCTION	FLAGGING FIELD	
		27	CHARGE CONTROL TIMER MALFUNCTION	CODE	DESCRIPTION
		28	RECTIFIER PROBLEM	A	FAILED COMPONENT CAUSED AN ACCIDENT
		30	SHORT CIRCUIT	B	COMPONENT FAILED TO MITIGATE AN ACCIDENT
		31	ELECTROLYTE DILUTION	C	SAFETY SIGNIFICANT
		32	FAULTY CABLE/CONNECTORS	D	FAIL # NOT KNOWN
		34	CHARGER MALFUNCTION	E	CELL # NOT KNOWN
-----		FAILURE MODE		F	FAIL # AND CELL # NOT KNOWN
		CODE	DESCRIPTION	N	FROM NSIC DATA BASE
		A	REDUCED CAPABILITY		
		BB	NO OUTPUT		
		BC	UNKNOWN/UNSPECIFIED/OTHER		
		D	HIGH CURRENT/VOLTAGE OUTPUT		
		QU	LOW OUTPUT VOLTAGE		
		R	HIGH AC RIPPLE ON DC OUTPUT		
		T	MAINTENANCE REPLACEMENT		
		T	TEST NOT PERFORMED		

TABLE II. (continued)

SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
AM	- AREA MONITOR SYSTEM
DB	- EMERGENCY DIESEL GENERATOR
ES	- ENGINEERED SAFETY FEATURE
FP	- FIRE PROTECTION SYSTEM
FW	- FEEDWATER SYSTEM
NM	- NEUTRON MONITORING BATTERY
NN	- UNKNOWN/UNSPECIFIED/OTHER
SA	- AUTOMATIC (REACTOR) DEPRESSURIZATION (ADS)
SP	- SPECIAL USE BATTERIES
ST	- STATION BATTERIES/CHARGERS
SW	- SERVICE WATER BUILDING BATTERIES/CHARGERS
SY	- SWITCHYARD BATTERIES/CHARGERS
UP	- UNINTERRUPTIBLE POWER SYSTEM (UPS)

REFERENCES

1. P. W. Baranowsky, A. M. Kolaczowski, M. A. Fedele, A Probabilistic Safety Analysis of DC Power Supply Requirements for Nuclear Power Plants, NUREG-0666, April 1981.
2. Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File, NUREG-0161, July 1977.

APPENDIX A
DISCUSSION OF THE CAUSES OF VARIATIONS IN LER REPORTING

APPENDIX A
DISCUSSION OF THE CAUSES OF VARIATIONS IN LER REPORTING

There are generally two criteria used by the utilities to determine reporting requirements for failures; these are: (a) the technical specifications for each individual plant and (b) the LER reporting guide, Regulatory Guide 1.16.^{A-1} The technical specifications for plants licensed prior to January 1, 1976, were independently written by individual plants without any planned uniformity among plants. All plants licensed after this date use standardized technical specifications, which helped to create more uniform reporting. Table A-1 shows those plants that have standard technical specifications. In addition to technical specification standardization, since 1976 there have been changes in the rules that govern LER reporting. These changed reporting rules, and the standardized technical specifications, are expected to result in more uniform LER reporting after January 1, 1976. But pre-1976 LER data, as well as LER data reported by plants which are not subject to standard technical specifications, will show considerable variation.

The above "mechanical" causes for LER reporting variations are explicable and expected. However, there are additional reporting variations. Differences in interpretation of the rules for submitting LER reports cause some variation. Also, variation is caused by the difficulty of determining the extent of safety and non-safety systems and therefore, by the questions of what failures are or are not required to be reported. Finally, variation can be caused by the degree of importance assigned to the LER reports by management of the individual utilities. We have seen variation in both the quantity and quality of LERs submitted by similar plants, where one would expect more uniform reporting. We have attributed these variations to the reasons given above.

The one thing that seems to have most hindered the development of uniform reporting is the lack of agreement about the purpose of an LER. Many people feel that LERs are intended to highlight problem areas within

the safety systems. Some feel that the LERs ought to be used to highlight generic problem areas. Many of these same people do not feel that these uses are compatible with the need to determine failure rate information.

These differing viewpoints may confuse the individual responsible for reporting events. Hence, we have the variations in the quality and quantity of LERs received by the Nuclear Regulatory Commission. For further discussion of the causes of variations in LER reporting, see Reference A-2.

TABLE A-1. FACILITY OPERATING LICENSES ISSUED WITH STANDARD TECHNICAL SPECIFICATIONS

Facility	Vendor	Issue Date
Crystal River Unit 3	B	December 3, 1976
Davis-Besse Unit 1	B	April 22, 1977
Three Mile Island Unit 2	B	February 8, 1978
Arkansas Unit 2	C	July 18, 1978
Calvert Cliffs Unit 1 (STS Conversion)	C	February 11, 1977
Calvert Cliffs Unit 2	C	August 13, 1976
Millstone Unit 2	C	August 1, 1975
St. Lucie Unit 1	C	March 1, 1976
Beaver Valley Unit 1	W	January 30, 1976
D. C. Cook Unit 1	W	October 25, 1974
D. C. Cook Unit 2	W	December 23, 1977
Joseph Farley Unit 1	W	June 25, 1977
Joseph Farley Unit 2	W	March 31, 1981
McGuire Unit 1	W	July 8, 1981
North Anna Unit 1	W	November 21, 1977
North Anna Unit 2	W	August 21, 1980
Salem Unit 1	W	August 13, 1976
Salem Unit 2	W	May 20, 1981
Sequoyah Unit 1	W	September 17, 1980
Sequoyah Unit 2	W	September 15, 1981
Trojan	W	November 21, 1975
Yankee Rowe (STS Retrofit)	W	January 1, 1977
Brunswick Unit 1	G	September 8, 1976
Brunswick Unit 2 (STS Conversion)	G	November 23, 1977
Hatch Unit 2	G	June 13, 1978

REFERENCES

- A-1. "Reporting of Operating Information--Appendix A Technical Specifications," U.S. Nuclear Regulatory Commission Regulatory Guide 1.16, Revision 4, August 1975.
- A-2. Gerald L. Boner and Harvey W. Hanners, Enhancement of Onsite Emergency Diesel Generator Reliability, University of Dayton Research Institute, NUREG/CR-0660, 1979, pp. I-4,5, IV-5,6, V-10, and V-13.

APPENDIX B
GENERAL PLANT INFORMATION

TABLE B-1. GENERAL PLANT INFORMATION

BARCOCK & WILCOX

Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Criticality Date	Date of Commercial Operation	Location (State)	Architect/Engineer	Constructor
AR1	Arkansas Nuclear One 1 (50-313)	850	08/06/74	12/19/74	AR	Bechtel	Bechtel
CR3	Crystal River 2 (50-302)	825	01/14/77	03/13/77	FL	Gilbert Associates	J. A. Jones Construction
DB1	Davis-Besse 1 (50-316)	906	08/12/77	07/31/78	OH	Bechtel	Bechtel
OE1	Oconee 1 (50-269)	837	04/19/73	07/15/73	SC	Duke & Bechtel	Duke Power
OE2	Oconee 2 (50-270)	887	11/11/73	09/09/74	SC	Duke & Bechtel	Duke Power
OE3	Oconee 3 (50-287)	837	09/05/74	12/16/74	SC	Duke & Bechtel	Duke Power
RS1	Rancho Seco (50-312)	918	09/16/74	04/17/75	CA	Bechtel	Bechtel
T11	Three Mile Island 1 ^a (50-289)	819	06/05/74	09/02/74	PA	Gilbert Associates	United Engineers & Constructors
T12	Three Mile Island 2 ^a (50-320)	906	03/28/78	12/30/78	PA	Burns & Roe	United Engineers & Constructors

TABLE E-1. (Continued)

COMBUSTION ENGINEERING							
Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Criticality Date	Date of Commercial Operation	Location (State)	Architect/Engineer	Constructor
AR2	Arkansas Nuclear One 2 (50-368)	912	12/05/78	03/26/80	AR	Bechtel	Bechtel
CC1	Calvert Cliffs 1 (50-317)	845	10/07/74	05/08/75	MD	Bechtel	Bechtel
CC2	Calvert Cliffs 2 (50-318)	845	11/30/76	04/01/77	MD	Bechtel	Bechtel
FC1	Fort Calhoun (50-285)	478	08/06/73	06/20/74	NB	Gibbs, Hill, Durham & Richardson	Gibbs, Hill, Durham & Richardson
MI2	Millstone 2 (50-336)	870	10/17/75	12/16/75	CT	Bechtel	Bechtel
MY1	Maine Yankee (50-309)	825	10/23/72	12/28/72	ME	Stone & Webster	Stone & Webster
PA1	Palisades (50-255)	805	05/24/71	12/31/71	MI	Bechtel	Bechtel
SL1	St. Lucie (50-335)	802	04/22/76	12/21/76	FL	Ebasco	Ebasco

TABLE B-1. (Continued)

WESTINGHOUSE							
Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Criticality Date	Date of Commercial Operation	Location (State)	Architect/Engineer	Constructor
BV1	Beaver Valley 1 (50-334)	852	05/10/76	10/01/76	PA	Stone & Webster	Stone & Webster
DC1	Donald C. Cook 1 (50-315)	1054	01/18/75	08/27/75	MI	American Electrical Power Service Corporation	American Electrical Power Service Corporation
DC2	Donald C. Cook 2 (50-316)	1100	03/10/78	07/01/78	MI	American Electrical Power Service Corporation	J. A. Jones Construction
HN1	Haddam Neck (50-213)	582	07/24/67	01/01/68	CT	Stone & Webster	Stone & Webster
IP2	Indian Point 2 (50-247)	873	05/22/73	08/01/74	NY	United Engineers & Constructors	Westinghouse Development Corp.
IP3	Indian Point 3 (50-286)	965	04/06/76	08/30/76	NY	United Engineers & Constructors	Westinghouse Development Corp.
JF1	Joseph M. Farley 1 (50-348)	829	08/09/77	12/01/77	AL	Southern Services, Inc.	Bechtel
JF2	Joseph M. Farley 2 (50-364)	829	05/05/81	07/30/81	AL	Southern Services, Inc.	Bechtel
KE1	Kewaunee (50-305)	535	03/07/74	06/16/74	WI	Pioneer Services & Engineering	Pioneer Services & Engineering
MG1	McGuire 1 (50-369)	1180	09/08/81	12/01/81	NC	Duke Power	Duke Power
NA1	North Anna 1 (50-338)	907	04/05/78	06/06/78	VA	Stone & Webster	Stone & Webster
NA2	North Anna 2 (50-339)	907	06/12/80	12/14/80	VA	Stone & Webster	Stone & Webster
PR1	Prairie Island 1 (50-282)	530	12/01/73	12/16/73	MN	Fluor Pioneer, Inc.	Northern States Power Company
PR2	Prairie Island 2 (50-306)	530	12/17/74	12/21/74	MN	Fluor Pioneer, Inc.	Northern States Power Company
PT1	Point Beach 1 (50-266)	497	11/02/70	12/21/70	WI	Bechtel	Bechtel

TABLE B-1. (Continued)

WESTINGHOUSE (Continued)							
Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Criticality Date	Date of Commercial Operation	Location (State)	Architect/Engineer	Constructor
PT2	Point Beach 2 (50-301)	497	05/30/72	10/01/72	WI	Bechtel	Bechtel
RG1	Robert E. Ginna (50-244)	470	11/08/69	06/01/70	NY	Gilbert Associates	Bechtel
R02	H. B. Robinson 2 (50-261)	700	09/20/70	03/07/71	SC	Ebasco	Ebasco
SA1	Salem 1 (50-272)	1090	12/11/76	06/30/77	NJ	Public Services & Gas Co.	United Engineers & Constructors
SA2	Salem 2 (50-311)	1115	08/08/80	10/13/81	NJ	Public Services & Gas Co.	United Engineers & Constructors
SE1	Sequoyah 1 (50-327)	1128	07/05/80	07/01/81	TN	Tennessee Valley Authority	Tennessee Valley Authority
SE2	Sequoyah 2 (50-328)	1148	11/05/81	NA	TN	Tennessee Valley Authority	Tennessee Valley Authority
S01	San Onofre 1 (50-206)	436	06/14/67	01/01/68	CA	Bechtel	Bechtel
SU1	Surry 1 (50-280)	788	07/01/72	12/22/72	VA	Stone & Webster	Stone & Webster
SU2	Surry 2 (50-281)	788	03/07/73	05/01/73	VA	Stone & Webster	Stone & Webster
TR1	Trojan (50-344)	1130	12/15/75	05/20/76	OR	Bechtel	Bechtel
TU3	Turkey Point 3 (50-250)	693	10/20/72	12/14/72	FL	Bechtel	Bechtel
TU4	Turkey Point 4 (50-251)	693	06/11/73	09/07/73	FL	Bechtel	Bechtel
YR1	Yankee Rowe (50-029)	175	08/19/60	07/01/61	MA	Stone & Webster	Stone & Webster
Z11	Zion 1 (50-295)	1040	06/19/73	12/31/73	IL	Sargent & Lundy	Commonwealth Edison
Z12	Zion 2 (50-304)	1040	12/24/73	09/17/74	IL	Sargent & Lundy	Commonwealth Edison

TABLE B-1. (Continued)

GENERAL ELECTRIC							
Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Criticality Date	Date of Commercial Operation	Location (State)	Architect/Engineer	Constructor
BF1	Browns Ferry 1 (50-259)	1065	08/17/73	03/01/74	AL	Tennessee Valley Authority	Tennessee Valley Authority
BF2	Browns Ferry 2 (50-260)	1065	07/20/74	03/01/75	AL	Tennessee Valley Authority	Tennessee Valley Authority
BF3	Browns Ferry 3 (50-296)	1065	08/08/76	03/01/77	AL	Tennessee Valley Authority	Tennessee Valley Authority
BP1	Big Rock Point (50-155)	72	09/27/62	03/29/63	MI	Bechtel	Bechtel
BR1	Brunswick 1 (50-325)	821	10/08/76	03/18/77	NC	United Engineers & Constructors	Brown & Root
BR2	Brunswick 2 (50-324)	821	03/20/75	11/03/75	NC	United Engineers & Constructors	Brown & Root
CO1	Cooper Station (50-298)	778	02/21/74	07/07/74	NB	Burns & Roe	Burns & Roe
DA1	Duane Arnold (50-331)	538	03/23/74	02/01/75	IA	Bechtel	Bechtel
DR1	Dresden 1 ^b (50-010)	200	10/15/59	07/04/60	IL	Bechtel	Bechtel
DR2	Dresden 2 (50-237)	794	01/07/70	06/09/70	IL	Sargent & Lundy	United Engineers & Constructors
DR3	Dresden 3 (50-249)	794	01/31/71	11/16/71	IL	Sargent & Lundy	United Engineers & Constructors
EN1	Edwin I. Hatch 1 (50-321)	777	09/12/74	12/31/75	GA	Bechtel	Georgia Power Co.
EN2	Edwin I. Hatch 2 (50-366)	784	07/04/78	09/05/79	GA	Bechtel	Georgia Power Co.
FP1	James A. Fitzpatrick (50-333)	821	11/17/74	07/28/75	NY	Stone & Webster	Stone & Webster
MI1	Millstone 1 (50-245)	660	10/26/70	03/01/71	CT	Ebasco	Ebasco

TABLE B-1. (Continued)

GENERAL ELECTRIC							
Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Criticality Date	Date of Commercial Operation	Location (State)	Architect/Engineer	Constructor
MD1	Monticello (50-263)	545	12/10/70	06/30/71	MD	Bechtel	Bechtel
NM1	Nine Mile Point 1 (50-220)	620	09/05/69	12/01/69	NY	Niagara Mohawk Power Corporation	Stone & Webster
OC1	Oyster Creek 1 (50-219)	650	05/03/69	12/01/69	NJ	Burns & Roe	Burns & Roe
PB2	Peach Bottom 2 (50-277)	1065	09/16/73	07/05/74	PA	Bechtel	Bechtel
PB3	Peach Bottom 3 (50-278)	1065	08/07/74	12/23/74	PA	Bechtel	Bechtel
PI1	Pilgrim 1 (50-293)	655	06/16/72	12/01/72	MA	Bechtel	Bechtel
QC1	Quad-Cities 1 (50-254)	789	10/18/71	02/18/73	IL	Sargent & Lundy	United Engineers & Constructors
QC2	Quad-Cities 2 (50-265)	789	04/26/72	03/10/73	IL	Sargent & Lundy	United Engineers & Constructors
VY1	Vermont Yankee (50-271)	514	03/24/72	11/30/72	VT	Ebasco	Ebasco

a. Plant shutdown since 03/28/79.

b. Plant shutdown since 10/31/79.

APPENDIX C
ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS
SORTED BY NSSS VENDOR

CODES USED IN LER ONE-LINE DESCRIPTIONS

NSSS VENDOR

CODE DESCRIPTION

B - BABCOCK & WILCOX
 C - COMBUSTION ENGINEERING
 W - WESTINGHOUSE
 G - GENERAL ELECTRIC

EVENT CLASSIFICATION

CODE DESCRIPTION

D - FREQUENCY
 T - AGE
 U - UNKNOWN

COMPONENT

CODE DESCRIPTION

BA - BATTERY
 BC - BATTERY CHARGER

FAILURE CAUSE

CODE DESCRIPTION

00 - UNKNOWN
 01 - PERSONNEL OPERATION
 02 - PERSONNEL MAINTENANCE
 03 - PERSONNEL TESTING
 04 - DESIGN/FABRICATION/CONSTRUCTION/QUALITY CONTROL
 05 - DEFECTIVE PROCEDURES
 06 - EXTREME ENVIRONMENT
 08 - CORROSION
 10 - NORMAL WEAR/NATURAL END OF LIFE
 11 - ELECTRICAL MALFUNCTION
 12 - MECHANICAL MALFUNCTION
 13 - PIECE PART FAILURE
 14 - LOW SPECIFIC GRAVITY
 15 - STRATIFICATION
 16 - HIGH ELECTROLYTE SOLUTION LEVEL
 17 - LOW ELECTROLYTE SOLUTION LEVEL
 18 - INSUFFICIENT CHARGE
 20 - DEFECTIVE/WEAK CELLS
 21 - VOLTAGE REGULATOR MALFUNCTION
 22 - CURRENT LIMITER MALFUNCTION
 23 - CURRENT CONTROLLER MALFUNCTION
 24 - VOLTAGE LIMITER MALFUNCTION
 25 - THERMAL OVERLOAD PROTECTION
 26 - COOLING FAN/VENTILATION MALFUNCTION
 27 - CHARGE CONTROL MALFUNCTION
 28 - CHARGE CONTROL TIMER MALFUNCTION
 29 - RECTIFIER PROBLEM
 30 - SHORT CIRCUIT
 31 - ELECTROLYTE DILUTION
 32 - FAULTY CABLE/CONNECTORS
 34 - CHARGER MALFUNCTION

FAILURE MODE

CODE DESCRIPTION

A - REDUCED CAPABILITY
 B - NO OUTPUT
 C - UNKNOWN/UNSPECIFIED/OTHER
 D - HIGH CURRENT/VOLTAGE OUTPUT
 E - LOW OUTPUT VOLTAGE
 G - HIGH AC RIPPLE ON DC OUTPUT
 M - MAINTENANCE REPLACEMENT
 T - TEST NOT PERFORMED

TYPE EVENT

CODE DESCRIPTION

B - RECURRING COMMON CAUSE
 C - COMMON CAUSE
 D - RECURRING
 F - COMMAND FAULT
 G - RECURRING COMMAND FAULT
 J - COMMON CAUSE COMMAND FAULT
 U - RECURRING COMMON CAUSE COMMAND FAULT
 BLANK - RANDOM

ACTIVITY RESULTING IN DISCOVERY

CODE DESCRIPTION

A - TESTING(UNSPECIFIED)
 B - NORMAL LOAD TESTING
 C - MONTHLY TESTING
 D - WEEKLY TESTING
 E - QUARTERLY TESTING
 F - REFUELING TESTING
 G - 18 MONTH TESTING
 H - 3 YEAR TESTING
 M - MAINTENANCE
 N - NORMAL PLANT OPERATION
 R - RECORDS REVIEW
 U - UNKNOWN

FLAGGING FIELD

CODE DESCRIPTION

A - FAILED COMPONENT CAUSED AN ACCIDENT
 B - COMPONENT FAILED TO MITIGATE AN ACCIDENT
 C - SAFETY SIGNIFICANT
 D - FAIL # NOT KNOWN
 E - CELL # NOT KNOWN
 F - FAIL # AND CELL # NOT KNOWN
 N - FROM NSIC DATA BASE

SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
AM	- AREA MONITOR SYSTEM
DB	- EMERGENCY DIESEL GENERATOR
ES	- ENGINEERED SAFETY FEATURE
FP	- FIRE PROTECTION SYSTEM
FW	- FEEDWATER SYSTEM
NM	- NEUTRON MONITORING BATTERY
NN	- UNKNOWN/UNSPECIFIED/OTHER
SA	- AUTOMATIC (REACTOR) DEPRESSURIZATION (ADS)
SP	- SPECIAL USE BATTERIES
ST	- STATION BATTERIES/CHARGERS
SW	- SERVICE WATER BUILDING BATTERIES/CHARGERS
SY	- SWITCHYARD BATTERIES/CHARGERS
UP	- UNINTERRUPTIBLE POWER SYSTEM (UPS)

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY NSSS VENDOR

NSSS	PLANT	CONTROL NUMBER	EVENT DATE	COMP	SYSTEM	FAULT CODE	ACTIVITY TYPE	CLASS	FAIL #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
B CP3	017166A	011277	BA NN T03	P U D	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED					
B CP3	017166B	020277	BA NN T03	R U D	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED					
B CP3	017166C	020977	BA NN T03	R U D	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED					
B CP3	021165	040578	BA NN T02	R V D	WRONG BTRY CELLS MONITORED FOR WEEKLY BATT SURV	PERSONNEL NOT FOLLOWING PROCEDURES					
B CP3	034100	071481	BA ST B3002	N C D	STATION BATTERY SHORTED DURING MAINTENANCE	PERSONNEL ERROR. CAUSED REACTOR TRIP					
B DB1	020448	011978	BA ST A1415	E U	IN BTRY CELL 32 ELECTROLYTE S.G. DECRS .003 NOT	ELEC. STRAT. DUE TO LO BTRY LOADING					
B DB1	021587	042778	BA FP A17	N U	4 CELLS OF ENGINE BTRY W/ ELECTROLYTE BELOW PLATE	ELEC. ADDED BROUGHT CELLS UP TO NORMAL					
B DB1	027362	090578	BA ST T02	R U D	STATION BATTERIES WMLY SURV TEST NOT DONE ON TIME	MISUNDERSTANDING BTWN PERSONNEL					
B DB1	025397	020879	BA FP A17	D U	ELECTROL LEVEL IN 4 CELLS FOUND LO IN DSL ENG STA-	RTING BTRY. DIESEL STILL STARTED					
B DF3	015532	081876	BA NN T05	R U D	125-VDC INSTR & CNTRL BATTERIES NOT LOAD TESTED	DFCTV PRDCT WRONG DATA IN SURV PRINTOUT					
B DF3	022183	072778	BA NN B33	B U	SNOKE FROM 1 TERMINAL OF 1&C BATTERY 3CB.	TERMINAL DFCTV/CHNCTNS FOUND DEFECTIVE					
B T12	023084*	111278	BC NN B15	B U	2 CHRGRS 2-2A/B FUSE BLEW NO CHRGR FOR BANK 2-25B	DEFECTIVE GATING FILTER MODULES					
C AP2	026489	052779	BA ST T03	R U D	SURVEILLANCE NOT PERFORMED ON STATION BATTERIES	PERSONNEL OVERSIGHT					
C AP2	026904	080579	BC NN B1306	N C D	BATTERY CHARGER 2031 FAILED. DC OUTPUT LAMP SOCK-	LET BURNED UP DUE TO HIGH HEAT, VOLT, DLSI					
C AP2	027808	121179	BC NN P21	N S D	BATTERY CHARGER 2032 AC BREAKER TRIPPED	CURRENT SURGED WHEN SHIFTING TO FLOAT					
C AP2	039245*	110581	BC NN B00	N U	2 OUTPUT BREAKER OF BATTERY CHARGER 2034 TRIPPED OP-	EN TWICE. NO CAUSE COULD BE FOUND					
C CC1	021533	050378	BA NN A00	A U	125 VDC BTRY 22 CELL 54 ICV BELOW MIN VOLTAGE	CAUSE UNKNOWN					
C CC1	037262	050681	BA NN M20	A U	VOLT OF CELL 18 OF 125 VDC BATTERY 12 FOUND .08V -	BELOW MINIMUM. FULL CAPACITY AVAILAEE					
C CC2	017344	021777	BA NN B01	N S D	#11 125 VDC BATTERY INADVERTENTLY TAKEN OUT OF SE-	RVICE. SUPERVISOR GAVE PERMISSION					
C M12	026979	080379	BA NN M20	A U	VARIOUS CELLS REPLACED IN 201B BTRY (4 CELLS)	REDUCTION IN CELL VOLT. FULL CAPACITY					
C PA1	016178	102076	BC NN E2201	N D	DC BUS-2 VOLTG FELL VOLTG ON ASSOC AC BUSES FELL	CURR LMR & OUTPUT BRKR SETTING ERRONEOUS					
C PA1	025917	040479	BA ST B2005	A C D	2 CELLS IN STATION BATTERY #2 BURST WHILE TAKING -	VOLTAGE READINGS. FULL CAPACITY AVAI					
C PA1	036000*	010681	BA ST B02	U U D	2 OUTPUT BREAKER FOR BOTH STATION BATTERIES WERE OP-	ENED FOR 1 HOUR. PERSONNEL ERROR					
C S11	020069	121677	BC NN B00	N D	OUTPUT LOST FROM "AB" BATTERY CHARGER	POWER SUPPLY BKR TRIPPED FOR NO REASON					
C S11	037962	062481	BC NN T02	R U D	SURVEILLANCE REQUIREMENTS NOT MET ON "AB" BATTERY-	CHARGER. MISINTERPRETATION OF TECH SPEC					
C S11	038775	091881	BC NN B24	A R U	1A BATTERY CHARGER SHUTDOWN ON HIGH VOLTAGE	HIGH VOLTAGE DEVICE FOUND DEFECTIVE					
W BV1	016357	102476	BA NN M00	A U	VOLTAGE DECREASED IN CELL 4B BY MORE THAN 0.05V	UNKNOWN. CELL 4B FROM BTRY 3, 1650 A.H.					
W BV1	017119A	020477	BA ST T03	R U D	SURVEILLANCE TEST NOT PERFORMED ON #3 & #4 STATIO-	N BATTERIES. PERSONNEL ERROR					
W BV1	017119B	020477	BC ST T03	R U D	SURVEILLANCE TEST NOT PERFORMED ON CHARGERS ASSOC-	ATED WITH #3 & #4 STATION BTRY. PERSON					
W BV1	021043	032078	BC NN E2713	N U	DFCR #4 DC BUS VOLTAGE DUE TO A FAULTY BTRY CHRGR	FAILD COLLECTR RESISTR IN CHRGR CNTRL CKT					
W BV1	022136	080478	BC ST B00	B U	#4 STATION BTRY CHRGR OUTPUT BRKR TRIPPED	IMPROPR OP OF CKTBRK, CAUSE OF TRP UNKNOWN					
W BV1	028147	092179	BA NN M2C10	A T	CELL #6 OF BATTERY NO. 1 COULD NOT HOLD ORIGINAL -	VOLTAGE. FULL BATTERY CAPACITY AVAIL.					

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY NSSS VENDOR

UNIVZ	PLANT	CONTROL NUMBER	EVENT DATE	COMP	REMARKS	FAILURE ORDER	ACTION TYPE	CLASS	FAILURE #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
W	RV1	037757	061581	BC	NN	B2506	N	R	D	#2 BATTERY CHARGER OUTPUT BREAKER FAILED OPEN	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
W	RV1	038347	080581	BC	NN	B2506	N	R	D	#2 BATTERY CHARGER OUTPUT BREAKER TRIPPED O/P	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
W	RV1	038825	091081	BC	ST	B33	N	U		#4 STATION BATTERY CHARGER TAKEN OUT OF SERVICE	RAD ELECTRICAL CONNECTION IN OUTPUT
W	RV1	039154	101781	BA	NN	M20	E	R	U	2 OF 60 CELLS VOLTAGE FOUND DROPPED BY .05 VDC	NO CAUSE GIVEN, BATTERY HAD FULL CAPACITY
W	DC1	025643	032379	BC	NN	DD1	N	U	D	125 VDC EQUALIZING CHARGE TOO HIGH, FAILED INVERT-	-EP, CAUSED SCRAM AND ST. NO CAUSE
W	DC2	021633	060778	BA	NN	A14	A	U		CD PLANT BTRY CELL 89 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W	DC2	021632	061578	BA	NN	A14	A	U		AD PLANT BTRY CELL 35 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W	DC2	037127	101981	BA	NN	T05	R	U	D	SURVEILLANCE NOT PERFORMED ON "N" TRAIN BATTERY	PROCEDURE LACKED SIGNOFF
W	HNI	014608A	042576	BC	NN	D2833	N	U		BTRY CHARGER A WENT INTO OVERCHARGE	FAULTY CNTCT ON CHARGER CONTROL TIMER
W	HNI	014608B	042576	BC	NN	D2122	N	U		VOLTG REG SPIKING TO 200 AMPS THEN SHUTTING OFF	FAULTY PHASING CRD IN CURRENT LIMITER CKT
W	IP3	014709	051076	BC	NN	B2630	A	U		BTRY CHRGR TROUBLE ALARMED CHARGER FAN HAD TRPD	AC FAN MTR INOP EXPOSED WIRE BLEW A FUSE
W	IP3	015138	060876	BC	NN	B13	A	S	U	# 31 BTRY CHRGR AC BRKR TRIPD BATT CHRGR INOP	PRESSURE SENSOR FAILED TRIPPING BREAKER
W	IP3	036207	012481	BC	NN	B2123	N	U		OUTPUT FROM CHARGER #32 DISCOVERED DROPPING	VOLTAGE AND CURRENT CONTROLLER REPLACED
W	IP3	038257	070681	BC	NN	B13	N	S	U	BATTERY CHARGER #32 DISCOVERED TRIPPED	FAILED DP AIR FLOW SENSOR SWITCH
W	JF1	021235A	041878	BA	SW	B00	E	U		2 CELLS IN SW BLDG "A" BATT BANK 1 FAILED T.S. REQ	CAUSE COULD NOT BE DETERMINED
W	JF1	021235B	041878	BA	SW	B00	E	U		2 CELLS IN SW BLDG B BATT BANK 2 FAILED T.S. PFD	CAUSE COULD NOT BE DETERMINED
W	JF1	027181	090679	BA	NN	T03	R	U	D	QUARTERLY AUXILIARY BUILDING BATTERY VERIFICATION-	-NOT PERFORMED ON TIME. PERSONNEL
W	JF1	032332A	081280	BA	SW	A14	A	R	U	SW BLDG B BTRY SYS LOW SPECIFIC GRAVITY	BATT PLACED ON EQUALIZE & S.G. ACCEPTABLE
W	JF1	032332B	082580	BA	SW	A14	A	R	U	SW BLDG B BTRY SYS LOW SPECIFIC GRAVITY	NO EXTERNAL CAUSE FOR LOW SPECIFIC GRAV
W	JF1	032504	082580	BC	SW	B24	N	S	U	SW B DC DISTRIBUTION SYS INOP NO OUTPUT FROM BATT-	-CHGR 4. HV S/D RELAY ACTUATED
W	JF1	032687	091180	BA	SW	A1404	A	D		SW BLDG "A" BATT SYS LO BATT CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN
W	JF1	033007	102180	BA	SW	A1404	A	D		SW "A" BTRY SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN
W	JF1	033163	102880	BA	SW	A1404	A	D		SW BLDG "A" BATT SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM PROX/ACID RES/POST SEAL DESIGN
W	HG1	039186	101981	BA	ST	A3308	N	T		CELL TO CELL RESISTANCE IN 3 CELLS FOUND HIGH	CORROSION OF TERMINAL CONNECTIONS
W	NA1	026545	062879	BA	DB	T05	R	U	D	7 DAY SURVEILLANCE OF EMERGENCY DIESEL GENERATOR -	-BATTERIES EXCEEDED INTERVAL. PROCEDURAL
W	NA1	026656	073179	BA	DB	T05	R	U	D	DIESEL GENERATOR BATTERIES SURVEILLANCE NOT DONE	TIME LAG IN IMPLEMENTING NEW PROCEDURES
W	NA1	036491A	022881	BA	ST	T02	R	U	D	18 MONTH SURVEILLANCE ON D.C. DISTRIBUTION SRVTC-	-F SYSTEM NOT DONE. PERSONNEL OVERSIGHT
W	NA1	036491B	022881	BC	ST	T02	R	U	D	18 MONTH SURVEILLANCE ON D.C. DISTRIBUTION SRVTC-	-B SYSTEM NOT DONE. PERSONNEL OVERSIGHT
W	NA1	171672	120181	BA	DB	A1410	A	T		1J EMERGENCY D/G INOP CELL S.G. BELOW 1.2	D/G BATTERY NEAR END OF USEFUL LIFE
W	NA2	036466*	021881	BA	DB	M14	E	U	2	BATTERIES FOR 2J & 2H DIESEL GENERATORS FAILED SU-	-RVILLANCE TEST. 4 CELLS REPLACED
W	NA2	036417	022081	BA	DB	T05	R	U	D	DATA FROM TWO TESTS ON 2J DIESEL BATTERY FOUND NO-	-T USABLE. NOT COMPARED WITH INITIAL CON
W	PP1	026268	053179	BA	FP	T05	R	U	D	DIESEL DRIVEN WEEKLY BATTERY INSPECTION NOT DONE	PROCEDURES WERE DEFECTIVE

55

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY NISS VENDOR

SY	CONTROL NUMBER	EVENT DATE	UNIT	STATUS	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
M	PRI 030917	033180	BA ST 102	R U D	INDIVIDUAL FLOAT CELL VOLT MEAS NOT DONE IN STATION	-ON BATTERY TEST. PERSONNEL OVERSIGHT
M	PRI 033222	110580	RC NN A2911	A U	#12 BTRY CHGRP FAIL TO PROVIDE NORMAL OUTPUT	FIRING CAPD B NOT PROVIDING PULSE TO SCR
M	PRI 014599	041476	RC NN B2133	B U	#12 BATTERY CHARGER FAILED DISABLED "B" DC POWER	VOLTAGE CNTRL CFD LOOSE IN ITS SOCKET
M	PRI 015515	071076	BA NN 802	M U	BATTERY B LEADS WERE REMOVED RENDERING BATT INOP	PERS FAILED TO COMPLY W/ T.S. 3-7
M	PRI 021898	071678	RA ST B3311	N U	PLASTIC TOP OF 2 STATION "A" BATT CELLS ON FIRE	RESISTING HEATG OF STRAP-CELL TERMINAL
M	SAL 020738A	020178	BA NN A34	N U	1C 125V BATTERY VOLTAGE LOW	1C1,1C2 BATT CHARGER D.C. BRKRS TRPD
M	SAL 020738B	020178	BC NN 800	N U	2 1C1,1C2 BATT CHARGER D.C. BRKRS TRIPPED	UNKNOWN CAUSE
M	SAL 032162	022180	BA FP 102	R U D	92 DAY 6.18 MON SURV NOT DONE ON 24 V STARTG BATT	ELECTRICIAN NOT COMPLETING JOB
M	SAL 038834	091881	BA FP B33	N U	BATTERY CABLE CLAMP FOUND ARCING AND CRACKED	CLAMP WAS REPLACED ON #2 FIRE PUMP BTRY
M	SAL 038319	072481	BC NN B2101	N U D	2C1 BATTERY CHARGER DISCOVERED TRIPPED. VOLTAGE -	--SETTING WAS INCORRECTLY SET
M	SAL 038327	081281	RC NN B24	N U	2B1 BATTERY CHARGER WOULD NOT PICK UP 28 VDC LOAD	HIGH VOLTAGE CUT-OUT ACTUATED
M	SAL 038683	090681	BA AM 800	N U	RAD MONITOR 2P12A BATTERY PACK FAILED	NO CAUSE GIVEN
M	SE1 032338	080780	BA UB B10	N U	D/G BTRY 1B-B CELL 51 SHORTED AND FAILED	NO CAUSE GIVEN
M	SE1 032342A	081280	BA UB B05	U D	D/G BTRY 1B-B CELLS 49,50,51 DISCHARGED	INADEQUATE PROCEDURE
M	SE1 032342B	081380	BA UB B05	U D	D/G BTRY 1B-B CELLS 49,50,51 DISCHARGED	INADEQUATE PROCEDURE
M	SU2 167141	081981	BC FP B13	N U	SMOKE DET SYS INOP BTRY CHGRP LOST POWER	FAULTY POWER SUPPLY CARD IN CHARGER
M	SU2 038470	090681	BA FP B00	U U	SOMKE DETECTOR BATTERY FOUND NOT TO TAKE A CHARGE	NO CAUSE GIVEN
M	SU2 038936A	100181	BA FP B34	A D	SMOKE DETECTOR BATTERY FAILED	CHARGER NOT CHARGING BATTERY
M	SU2 038936B	100181	BC FP 800	A U	BATTERY CHARGER FOR SMOKE DETECTOR BATTERY FAILED	NO CAUSE GIVEN
M	TP1 014583	032476	BA ES 105	R U D	ESF DC PWR SUPPLIES SURV REQ PERFORMD AT WRNG FREQ	PROCEDURE DID NOT USE FREQ REQ BY T.S.
M	TP1 020885	031778	BA NN 102	R U D	125 VDC ELECTRICAL SYS OP NOT VERIFIED WK OF 2-26	MAINT PERS FAILED TO INSURE SURV COMPLETED
M	TP1 025211A	011979	BA NN 103	R U D	125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL
M	TP1 025211B	011979	BC NN 103	R U D	125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL
M	TP1 032622	090380	BA FW B20	N U	DIESEL-DRIVEN AFWP FAIL TO START FROM MANUAL SIG	FAILED STARTING BATTERY
M	TU3 022018A	122277	BA ST 101	U U D	EQUALIZING CHARGES ON STATION BATTERIES NOT PERFORMED	PERSONNEL ERROR, FULL CAPACITY AVL
M	TU3 022018B	122977	BA ST 101	U U D	EQUALIZING CHARGES ON STATION BATTERIES NOT PERFORMED	PERSONNEL ERROR, FULL CAPACITY AVL
M	TU3 033500A	121180	BC NN C00	N U	PROBLEMS WITH 4B 125 VDC BATTERY CHARGER	NO CAUSE GIVEN
M	TU3 033500B	121180	BA NN 134	N U T	4B 125 VDC BATT ODS, TECH SPEC EXCEEDED	PROBLEM W/ ASSOCIATED BTRY CHARGER
M	TU3 039363	111281	BA NN B20	A R U	"3A" 125 VDC FAILED TO HOLD A CHARGE	BEING EVALUATED W/ MANUFACTURER
M	YRI 019476A	101477	BC NN B1210	N R T	NO. 2 BATTERY CHARGER TAKEN OUT OF SERVICE	FAILED BEARING
M	YRI 019476B	101477	BC NN 101	N U D	NO. 1 BATTERY CHARGER CROSS TIED TO NO. 2 BATTERY	OVERSIGHT CAUSE LCD STATED IN TECH SPEC
M	YRI 0194640	110577	BC NN B1210	N R T	NO. 1 BATTERY CHARGER TAKEN OUT OF SERVICE	FAILED BEARING DUE TO NORMAL WEAR

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY NSSS VENDOR

WAGON	PLANT	CONTROL NUMBER	EVENT DATE	COMP	SYSTEM	FAULT CODE	ACTIVITY TYPE	CLASS	FAIL #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
W	YR1	019861	120577	BA	ST	A20	E	U		CELL VOLTAGE ON CELL 18 OF BANK 1 FOUND LOW	NO CAUSE FOUND, CELL REPLACED
W	Z11	171128A	121281	BA	NN	R01	M	U	D	UNIT 2 212 BATTERY TAKEN OOS ERRONEOUSLY	LICENSED OPERATOR ERROR
W	Z11	171128B	121281	BC	NN	R01	M	U	D	UNIT 2 212 CHARGER TAKEN OOS ERRONEOUSLY	LICENSED OPERATOR ERROR
W	Z11	172130	121581	BA	NN	C05	U	U	U	EQUALIZING CHARGE NOT PLACED ON BATTERY 112	PROCEDURE NOT CLEAR ON COMMUNICATIONS
G	RF1	038085	072281	BA	NN	A20	U	U	U	250 VOLT MAIN BATTERY TAKEN OOS TO BYPASS A CRACK-	-ED CELL.
G	RF2	015394	070976	BA	NM	B3302	M	U	D	NEUTRON MONITORING BATTERY 2A MADE INOPERABLE	CNCR BRKWN OFF A CELL POST PERS ERROR
G	RF2	029671	041979	BA	SP	B3302	N	C	D	BROKEN TERMINAL DISCOVERED ON S/D BOARD "M" BTRY	PERSUNNEL ERROR. ALSO AFFECTED UNIT 1
G	RP1	019248A	063076	BC	ST	B29	N	U	U	STATION BATTERY CHARGER FAILED	DEFECTIVE SILICON RECTIFIERS
G	RP1	019248B	063076	BA	ST	A18	N	D	D	LOAD ON BTRY REDUCED VOLTAGE & SPECIFIC GRAVITY	STATION BATTERY CHARGER HAD FAILED
G	BP1	019326A	072276	BA	SA	A17	C	U	U	RDS BATTERY D PILOT CELL LOW ELECTROLYTE LEVEL	EXACT CAUSE UNKNOWN
G	BP1	019326B	072276	BA	SA	A1432	C	D	D	RDS BATTERY D PILOT CELL HAD LOW SPECIFIC GRAVITY	ADDITION OF WATER POSSIBLE CAUSE
G	BP1	019327A	072876	BA	SA	A17	C	U	U	RDS BTRY C PILOT CELL LOW ELECTROLYTE LEVEL	UNKNOWN CAUSE
G	BP1	019327B	072976	BA	SA	T14	C	U	D	RDS BTRY C PILOT CELL RDG LD SPECIFIC GRAVITY	DECTV PROC SPECIFIC GRAVITY READ TOO SOON
G	RP1	019444	081276	BA	DB	B33	N	T	T	EMERGENCY DIESEL GENERATOR DID NOT START DUE TO L-	-NOISE BATTERY CONNECTION.
G	BP1	016073B	100376	BA	SA	A17	A	U	U	RDS D BTRY PILOT & 3 OTHER CELLS LD ELECTROLYTE -	-LEVEL. UNKNOWN CAUSE
G	BP1	016073A	100476	BA	SA	A1405	A	D	D	RDS D BTRY PILOT & 3 OTHER CELLS LD SPEC GRAVITY	INCOMPLETE ELECTROLYTE MIXING
G	BP1	016305A	102176	BA	SA	A14	D	U	U	RDS "A" BTRY PILOT CELL 55 LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BP1	016459	110476	BA	SA	A14	C	U	U	RDS B PILOT CELL LOW SPECIFIC GRAVITY	UNKNOWN CAUSE
G	BP1	016305B	112176	BA	SA	A14	D	U	U	RDS "A" BTRY PILOT CELL 55 LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BP1	016584	120276	BA	SA	A14	D	U	U	RDS B BTRY PILOT CELL 27 LD SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BP1	017023	120976	BA	SA	A14	D	U	U	RDS B ONE CELL LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BP1	017024*	010477	BA	SA	M14	A	R	U	2 B CELLS SPECIFIC GRAVITY FOUND BELOW 1.2. EVALUA-	-TION REVEALED ADEQUATE CAPACITY
G	BP1	017464	022477	BA	SA	M14	C	R	U	RDS BATTERY B HAD ONE CELL BELOW MINIMUM SPECIFIC-	-GRAVITY. ADEQUATE CAPACITY AVAILABLE
G	BP1	017463	031777	BA	SA	M14	C	R	U	SPECIFIC GRAVITY FOUND LOW IN 5 CELLS OF RDS BTRY-	-"A". ADEQUATE CAPACITY AVAILABLE
G	BP1	017704*	033077	BA	UP	B3304	N	C	D	4 NO OUTPUT FROM ALL UPS BATTERY BANKS	CONNECTORS NOT TIGHTENED DURING INSTAL
G	BP1	018096A	042177	BA	SA	M14	C	R	U	RDS BATTERY B, CELL 27 FOUND TO HAVE LOW SPECIFIC -	-GRAVITY OF 1.191. FULL CAPACITY AVAIL
G	BP1	018096B	042777	BA	SA	M14	C	U	U	SPECIFIC GRAVITY OF LD MARGINAL CELLS ADJUSTED OF-	-RDS BATTERY B. FULL CAPACITY AVAILAEE
G	BP1	018462A	061677	BA	SA	A17	U	R	U	WATER ADDED TO CELL 27 OF RDS BATTERY "B"	NO CAUSE GIVEN FOR LOW WATER LEVEL
G	BP1	018462B	061677	BA	SA	T1432	C	V	D	SPECIFIC GRAVITY OF CELL 27 OF RDS BATTERY B LOW	WATER ADDED THEN TESTED TOO SOON
G	BP1	019025A	082977	BA	FP	B3302	N	D	D	DIESEL FIRE PUMP "A" BATTERY FOUND WITH NO OUTPUT	CONNECTORS NOT TIGHTENED
G	BP1	019025B	082977	BA	FP	B00	N	U	U	DIESEL FIRE PUMP "B" BATTERY FOUND FAILED WITH NO-	-OUTPUT. DISCHR WITH NO APPARENT CAUSE
G	BP1	019472A	092977	BA	SA	A17	U	R	U	WATER ADDED TO CELL 12 OF RDS BATTERY "A"	NO CAUSE GIVEN FOR LOW WATER LEVEL

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY NSSS VENDOR

NSSS	PLANET	CONTROL NUMBER	EVENT DATE	CDMV	SYSTEM	FAILURE CODE	ACTIVITY TYPE	CLASS #	FAILURE #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G BP1	019472B	092977	BA SA	A1432	C R D					SPECIFIC GRAVITY OF CELL 12 OF RDS BATTERY "A" LOW	WATER ADDED, CHARGE INSUFFICIENT TO MIX
G BP1	019542A	100R77	BA SA	A17	U R U					WATER ADDED TO 3 CELLS OF RDS BATTERY "D"	NO CAUSE GIVEN FOR LOW WATER LEVEL
G BP1	019542B	102077	BA SA	A1432	C R D					SPECIFIC GRAVITY OF 3 CELLS OF RDS BATTERY "D" LOW	WATER ADDED, MIXING WAS INADEQUATE
G BP1	020176	122277	BA SA	A14	C R U					SPECIFIC GRAVITY ON RDS BATTERY "A", CELL 12 LOW	EQUALIZING CHARGE FOR 8 HOURS CORRECTED
G BP1	021307	050478	BA FP	A17	D U					FIRE PUMP DIESEL STARTG BTRY A CELLS 1,3,5 LD	ELECTROLYTE SOLN. EXACT CAUSE UNKNOWN
G BP1	021519	052578	BA FP	A1705	D D					FIRE PUMP DIESEL STARTG BTRY "A" CELLS 2,4,6 LD	ELECTROLYTE SOLN. INADQ MAINTENANCE PROC
G BP1	022664	083178	BA SA	A14	C R U					RDS BATTERY A, CELL 12 LD SPECIFIC GRAVITY READING	EXACT CAUSE UNKNOWN
G BP1	027985	110179	BA SA	A1420	C U					SPECIFIC GRAVITY OF CELL 48 OF RDS BATTERY C LOW	CELL REPLACED, WOULD NOT TAKE EQUAL CHARGE
G BP1	030237	012480	BA SA	A1420	C U					RDS C BTRY CELL 14 LOW SPECIFIC GRAVITY RDG	DEFECTIVE CELL REPLACED
G BP1	031176	050180	BA SA	A1420	C U					RDS BTRY "A" CELL 2 LOW SPECIFIC GRAVITY RDG	CELL DID NOT RESPOND ADQ TO EQUALIZG CHR
G BP1	031848	071080	BA SA	A1420	C U					RDS C BTRY CELLS 35,54 LOW SPECIFIC GRAVITY RDG	CELL DID NOT RESPOND ADQ TO EQUALIZG CHR
G BP1	032023	071880	BA SA	A20	D U					RDS C BTRY PILOT CELL UNIT-9 INTERNAL RESISTANCE	-INCRS. CAUSE UNKNOWN
G BP1	032297	080780	BA SA	A14	C U					RDS C BTRY CELLS 38,39,56 LOW SPECIFIC GRAVITY	VENDOR RECOM INCRS IN FLOAT VOLTAGE LEVEL
G BP1	032656	091180	BA SA	A1420	C U					RDS D BATTERY CELL 12 LOW SPECIFIC GRAVITY RDG	CELL DID NOT ADQ RESPOND TO EQUALIZG CHR
G BP1	033544	121180	BA SA	A1402	C D					21 CELLS OF RDS "A" BATTERY LOW SPECIFIC GRAVITY	CELL TERMINALS INADQ CLEANED BY MAINT PER
G BP1	033637	122380	LA NN	T02	R U D					DC BATTERY MONTHLY TESTS OVERDUE	INADQ ADMIN CONTROLS & PERSONNEL ERROR
G BP1	037338	010281	BA SA	A1420	C R U					RDS CH D BATTERY CELL 56 HAD LOW SG, WOULD NOT RFS-	-POND TO EQUALIZING CHARGE.
G BP1	038112	081581	PA SA	A1602	A C D					FOUND PILOT CELL IN CH A RDS POWER SUPPLY WITH A -	-HIGH ELEC LEVEL. POSSIBLY OVERFILLED
G BP1	038592	083181	BA ST	A2014	C D					LOW SG IN CELL 43 OF ST BTRY, CELL FOUND CRACKED.	-THIS LEAD TO DILUTION, CRACKED WHEN HEVED
G BP1	038785	091581	BA SA	A1420	C U					"A" RDS BTRY CELL #5 LOW SPECIFIC GRAVITY	CELL DIDN'T RESPOND ADQ TO EQUALIZG CHR
G BP1	019389	102177	BC NN	B2206	B U					BATT CHRGR DC OUTPT FUSE FAILED WHEN CHRGR BATT 2B-2	HT CURR/TEMP CAUSD SOLDERD LINKG SEPARATE
G BP1	025637A	032579	BA NN	A3308	B R T					BATTERY 1B2 VOLTAGE FELL TO 102.5V THEN ROSE TO -	-118V. CORRODED AND LOOSE BTRY CONNECT
G BP1	025637B	032774	BA NN	A3308	B R T					BTRY 1B1 VOLTAGE FELL TO 96.8V THEN ROSE TO 118V	CORRODED AND LOOSE BTRY CONNECTORS
G BR2	014651	021276	BA NN	T05	R U D					MONTHLY INSTEAD OF QUARTERLY BATTERY P.T. PERFORMD	WRONG P.T. SCHEDULED BY MISTAKE
G C01	022101A	062778	BC NN	B2333	N T					1A 250V BTRY CHRGR TIE BREAKER TRIPPED	PDDR CNNECT CNTCS IN CURRENT MODULE
G C01	022101B	062778	BC NN	B3304	N U D					1A 250V BTRY CHRGR INPUT BREAKER TRIPPED	LOOSE CNNECTN AT CHRGR INPUT BRKR PHASE A
G C01	037646	050581	BC ST	G29	B U					HIGH RIPPLE FROM BATTERY CHARGER WHICH FAILED INV-	-FRTER 1A. FAILED SCR
G C01	037938	052881	BA ST	T03	R U D					SG TESTS FOR 125V 1A6B AND 250V 1B NOT PERFORMED -	-PROPERLY. PERSONNEL USED WRONG HYDROM
G DA1	030982	041780	BA NN	T02	R U D					WKLY BATT SURV DOCUMENTATION NOT COMPLETED	PERSONNEL ERROR-NONLIC. OPERATIONS PERS
G DA1	171665	120881	BC NN	E00	N U					BATTERY CHARGER OUTPUT INCORRECT	UNKNOWN
G DP1	018553A	072977	BA FP	B3413	N C D	2				DIESEL FIRE PUMP BATTERIES FAILED TO START DIESEL	FAILED FUSE FROM BATTERY CHARGER CIRCUIT
G DP1	018553B	072977	BC FP	B22	N U					FUSE FOUND BLOWN IN DIESEL FIRE PUMP BATTERY CHAR-	-GR.

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY NISS VENDOR

N S S	P L A N T	C O N T R O L N U M B E R	E V E N T D A T E	C O M P	S Y S T E M	F A I L U R E C O D E	A C T I V I T Y	F A I L T Y P E	C L A S S	F A I L #	F A I L U R E M O D E D E S C R I P T I O N	F A I L U R E C A U S E D E S C R I P T I O N
G	DR2	039116	102181	BA	NN	T01	R	U	D		QUARTERLY STORAGE BATTERY SURVEILLANCE DONE 3 DAY--S LATE. OVERSIGHT BY OPERATING SHIFT	
G	DR3	016265A	101876	BA	NN	A34	A	D			BATTERY IN A DEGRADED CONDITION	CHARGER SUBJECTED BTRY TO "DEEP CYCLING"
G	DR3	016265B	101876	BC	NN	C00	A	U			CHARGER SUBJECTED BTRY TO "DEEP CYCLING"	UNKNOWN CAUSE
G	DR3	020853	032878	BA	NN	A10	F	R	T		24748 V BTRY FAILED THE REFUELING OUTAGE DISCHRG--TEST. 4 CELLS REPLCD NAT'L END OF LIFE	
G	DR3	025951	042479	BA	NN	B01	N	U	D		UNIT 2'S BATTERY NOT RETURNED TO NORMAL LINEUP	BREAKER COULD HAVE BEEN SHUT AT ANY TIME
G	DR3	036569	030381	BA	NN	T01	R	U	D		WEEKLY STORAGE BATTERY SURVEILLANCE DONE 4 DAYS L--ATE. OVERSIGHT BY OPERATING SHIFT	
G	EN1	021475*	060478	BC	ST	M1304	M	D	2		HEAT-SENSITIVE XSTR ON BATT CHRGR FIRING MODUL CRD SHOULD BE A NON-HEAT-SENSITIVE TRANSISTOR	
G	EN1	021719	062778	BA	DB	T02	R	U	D		WKLY PILOT CELL SURV OF IC D/G BTRY NOT COMPLET--FD ON TIME. PERSONNEL OVERSIGHT	
G	EN1	027782	112679	BA	NN	T03	R	U	D		CELL SURVEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT
G	EN2	022208	081678	BA	NN	T02	R	U	D		WKLY PILOT CELL SURV OF PLANT BATT NOT COMPLETED--ON TIME. NOTICES ROUTED TO ABSENT PERS	
G	EN2	026657	071879	BA	NN	T03	R	V	D		CELL SURVEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT
G	EN2	030651*	032580	BC	ST	A2122	G	U	2		EMER STATION BATT CHRGR 2G,2J FAILD TO HOLD LOAD	VOLIG CNTRL & CURP LMT MODULES TUNED
G	EN2	030711A	032780	BC	ST	A29	G	U	2		STATION BATT CHRGR 2A,2B FAILED TO MAINTAIN LOADS	SILICON CNTRL RECTIFIERS NEED LOAD BALANC
G	EN2	030711B	032780	BC	ST	A22	G	U			STATION BATT CHRGR 2C FAILED TO MAINTAIN LOAD	CURRENT LIMIT MODULE NEEDED ADJUSTMENT
G	EN2	033891	081180	BA	ST	B30	M	U			DC BATT GROUND ON 2B STATION SERVICE BATTERY	NO CAUSE GIVEN
G	EN2	032981A	032381	BA	AM	B1834	N	D			POST TREATMENT MON 2011-K615A BATTERY DRAINED	BATTERY CHARGER 2AB 24748 VDC FAILED
G	EN2	032981B	032381	BC	NN	B00	N	U			24748 VDC BATTERY CHARGER FOUND NOT CHARGING	NO CAUSE GIVEN
G	EN2	036943A	040781	BA	ST	A1602	N	C	D	2	ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF ST --BTRYS 2R42-5001A&B. PERSONNEL ERROR	
G	EN2	036943B	040781	BA	ST	A1702	N	C	D	2	ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF ST B--TTRYS 2R42-5001A&B. PERSONNEL ERROR	
G	EN2	036943C	040781	BA	DB	A1602	N	C	D		ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF DIE--SFL GENERATOR BATTERY. PERSONNEL ERROR	
G	EN2	036943D	040781	BA	DB	A1702	N	C	D		ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF DIES--EL GENERATOR BATTERY. PERSONNEL ERROR	
G	FP1	019457	102077	BA	ST	A20	U	U			STATION BATTERY "B" FOUND TO HAVE CRACKED CELL	NO CAUSE KNOWN FOR CRACKED CELL #28
G	FP1	021433	053178	BA	FP	A1420	A	U			LD S.G. OF BTRY A2 CELL 1	BAD CELL IN BATTERY
G	FP1	026922	090479	BA	ST	A20	N	U			LEAKING CELL NOTED IN BATTERY "B". BATTERY TEMPOR--APILY INOP WHILE CELL JUMPERED	
G	FP1	031743*	062880	BA	FP	A14	A	T	2		DIESEL FIRE PUMP 24V BATT CELLS A2-6,B2-1 LOW S.G. CHARGER OOS DURING SURVEILLANCE	
G	FP1	033280	111790	BA	ST	A10	N	T			STATION BTRY B MADE INOP TO JUMP A CELL	CELL #8 POOR PERFORMANCE DUE TO AGE
G	FP1	171811	123081	BA	NM	B18	N	D	2		LOW VOLTAGE FROM DIVISION I 24 VDC BATTERIES,CAUS--FD ERRATIC READINGS ON LRM & SRM INST	
G	MT1	014478	040776	BA	SY	T01	R	U	D		SWITCHYARD BTRY SURVEILLANCE NOT PERFORMED W/IN--RFO TIME PERIOD. PERSONNEL ERROR	
G	MD1	166730A	061581	BA	NN	A3401	A	D			250 VDC BATTERY INADVERTENTLY DISCHARGED	PERS DISCONNECTED TEMP BATTERY CHARGER
G	MD1	166730B	061591	BC	NN	B01	A	U	D		TEMPORARY BATTERY CHARGER TAKEN OUT OF SERVICE	PERSONNEL ERROR,CAUSED BTRY TO DISCHRGE
G	DC1	018293A	062877	BA	SY	B34	U	C	D		ONE OF TWO SWITCHING STATION BATTERIES FOUND OOS --FOR 11 DAYS. BATTERY CHARGER FAILED	
G	DC1	018293B	062877	BC	SY	B2713	U	U			BATTERY CHARGER FOR SWITCHING STATION BATTERY FOU--NO OOS AFTER 11 DAYS	

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY NISS VENDOR

PLANT	CONTROL NUMBER	EVENT DATE	CDMP	SYSTEM	FAILURE ORDER	ACTIVITY	TYPE	CLASS	FAILURE #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G DC1	021497A	052478	BA	DB	T01	N	U	D		D/G BTRY LOAD TESTING NOT PERFORMED IN TIME	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	021497B	052478	BA	ST	T01	N	U	D		STATION BTRY LOAD TESTING NOT PERFORMED IN TIME	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	023298A	121378	BA	DB	T01	R	U	D		D/G BTRY NOT TESTED/MONITORED W/IN TIME INTERVAL	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	023298B	121378	BA	ST	T01	R	U	D		STATION BTRY NOT TEST/MONITOR W/IN TIME INTERVAL	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	030599A	022880	BA	ST	T02	R	U	D		MAIN STATION BTRY SURV TEST NOT PERFORMED	PLANT PERS FAILED TO ADHERE TO SURV SCHEDULE
G DC1	030599B	022880	BA	DB	T02	R	U	D		DIESEL GENERATOR BTRY SURV TEST NOT PERFORMED	PLANT PERS FAILED TO ADHERE TO SURV SCHEDULE
G DC1	038737	091181	BA	NN	T02	R	U	D		BATTERY SURVEILLANCE PROCEDURES FOUND NOT TO FULLY COMPLY WITH NEW REQUIREMENTS.	-Y COMPLY WITH NEW REQUIREMENTS.
G PB3	014211	012976	BA	NN	A14	B	L			B BTRY CAPACITY BELOW DESIGN	CELL S.G. IN LRNG, PARTIAL ACID REPLCD
G PI1	027950A	122379	BC	SY	B00	U	R	U		SWITCHYARD 125 VDC BATTERY CHARGER FAILED	NO CAUSE GIVEN
G PI1	027950B	122479	BC	SY	B00	N	R	U		SWITCHYARD 125 VDC BACKUP BATTERY CHARGER FAILED	NO CAUSE GIVEN
G PI1	033899	082180	BC	NN	B211	N	U			"A" 125 VDC CONTROL BATT CHARGER INOPERABLE	VOLTAGE REGULATOR ELECTRONIC MODULES REPLCD
G DC1	019222	092477	BA	NN	M201	U				BATTERY SYSTEM TAKEN OUT OF SERVICE	REPLACED 12 WEAK CELLS, NORMAL END OF LIFE
G DC2	018164	031777	BC	NN	C23	U				UNITS BATTERY CHARGER APPARENTLY INOPERABLE	FAULTY INDUCTIVE CURRENT CONTROL CIRCUIT
G DC2	018460	060977	BC	NN	E2101	N	U			BATTERY CHARGER SUPPLYING CURRENT TO BATTERY FOUND LOW.	FLOATING POTENTIOMETER SET LOW
G VY1	016217A	101376	BA	UP	A34	N	R	U		UPS-1B CNTRL PWR BTRY VOLTAGE WAS LOW	CNTRL BATT CHRGNG POWER SUPPLY FAILED
G VY1	016217B	101376	BC	UP	B21	N	R	U		CNTRL BTRY CHARGING POWER SUPPLY FAILED	INOPERATIVE VOLTAGE REGULATOR CIRCUIT
G VY1	018407A	031877	BA	UP	A3413	N	R	D		UPS-1B ALARMED DUE TO LOW VOLTAGE, CAUSED SCRAM	CAPACITOR FAILED IN CHARGING POWER SUPPLY
G VY1	018407B	031877	BC	UP	B13	N				UPS-1B CONTROL CHARGING POWER SUPPLY FAILED	FAILED CAPACITOR IN ON/OFF CIRCUITRY
G VY1	021749	061978	BC	NN	B06	N	S	D		AC INPUT BRKR TO CA1 BATT CHGR TRPD OPEN	SPOKIOUS TRP OF AC BRKR IN AN ELEC STERN
G VY1	025519	031779	BC	UP	B00	N				CONTROL CHARGING POWER SUPPLY FAILED	NO CAUSE GIVEN. CAUSED BATTERIES DISCHR

APPENDIX D
ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS
SORTED BY COMPONENT

 CODES USED IN LER ONE-LINE DESCRIPTIONS

 MSSS VENDOR

 CODE DESCRIPTION

 B - BABCOCK & WILCOX
 C - COMBUSTION ENGINEERING
 M - WESTINGHOUSE
 G - GENERAL ELECTRIC

 EVENT CLASSIFICATION

CODE DESCRIPTION

D - FREQUENCY
 T - AGE
 U - UNKNOWN

 COMPONENT

CODE DESCRIPTION

BA - BATTERY
 BC - BATTERY CHARGER

 FAILURE CAUSE

 CODE DESCRIPTION

 00 - UNKNOWN
 01 - PERSONNEL OPERATION
 02 - PERSONNEL MAINTENANCE
 03 - PERSONNEL TESTING
 04 - DESIGN/FABRICATION/CONSTRUCTION/QUALITY CONTROL
 05 - DEFECTIVE PROCEDURES
 06 - EXTREME ENVIRONMENT
 08 - CORROSION
 10 - NORMAL WEAR/NATURAL END OF LIFE
 11 - ELECTRICAL MALFUNCTION
 12 - MECHANICAL MALFUNCTION
 13 - PIECE PART FAILURE
 14 - LOW SPECIFIC GRAVITY
 15 - STRATIFICATION
 16 - HIGH ELECTROLYTE SOLUTION LEVEL
 17 - LOW ELECTROLYTE SOLUTION LEVEL
 18 - INSUFFICIENT CHARGE
 20 - DEFECTIVE/WEAK CELLS
 21 - VOLTAGE REGULATOR MALFUNCTION
 22 - CURRENT LIMITER MALFUNCTION
 23 - CURRENT CONTROLLER MALFUNCTION
 24 - VOLTAGE LIMITER MALFUNCTION
 25 - THERMAL OVERLOAD PROTECTION
 26 - COOLING FAN/VENTILATION MALFUNCTION
 27 - CHARGE CONTROL MALFUNCTION
 28 - CHARGE CONTROL TIMER MALFUNCTION
 29 - RECTIFIER PROBLEM
 30 - SHORT CIRCUIT
 32 - ELECTROLYTE DILUTION
 33 - FAULTY CABLE/CONNECTORS
 34 - CHARGER MALFUNCTION

 FAILURE MODE

CODE DESCRIPTION

 A - REDUCED CAPABILITY
 B - NO OUTPUT
 C - UNKNOWN/UNSPECIFIED/OTHER
 D - HIGH CURRENT/VOLTAGE OUTPUT
 E - LOW OUTPUT VOLTAGE
 G - HIGH AC RIPPLE ON DC OUTPUT
 M - MAINTENANCE REPLACEMENT
 T - TEST NOT PERFORMED

 TYPE EVENT

CODE DESCRIPTION

B - RECURRING COMMON CAUSE
 C - COMMON CAUSE
 R - RECURRING
 S - COMMAND FAULT
 T - RECURRING COMMAND FAULT
 J - COMMON CAUSE COMMAND FAULT
 V - RECURRING COMMON CAUSE COMMAND FAULT
 BLANK - RANDOM

 ACTIVITY RESULTING IN DISCOVERY

CODE DESCRIPTION

A - TESTING(UNSPECIFIED)
 B - NORMAL LOAD TESTING
 C - MONTHLY TESTING
 D - WEEKLY TESTING
 E - QUARTERLY TESTING
 F - REFUELING TESTING
 G - 18 MONTH TESTING
 H - 2 YEAR TESTING
 M - MAINTENANCE
 N - NORMAL PLANT OPERATION
 R - RECORDS REVIEW
 U - UNKNOWN

 FLAGGING FIELD

CODE DESCRIPTION

A - FAILED COMPONENT CAUSED AN ACCIDENT
 B - COMPONENT FAILED TO MITIGATE AN ACCIDENT
 C - SAFETY SIGNIFICANT
 D - FAIL # NOT KNOWN
 E - CELL # NOT KNOWN
 F - FAIL # AND CELL # NOT KNOWN
 N - FROM NSIC DATA BASE

SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
AM	- AREA MONITOR SYSTEM
DB	- EMERGENCY DIESEL GENERATOR
ES	- ENGINEERED SAFETY FEATURE
FP	- FIRE PROTECTION SYSTEM
FW	- FEEDWATER SYSTEM
NM	- NEUTRON MONITORING BATTERY
NN	- UNKNOWN/UNSPECIFIED/OTHER
SA	- AUTOMATIC (REACTOR) DEPRESSURIZATION (ADS)
SP	- SPECIAL USE BATTERIES
ST	- STATION BATTERIES/CHARGERS
SW	- SERVICE WATER BUILDING BATTERIES/CHARGERS
SY	- SWITCHYARD BATTERIES/CHARGERS
UP	- UNINTERRUPTIBLE POWER SYSTEM (UPS)

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY COMPONENT

PLANT	CONTROL NUMBER	EVENT DATE	DESCRIPTION	STATUS	SYMBOL	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
B	CP3 017166A	011277	BA NN 103	R	U	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B	CP3 017166B	020277	BA NN 103	R	U	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B	CP3 017166C	020977	BA NN 103	R	U	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B	CP3 021165	040578	BA NN 102	R	U	WRONG BTRY CELLS MONITORED FOR WEEKLY BATT SURV	PERSONNEL NOT FOLLOWING PROCEDURES
B	CP3 038100	071481	BA ST B3002	M	C	STATION BATTERY SHORTED DURING MAINTENANCE	PERSONNEL ERROR. CAUSED REACTOR TRIP
B	DR1 020448	011978	BA ST A1415	E	U	IN BTRY CELL 32 ELECTROLYTE S.G. DECRS .003 NOT	ELEC. STRAT. DUE TO LO BTRY LOADING
B	DR1 021287	042778	BA FP A17	N	U	4 CELLS OF ENGINE BTRY W/ ELECTROLYTE BELOW PLATE	FLEC. ADDED BROUGHT CELLS UP TO NORMAL
B	DR1 022362	090578	BA ST T02	R	U	STATION BATTERIES W/ SURV TEST NOT DONE ON TIME	MISUNDERSTANDING BTRM PERSONNEL
B	DR1 025397	020879	BA FP A17	U	U	ELECTROL LEVEL IN 4 CELLS FOUND LO IN DSL ENG STA-	-RTING BTRY. DIESEL STILL STARTED
B	DE3 015532	081876	BA NN T05	R	U	125-VDC INSTR & CNTRL BATTERIES NOT LOAD TESTED	DFTV PROC. WRONG DATA IN SURV PRINTOUT
B	DE3 022183	072778	BA NN B33	B	U	SMOKE FROM 1 TERMINAL OF 1&C BATTERY 3CB	TERMINAL DFTV/CNCTNS FOUND DEFECTIVE
C	AR2 026489	052279	BA ST T03	R	U	SURVEILLANCE NOT PERFORMED ON STATION BATTERIES	PERSONNEL OVERSIGHT
C	CC1 021533	050378	BA NN A00	A	U	125 VDC BTRY 22 CELL 54 1CV BELOW MIN VOLTAGE	CAUSE UNKNOWN
C	CC1 037262	050681	BA NN H20	A	U	VOLT OF CELL 18 OF 125 VDC BATTERY 12 FOUND .04V -	-BELOW MINIMUM. FULL CAPACITY AVAILABLE
C	CC2 017344	021777	BA NN B01	N	S	#11 125 VDC BATTERY INADVERTENTLY TAKEN OUT OF SE-	-RVCE. SUPERVISOR GAVE PERMISSION
C	M12 026979	080379	BA NN H20	A	U	VARIOUS CELLS REPLACED IN 2018 BTRY (4 CELLS)	REDUCTION IN CELL VOLT. FULL CAPACITY
C	PA1 025917	040479	BA ST B2005	A	C	2 CELLS IN STATION BATTERY #2 BURST WHILE TAKING -	-VOLTAGE READINGS. FULL CAPACITY AVAIL
C	PA1 036000*	010681	BA ST B02	U	U	2 OUTPUT BREAKER FOR BOTH STATION BATTERIES WERE OP-	-ENED FOR 1 HOUR. PERSONNEL ERROR
W	BV1 016357	102476	BA NN M00	A	U	VOLTAGE DECREASED IN CELL 48 BY MORE THAN 0.05V	UNKNOWN. CELL 48 FROM BTRY 3, 1650 A.H.
W	BV1 017119A	020477	BA ST T03	R	U	SURVEILLANCE TEST NOT PERFORMED ON #3 & #4 STATION-	-N BATTERIES. PERSONNEL ERROR
W	BV1 028147	092179	BA NN M2010	A	T	CELL #6 OF BATTERY NO. 1 COULD NOT HOLD ORIGINAL -	-VOLTAGE. FULL BATTERY CAPACITY AVAIL.
W	BV1 039154	101781	BA NN M20	E	R	2 OF 60 CELLS VOLTAGE FOUND DROPPED BY .05 VDC	NO CAUSE GIVEN, BATTERY HAD FULL CAPACITY
W	DC2 021633	060778	BA NN A14	A	U	CD PLANT BTRY CELL 89 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W	DC2 021632	061578	BA NN A14	A	U	AB PLANT BTRY CELL 35 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W	DC2 039127	101981	BA NN T05	P	U	SURVEILLANCE NOT PERFORMED ON "M" TRAIN BATTERY	PROCEDURE LACKED SIGNOFF
W	JF1 021235A	041878	BA SW B00	E	U	2 CELLS IN SW BLOG "M" BATT BANK 1 FAILED T.S. REQ	CAUSE COULD NOT BE DETERMINED
W	JF1 021235B	041878	BA SW B00	E	U	2 CELLS IN SW BLOG B BATT BANK 2 FAILED T.S. REQ	CAUSE COULD NOT BE DETERMINED
W	JF1 027181	090679	BA NN T03	R	U	QUARTERLY AUXILIARY BUILDING BATTERY VERIFICATION-	-NOT PERFORMED ON TIME. PERSONNEL
W	JF1 032332A	081270	BA SW A14	A	F	SW BLOG B BTRY SYS LOW SPECIFIC GRAVITY	BATT PLACED UN EQUALIZE & S.G. ACCEPTABLE
W	JF1 032332B	082500	BA SW A14	A	R	SW BLOG B BTRY SYS LOW SPECIFIC GRAVITY	NO EXTERNAL CAUSE FOR LOW SPECIFIC GRAV
W	JF1 032687	091180	BA SW A1404	A	D	SW BLOG "M" BATT SYS IN BATT CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN
W	JF1 033007	102180	BA SW A1404	A	D	SW "M" BTRY SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY COMPONENT

N S S Y	P A M	C O N T R O L N U M B E R	E V E N T D A T E	C O M P O N E N T	F A U L T C O D E	F A U L T D E S C R I P T I O N	F A U L T D E S C R I P T I O N	
								FAILURE MODE DESCRIPTION
W JFI	033163	102880	BA SW	A1404	A	D	SW BLDG #4M BATT SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM PROXACTED RES/POST SEAL DESIGN
W MCI	030186	101981	BA ST	A3308	M	T	CELL TO CELL RESISTANCE IN 3 CELLS FOUND HIGH	CORROSION OF TERMINAL CONNECTIONS
W HAI	026565	062879	RA DB	T05	R	U	7 DAY SURVEILLANCE OF EMERGENCY DIESEL GENERATOR	-BATTERIES EXCEEDED INTERVAL. PROCEDURAL
W HAI	026656	073179	BA DB	T05	R	U	DIESEL GENERATOR BATTERIES SURVEILLANCE NOT DONE	TIME LAG IN IMPLEMENTING NEW PROCEDURES
W HAI	030491A	022881	BA ST	T02	R	U	18 MONTH SURVEILLANCE ON D-C. DISTRIBUTION SERVIC-	-E SYSTEM NOT DONE. PERSONNEL OVERSIGHT
W HAI	171872	120181	BA DB	A1410	A	T	1J EMERGENCY D/G INOP CELL S.G. BELOW 1.2	D/G BATTERY NEAR END OF USEFUL LIFE
W HAZ	035466*	021881	BA DB	M14	E	U	2 BATTERIES FOR 2J & 2II DIESEL GENERATORS FAILED SU-	-RVEILLANCE TEST. 4 CELLS REPLACED
W HAZ	036417	022081	BA DB	T05	R	U	DATA FROM TWO TESTS ON 2J DIESEL BATTERY FOUND NO-	-T USABLE. NOT COMPARED WITH INITIAL CON
W PRI	025268	053179	BA FP	T05	R	U	DIESEL DRIVEN WEEKLY BATTERY INSPECTION NOT DONE	PROCEDURES WERE DEFECTIVE
W PRI	030917	033180	BA ST	T02	R	U	INDIVIDUAL FLOAT CELL VOLT MEAS NOT DONE IN STATI-	-ON BATTERY TEST. PERSONNEL OVERSIGHT
W R02	015515	071076	BA NN	B02	M	D	BATTERY B LEADS WERE REMOVED RENDERING BATT INOP	PERS FAILED TO COMPLY W/ T.S. 3.7
W R02	021898	071878	BA ST	B3311	N	D	PLASTIC TOP OF 2 STAIN #4M BATT CELLS ON FIRE	RESISTIVE HEATG OF STRAP-CELL TERMINAL
W SAI	020738A	020178	BA NN	A34	M	U	1C 125V BATTERY VOLTAGE LOW	1C1,1C2 BATT CHARGER D.C. BRKRS TRPD
W SAI	032162	072180	BA FP	T02	R	U	92 DAY & 18 MON SURV NOT DONE ON 24 V STARTG BATT	ELECTRICIAN NOT COMPLETING JOB
W SAI	038834	091881	BA FP	B33	N	U	BATTERY CABLE CLAMP FOUND ARCING AND CRACKED	CLAMP WAS REPLACED ON #2 FIRE PUMP BTRY
W SAI	038783	090681	BA AM	B00	M	U	RAD MONITOR 2R12A BATTERY PACK FAILED	NO CAUSE GIVEN
W SEI	032338	080780	BA DB	B30	N	U	D/G BTRY 1B-B CELL 51 SHURTED AND FAILED	NO CAUSE GIVEN
W SEI	032342A	081280	BA DB	B05	U	U	D/G BTRY 1B-B CELLS 49,50,51 DISCHARGED	INADEQUATE PROCEDURE
W SEI	032342B	081380	BA DB	B05	U	U	D/G BTRY 1B-B CELLS 49,50,51 DISCHARGED	INADEQUATE PROCEDURE
W S02	038470	090681	BA FP	B00	U	U	SORKE DETECTOR BATTERY FOUND NOT TO TAKE A CHARGE	NO CAUSE GIVEN
W S02	038936A	100181	BA FP	B34	A	U	SORKE DETECTOR BATTERY FAILED	CHARGER NOT CHARGING BATTERY
W TPI	014563	032476	BA ES	T05	R	U	ESF DC PWR SUPPLIES SURV PEO PERFORMU AT MRNG FREQ	PROCEDURE DID NOT USE FREQ REQ BY T.S.
W TPI	020885	031778	BA NN	T02	R	U	125 VDC ELECTRICAL SYS OP NOT VERIFIED WK OF 2-26	MAINT PERS FAILED TO INSURE SURV COMPLETED
W TPI	025211A	011979	BA NN	T03	R	U	125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL
W TPI	032622	090380	BA FM	B20	M	U	DIESEL-DRIVEN AFMP FAILED TO START FROM MAHIAL SIG	FAILED STARTING BATTERY
W T03	022061A	122277	BA ST	T01	U	U	EQUALIZING CHARGES ON STATION BATTERIES NOT PERFO-	-RMD. PERSONNEL ERROR,FULL CAPACITY AVL
W T03	022061B	122977	BA ST	T01	U	U	EQUALIZING CHARGES ON STATION BATTERIES NOT PERFO-	-RMD. PERSONNEL ERROR,FULL CAPACITY AVL
W T03	033530B	121180	BA NN	T34	N	U	4B 125 VDC BATT 00S,RECT SPEC EXCEEDED	PROBLEM W/ ASSOCIATED BTRY CHARGER
W T03	039363	181281	BA NN	B20	A	R	"34" 125 VDC FAILED TO HOLD A CHARGE	BEING EVALUATED W/ MANUFACTURER
W YPI	019861	120577	BA ST	A20	E	U	CELL VOLTAGE ON CELL 1B OF BANK 1 FOUND LOW	NO CAUSE FOUND,CELL REPLACED
W ZII	171120A	121281	BA NN	B01	M	U	UNIT 2 212 BATTERY TAKEN 00S ERRONEOUSLY	LICENSED OPERATOR ERROR
W ZII	172130	121581	BA NN	C05	U	U	EQUALIZING CHARGE NOT PLACED ON BATTERY 112	PROCEDURE NOT CLEAR ON COMMUNICATIONS

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY COMPONENT

MSG#	PL	AL	Y	CONTROL NUMBER	EVENT DATE	C	D	F	M	U	F	A	L	C	A	F	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G	BFI	03805			072281	BA	NN	A20		U	U						250 VOLT MAIN BATTERY TAKEN ODS TO BYPASS A CRACK--ED CELL.	
G	BFI	015304			070976	BA	NN	B3302		M	U	D					NEUTRON MONITORING BATTERY 2A MADE INOPERABLE	CNCTR BROKEN OFF A CELL POST PERS ERROR
G	BFI	025671			041979	BA	SP	B3302		N	C	D					BROKEN TERMINAL DISCOVERED ON S/D BOARD "D" BTRY	PERSONNEL ERROR, ALSO AFFECTED UNIT J
G	BPI	0152488			063076	BA	ST	A18		N	D						LOAD ON BTRY REDUCED VOLTAGE & SPECIFIC GRAVITY	STATION BATTERY CHARGER HAD FAILED
G	BPI	0153264			072276	BA	SA	A17		C	U						RDS BATTERY D PILOT CELL LOW ELECTROLYTE LEVEL	EXACT CAUSE UNKNOWN
G	BPI	0153268			072276	BA	SA	A1432		C	D						RDS BATTERY D PILOT CELL HAD LOW SPECIFIC GRAVITY	ADDITION OF WATER POSSIBLE CAUSE
G	BPI	0153274			072876	BA	SA	A17		C	U						RDS BTRY C PILOT CELL LOW ELECTROLYTE LEVEL	UNKNOWN CAUSE
G	BPI	0153278			072976	BA	SA	T14		C	U						RDS BTRY C PILOT CELL RDS LO SPECIFIC GRAVITY	DECTV PROC SPECIFIC GRAVITY READ TOO SOON
G	BPI	015444			081276	BA	DB	B33		N	T						EMERGENCY DIESEL GENERATOR DID NOT START DUE TO L-	-DOSE BATTERY CONNECTION.
G	BPI	0160738			100376	PA	SA	A17		A	U						RDS D BTRY PILOT & 3 OTHER CELLS LO ELECTROLYTE	-LEVEL, UNKNOWN CAUSE
G	BPI	016073A			100476	BA	SA	A1405		A	D						RDS D BTRY PILOT & 3 OTHER CELLS LO SPEC GRAVITY	INCOMPLETE ELECTROLYTE MIXING
G	BPI	016302A			102176	BA	SA	A14		D	U						RDS "A" BTRY PILOT CELL 55 LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BPI	016459			110476	BA	SA	A14		C	U						RDS B PILOT CELL LOW SPECIFIC GRAVITY	UNKNOWN CAUSE
G	BPI	016302B			112176	BA	SA	A14		D	U						RDS "A" BTRY PILOT CELL 55 LOW SPECIFIC GRAVITY	VENDOR INVESTIGATING
G	BPI	016584			120276	BA	SA	A14		D	U						RDS B BTRY PILOT CELL 27 LO SPECIFIC GRAVITY	VENDOR INVESTIGATING
G	BPI	017023			170976	BA	SA	A14		D	U						RDS B ONE CELL LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BPI	017024*			010477	BA	SA	M14		A	R	U					2 B CELLS SPECIFIC GRAVITY FOUND BELOW 1.2, EVALUA-	-TION REVEALED ADEQUATE CAPACITY
G	BPI	017464			022477	BA	SA	M14		C	R	U					RDS BATTERY B HAD ONE CELL BELOW MINIMUM SPECIFIC-	-GRAVITY, ADEQUATE CAPACITY AVAILABLE
G	BPI	017463			031777	BA	SA	M14		C	R	U					SPECIFIC GRAVITY FOUND LOW IN 5 CELLS OF RDS BTRY-	"A", ADEQUATE CAPACITY AVAILABLE
G	BPI	017704*			033077	BA	UP	B3304		N	C	D					NO OUTPUT FROM ALL UPS BATTERY BANKS	CONNECTORS NOT TIGHTENED DURING INSTAL
G	BPI	018096A			042177	BA	SA	M14		C	R	U					RDS BATTERY B CELL 27 FOUND TO HAVE LOW SPECIFIC -	-GRAVITY OF 1.191, FULL CAPACITY AVAIL
G	BPI	018096B			042777	BA	SA	M14		C	U						SPECIFIC GRAVITY OF LO MARGINAL CELLS ADJUSTED OF-	-RDS BATTERY B, FULL CAPACITY AVAILABLE
G	BPI	018462A			061677	BA	SA	A17		U	R	U					WATER ADDED TO CELL 27 OF RDS BATTERY "B"	NO CAUSE GIVEN FOR LOW WATER LEVEL
G	BPI	018462B			061677	BA	SA	T1432		C	V	D					SPECIFIC GRAVITY OF CELL 27 OF RDS BATTERY B LOW	WATER ADDED THEN TESTED TOO SOON
G	BPI	019025A			082977	BA	FP	B3302		N	D						DIESEL FIRE PUMP "A" BATTERY FOUND WITH NO OUTPUT	CONNECTORS NOT TIGHTENED
G	BPI	019025B			082977	BA	FP	B00		N	U						DIESEL FIRE PUMP "B" BATTERY FOUND FAILED WITH NO-	-OUTPUT, DISCHR WITH NO APPARENT CAUSE
G	BPI	019472A			092977	BA	SA	A17		U	R	U					WATER ADDED TO CELL 12 OF RDS BATTERY "A"	NO CAUSE GIVEN FOR LOW WATER LEVEL
G	BPI	019472B			092977	BA	SA	A1432		C	P	D					SPECIFIC GRAVITY OF CELL 12 OF RDS BATTERY "A" LOW	WATER ADDED, CHARGE INSUFFICIENT TO MIX
G	BPI	019542A			100877	BA	SA	A17		U	R	U					WATER ADDED TO 3 CELLS OF RDS BATTERY "D"	NO CAUSE GIVEN FOR LOW WATER LEVEL
G	BPI	019542B			102077	PA	SA	A1432		C	P	D					SPECIFIC GRAVITY OF 3 CELLS OF RDS BATTERY "D" LOW	WATER ADDED, MIXING WAS INADEQUATE
G	BPI	020176			122277	PA	SA	A14		C	R	U					SPECIFIC GRAVITY ON RDS BATTERY "A", CELL 12 LOW	FUZZIALIZING CHARGE FOR 8 HOURS CORRECTED
G	BPI	021307			050478	BA	FP	A17		D	U						FIRE PUMP DIESEL STARTG BTRY A CELLS 1+3+5 LO --	ELECTROLYTE SOLN, EXACT CAUSE UNKNOWN

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY COMPONENT

UNION	PLANT	CONTROL NUMBER	EVENT DATE	COMP	EMERG	FAC ID	RD FE	ACTIVITY	TYPE	CLASS	FAIL #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G	BP1	021519	052578	BA	FP	A1705	D	D				FIRE PUMP DIESEL STARTG BTRY "A" CELLS 2,4,6 LO--	ELECTROLYTE SOLN. INADQ MAINTENANCE PROC
G	BP1	022664	083178	BA	SA	A14	C	R	U			RDS BATTERY A, CELL 12 LO SPECIFIC GRAVITY READING EXACT CAUSE UNKNOWN	
G	BP1	027985	110179	BA	SA	A1420	C	U				SPECIFIC GRAVITY OF CELL 48 OF RDS BATTERY C LOW	CELL REPLACED, WOULD NOT TAKE EQUAL CHARGE
G	BP1	030237	012480	BA	SA	A1420	C	U				RDS C BTRY CELL 14 LOW SPECIFIC GRAVITY RDG	DEFECTIVE CELL REPLACED
G	BP1	031176	050180	BA	SA	A1420	C	U				RDS BTRY "A" CELL 2 LOW SPECIFIC GRAVITY RDG	CELL DID NOT RESPOND ADQ TO EQUALIZG CHR
G	BP1	031848	071080	BA	SA	A1420	C	U				RDS C BTRY CELLS 35,54 LOW SPECIFIC GRAVITY RDG	CELL DID NOT RESPOND ADQ TO EQUALIZG CHR
G	BP1	032023	071880	BA	SA	A20	D	U				RDS C BTRY PILOT CELL UNIT-9 INTERNAL RESISTANCE-	-INCRS. CAUSE UNKNOWN
G	BP1	032297	080780	BA	SA	A14	C	U				RDS C BTRY CELLS 38,39,56 LOW SPECIFIC GRAVITY	VFNDR P'COM INCRS IN FLOAT VOLTAGE LEVEL
G	BP1	032656	091180	BA	SA	A1420	C	U				RDS D BATTERY CELL 12 LOW SPECIFIC GRAVITY RDG	CELL DID NOT ADQ RESPOND TO EQUALIZG CHR
G	BP1	033544	121180	BA	SA	A1402	C	U				21 CELLS OF RDS "A" BATTERY LOW SPECIFIC GRAVITY	CELL TERMINALS INADQ CLEANED BY MAINT PER
G	BP1	033637	122380	BA	NN	T02	R	U	D			DC BATTERY MONTHLY TESTS OVERDUE	INADQ ADMIN CONTROLS & PERSONNEL ERROF
G	BP1	037338	010281	BA	SA	A1420	C	R	U			RDS CH D BATTERY CELL 56 HAD LOW SG, WOULD NOT RES-	-POND TO EQUALIZING CHARGE.
G	BP1	038112	081581	BA	SA	A1602	A	C	D			FOUND PILOT CELL IN CH A RDS POWER SUPPLY WITH A -	-HIGH ELEC LEVEL. POSSIBLY OVERFILLED
G	BP1	038592	083181	BA	ST	A20.4	C	C	D			LOW SG IN CELL 43 OF ST BTRY, CELL FOUND CRACKED.-	-THIS LEAD TO DILUTION, CRACKED WHEN MOVED
G	BP1	038785	091581	BA	SA	A1420	C	U				"A" RDS BTRY CELL #5 LOW SPECIFIC GRAVITY	CELL DIDN'T RESPOND ADQ TO EQUALIZG CHR
G	BP1	025637A	032579	BA	NN	A3308	B	R	T			BATTERY 1B2 VOLTAGE FELL TO 102.5V THEN ROSE TO -	-118V. CORRODED AND LOOSE BTRY CONNECT
G	BP1	025637B	032779	BA	NN	A3308	B	R	T			BTRY 1B1 VOLTAGE FELL TO 96.8V THEN ROSE TO 118V	CORRODED AND LOOSE BTRY CONNECTORS
G	BR2	014651	021276	BA	NN	T05	R	U	D			MONTHLY INSTEAD OF QUARTERLY BATTERY P.T. PERFORMD	WRONG P.T. SCHEDULED BY MISTAKE
G	CO1	037938	052881	BA	ST	T03	R	U	D			SG TESTS FOR 125V 1A&B AND 250V 1B NOT PERFORMED -	-PROPERLY. PERSONNEL USED WRONG HYDRON
G	DA1	030982	041780	BA	NN	T02	R	U	D			WKLY BATT SURV DOCUMENTATION NOT COMPLETED	PERSONNEL ERROF-NONLIC. OPERATIONS PERS
G	DR1	018553A	072977	BA	FP	B3413	M	C	D	2		DIESEL FIRE PUMP BATTERIES FAILED TO START DIESEL	FAILED FUSE FROM BATTERY CHARGER CIRCUIT
G	DR2	039116	102181	BA	NN	T01	R	U	D			QUARTERLY STORAGE BATTERY SURVEILLANCE DONE 3 DAY-	-S LATE. OVERSIGHT BY OPERATING SHIFT
G	DR3	016265A	101876	BA	NN	A34	A	D				BATTERY IN A DEGRADED CONDITION	CHARGER SUBJECTED BTRY TO "DEEP CYCLING"
G	DR3	020853	032878	BA	NN	A10	F	R	T			24748 V BTRY FAILED THE REFUELING OUTAGE DISCHRG-	-TEST. 4 CELLS REPLCD NAT'L END OF LIFE
G	DR3	025951	042479	BA	NN	B01	N	U	D			UNIT 2'S BATTERY NOT RETURNED TO NORMAL LINEUP	BREAKER COULD HAVE BEEN SHUT AT ANY TIME
G	DR3	036569	030381	BA	NN	T01	R	U	D			WEEKLY STORAGE BATTERY SURVEILLANCE DONE 4 DAYS L-	-ATE. OVERSIGHT BY OPERATING SHIFT
G	FN1	021719	062778	BA	DB	T02	R	U	D			WKLY PILOT CELL SURV OF 1C D/G BTRY NOT COMPLET--	-ED ON TIME. PERSONNEL OVERSIGHT
G	FN1	027782	112679	BA	NN	T03	R	U	D			CELL SURVEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT
G	FN2	022208	081678	BA	NN	T02	P	U	D			WKLY PILOT CELL SURV OF PLANT BATT NOT COMPLETFD--	-ON TIME. NOTICES ROUTED TO ABSENT PERS
G	FN2	026657	071879	BA	NN	T03	R	V	D			CELL SURVEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT
G	FN2	033891	081180	BA	ST	B30	M	U				DC BATT GROUND ON 2B STATION SERVICE BATTERY	NO CAUSE GIVEN
G	EN2	032981A	032381	BA	AM	B1834	N	D				POST TREATMENT MON 2011-K615A BATTERY DRAINED	BATTERY CHARGER 2AB 24748 VDC FAILED

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY COMPONENT

P N S S	CONTROL NUMBER	EVENT DATE	C O M P O N E N T	S Y S T E M	F A U L T C O D E	A C T I V E T Y P E	F A I L U R E C A U S E D E S C R I P T I O N
G	EN2 036943A	040781	BA ST	A1602	N C D	2	ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF ST --BTRYS 2R42-S001A6B. PERSONNEL ERROR
G	EN2 036943B	040781	BA ST	A1702	M C D	2	ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF ST --BTRYS 2R42-S001A6B. PERSONNEL ERROR
G	EN2 036943C	040781	BA DB	A1602	N C D		ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF DIE--SEL GENERATOR BATTERY. PERSONNEL ERROR
G	EN2 036943D	040781	BA DB	A1702	N C D		ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF DIE--SEL GENERATOR BATTERY. PERSONNEL ERROR
G	FPI 019457	102077	BA ST	A20	U U		STATION BATTERY #8M FOUND TO HAVE CRACKED CELL NO CAUSE KNOWN FOR CRACKED CELL #228
G	FPI 021433	053178	BA FP	A1420	A U		LO S.G. OF BTRY A2 CELL 1
G	FPI 026922	090479	BA ST	A20	M U		LEAKING CELL NOTED IN BATTERY #8M. BATTERY TEMPOR--APPLY INOP WHILE CELL JUMPERED
G	FPI 031743*	062880	BA FP	A14	A Y	2	DIESEL FIRE PUMP 24V BATT CELLS A2-6,82-1 LOW S.G. CHARGER OOS DURING SURVEILLANCE
G	FPI 033280	111780	BA ST	A10	M T		STATION BTRY B MADE INOP TO JUMP A CELL
G	FPI 171811	123081	BA NH	B18	N D	2	LOW VOLTAGE FROM DIVISION 1 24 VDC BATTERIES,CAUS --ERRATIC READINGS ON LRM & SRM INST
G	MII 014478	040776	BA SY	T01	R U D		SWITCHARD BTRY SURVEILLANCE NOT PERFORMED W/IN--REQ TIME PERIOD. PERSONNEL ERROR
G	M01 166730A	061581	BA NH	A3401	A D		250 VDC BATTERY INADVERTENTLY DISCHARGED
G	OC1 018293A	062877	BA SY	B34	U C D		ONE OF TWO SWITCHING STATION BATTERIES FOUND OOS --FOR 11 DAYS. BATTERY CHARGER FAILED
G	OC1 021497A	052478	BA DB	T01	N U D		D/G BTRY LOAD TESTING NOT PERFORMED IN TIME
G	OC1 021497B	052478	BA ST	T01	N U D		STATION BTRY LOAD TESTING NOT PERFORMED IN TIME
G	OC1 023298A	121378	BA DB	T01	R U D		D/G BTRY NOT TESTED/MONITORED W/IN TIME INTERVAL
G	OC1 023298B	121378	BA ST	T01	R U D		STATION BTRY NOT TEST/MONITOR W/IN TIME INTERVAL
G	OC1 030597A	022880	BA ST	T02	R U D		MAIN STATION BTRY SURV TEST NOT PERFORMED
G	OC1 030597B	022880	BA DB	T02	R U D		DIESEL GENERATOR BTRY SURV TEST NOT PERFORMED
G	OC1 038737	091181	BA NH	T02	R U D		BATTERY SURVEILLANCE PROCEDURES FOUND NOT TO FULL--Y COMPLY WITH NEW REQUIREMENTS.
G	PB3 014211	012976	BA NH	A14	B U		B BTRY CAPACITY BELOW DESIGN
G	OC1 019222	092477	BA NH	M2010	U T		BATTERY SYSTEM TAKEN OUT OF SERVICE
G	VY1 016217A	101376	BA UP	A34	N R U		UPS-1B CNTRL PWR BTRY VOLTAGE WAS LOW
G	VY1 018407A	031077	BA UP	A3413	N R D		UPS-1B ALARMED DUE TO LOW VOLTAGE,CAUSED SCRAM
B	I12 023084*	111278	BC NH	B13	B U	2	CHRGWS 2-2A/B FUSE BLEW NO CHRG FOR BANK 2-25B
C	AP2 026904	080979	BC NH	B1306	N C D		BATTERY CHARGER 2031 FAILED. DC OUTPUT LAMP SOCK--ET BURNED UP DUE TO HIGH HEAT,VOLT,DUST
C	AP2 027808	121179	BC NH	B21	M S D		BATTERY CHARGER 2032 AC BREAKER TRIPPED
C	AP2 039245*	110581	BC NH	B00	N U	2	OUTPUT BREAKER OF BATTERY CHARGER 2034 TRIPPED OP--EN TWICE. NO CAUSE COULD BE FOUND
C	PA1 01617	102076	BC NH	E2201	N D		DC BUS-2 VOLTG FELL/VOLTG ON ASSOC AC BUSES FELL
C	S11 020069	121677	BC NH	B00	M D		OUTPUT LOST FROM #8M BATTERY CHARGER
C	S11 037962	062481	BC NH	T02	R U D		SURVEILLANCE REQUIREMENTS NOT MET ON #8M BATTERY--CHARGER. MISINTERPRETATION OF TECH SPEC
C	S11 038775	091881	BC NH	B24	A R U		1A BATTERY CHARGER SHUTDOWN ON HIGH VOLTAGE HIGH VOLTAGE DEVICE FOUND DEFECTIVE

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY COMPONENT

UNIQUE	PLANT	CONTROL NUMBER	EVENT DATE	COMP	SYSTEM	FAILURE CODE	ACTIVITY	CLASS	FAILURE #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
W RV1	0171198	020477	BC ST T03	R U D						SURVEILLANCE TEST NOT PERFORMED ON CHARGERS ASSOC-	-TATED WITH #3 & #4 STATION BTRY. PERSON
W BV1	021043	032078	BC NN E2713	N U						DECR #4 DC BUS VOLTAGE DUE TO A FAULTY BTRY CHRGR	FAILED COLLECTR RESISTR IN CHRGR CNTRL CKI
W BV1	022136	080478	BC ST B00	B U						#4 STATION BTRY CHRGR OUTPUT BRKR TRIPPED	IMPROPR OP OF CKTBRK.CAUSE OF TRP UNKNOWN
W HV1	037757	061581	BC NN B2506	N R D						#2 BATTERY CHARGER OUTPUT BREAKER FAILED OPEN	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
W BV1	038347	080581	BC NN B2506	N R D						#2 BATTERY CHARGER OUTPUT BREAKER TRIPPED OPEN	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
W BV1	038825	091081	BC ST B33	N U						#4 STATION BATTERY CHARGER TAKEN OUT OF SERVICE	BAD ELECTRICAL CONNECTION IN OUTPUT
W DC1	025643	032379	BC NN D01	N U D						125 VDC EQUALIZING CHARGE CH4 FAILED INVERT-	-EP, CAUSED SCRAM AND SI. NO CAUSE
W HN1	014608A	042576	BC NN D2833	N U						BTRY CHARGER A WENT INTO V. LRG	FAULTY CNCTN ON CHARGER CONTROL TIMER
W HN1	014608B	042576	BC NN D2122	N U						VOLIG REG SPIKING TO 200 AMP IN SHUTTING OFF	FAULTY PHASING CRD IN CURRENT LIMITER CKI
W IP3	014709	051076	BC NN B2630	A U						BTRY CHRGR TROUBLE ALARMED CHARGER FAN HAD TRPD	AC FAN MTR INOP EXPOSED WIRE BLEW A FUSE
W IP3	015138	060876	BC NN B13	A S U						# 31 BTRY CHRGR AC BRKR TRIPD BATT CHRGR INOP	PRESSURE SENSOR FAILED TRIPPING BREAKER
W IP3	036207	012481	BC NN B2123	N U						OUTPUT FROM CHARGER #32 DISCOVERED DROPPING	VOLTAGE AND CURRENT CONTROLLER REPLACED
W TP3	038257	070681	BC NN B13	N S U						BATTERY CHARGER #32 DISCOVERED TRIPPED	FAILED DP AIR FLOW SENSOR SWITCH
W JF1	032504	087580	BC SW B24	N S U						SW B DC DISTRIBUTION SYS INOP NO OUTPUT FROM BATT-	-CHGR 4. HV S/D RELAY ACTUATED
W NA1	036491B	022881	BC ST T02	R U D						18 MONTH SURVEILLANCE ON D.C. DISTRIBUTION SERVIC-	-R SYSTEM NOT DONE. PERSONNEL OVERSIGHT
W PR1	033222	110590	BC NN A2911	A U						#12 BTRY CHRGR FAILED TO PROVIDE NORMAL OUTPUT	FIRING CARD B NOT PROVIDING PULSE TO SCR
W PR2	014599	041476	BC NN B2133	B U						#12 BATTERY CHARGER FAILED DISABLED "B" DC POWER	VOLTAGE CNTRL CRD LOOSE IN ITS SOCKET
W SA1	020738R	020178	BC NN B00	N U						2 IC1, IC2 BATT CHARGER D.C. BRKRS TRIPPED	UNKNOWN CAUSE
W SA2	038319	072481	BC NN B2101	N U D						2C1 BATTERY CHARGER DISCOVERED TRIPPED. VOLTAGE -	-SETTING WAS INCORRECTLY SET
W SA2	038327	081281	BC NN B24	N U						2B1 BATTERY CHARGER WOULD NOT PICK UP 28 VDC LOAD	HIGH VOLTAGE CUT-OUT ACTUATED
V SU2	169141	081981	BC FP B13	N U						SMOKE DET SYS INOP BTRY CHRGR LOST POWER	FAULTY POWER SUPPLY CARD IN CHARGER
W SU2	038936B	100181	BC FP B00	A U						BATTERY CHARGER FOR SMOKE DETECTOR BATTERY FAILED	NO CAUSE GIVEN
W TR1	025211B	011979	BC NN T03	R U D						125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL
W TU3	033530A	121180	BC NN C00	N U						PROBLEMS WITH 4B 125 VDC BATTERY CHARGER	NO CAUSE GIVEN
W YP1	019476A	101477	BC NN B1210	N R T						NO. 2 BATTERY CHARGER TAKEN OUT OF SERVICE	FAILED BEARING
W YP1	019476B	101477	BC NN T01	N U D						NO. 1 BATTERY CHARGER CROSS TIED TO NO. 2 BATTERY	OVERSIGHT CAUSE LCD STATED IN TECH SPEC
W YP1	019640	110577	BC NN B1210	N R T						NO. 1 BATTERY CHARGER TAKEN OUT OF SERVICE	FAILED BEARING DUE TO NORMAL WEAR
W Z11	171128R	121281	BC NN B01	M U D						UNIT 2 212 CHARGER TAKEN OUTS ERRONEOUSLY	LICENSED OPERATOR ERROR
G BP1	015248A	063076	BC ST B29	N U						STATION BATTERY CHARGER FAILED	DEFECTIVE SILICON RECTIFIERS
G BP1	014389	102177	BC NN B206	B U						BATT CHRGR DC OUPUT FUSE FAILED WHEN CHRGR BATT 28-2	HI CURR/TEMP CAUSD SOLDERG LINKG SEPARATE
G CD1	027101A	062778	BC NN B2333	N T						1A 250V BTRY CHRGR TIE BREAKER TRIPPED	POOR CNNECT CNCTS IN CURRENT MODULE
G CD1	022101B	062778	BC NN B3304	N U D						1A 250V BTRY CHRGR INPUT BREAKER TRIPPED	LOOSE CNNECTN AT CHRGR INPUT BRKR PHASE A

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY COMPONENT

SYSTEM	PLANT	CONTROL NUMBER	EVENT DATE	COMP	SYSTEM	FAILURE CODE	ACTIVITY	TYPE	CLASS	FAIL #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G	CO1	037646	050581	BC	ST	G29	B	U			HIGH RIPPLE FROM BATTERY CHARGER WHICH FAILED INV-	-ENTER IA. FAILED SCR
G	DA1	171665	120881	BC	NN	E00	N	U			BATTERY CHARGER OUTPUT INCORRECT	UNKNOWN
G	DR1	0185538	072977	BC	FP	B22	N	U			FUSE FOUND BLOWN IN DIESEL FIRE PUMP BATTERY CHAR-	-GER.
G	DR3	0162658	101876	BC	NN	C00	A	U			CHARGER SUBJECTED BTRY TO "DEEP CYCLING"	UNKNOWN CAUSE
G	EN1	021475*	060478	BC	ST	M1304	M	D	2		HEAT-SENSITIVE XSTR ON BATT CHRGR FIRING MODUL CRD	SHOULD BE A NON-HEAT-SENSITIVE TRANSISTOR
G	EN2	030651*	032580	BC	ST	A2122	G	U	2		EMER STATION BATT CHRGR 2G,2J FAILED TO HOLD LOAD	VOLTG CNTRL & CURR LMT MODULES TUNED
G	EN2	030711A	032780	BC	ST	A29	G	U	2		STATION BATT CHRGR 2A,2B FAILED TO MAINTAIN LOADS	SILICON CNTRL RECTIFIERS NEED LOAD BALANC
G	EN2	030711B	032780	BC	ST	A22	G	U			STATION BATT CHRGR 2C FAILED TO MAINTAIN LOAD	CURRENT LIMIT MODULE NEEDED ADJUSTMENT
G	EN2	032981B	032381	BC	NN	B00	N	U			24/48 VDC BATTERY CHARGER FOUND NOT CHARGING	NO CAUSE GIVEN
G	MO1	166730B	061581	BC	NN	B01	A	U	D		TEMPORARY BATTERY CHARGER TAKEN OUT OF SERVICE	PERSONNEL ERROR, CAUSED BTRY TO DISCHARGE
G	OC1	0182938	067877	BC	SY	B2713	U	U			BATTERY CHARGER FOR SWITCHING STATION BATTERY FOU-	-NO ODS AFTER 11 DAYS
G	PI1	027950A	122379	BC	SY	B00	U	R	U		SWITCHYARD 125 VDC BATTERY CHARGER FAILED	NO CAUSE GIVEN
G	PI1	027950B	122479	BC	SY	B00	N	R	U		SWITCHYARD 125 VDC BACKUP BATTERY CHARGER FAILED	NO CAUSE GIVEN
G	PI1	033899	082180	BC	NN	B2113	N	U			"A" 125 VDC CONTROL BATT CHARGER INOPERABLE	VOLTAGE REGULATOR ELECTRONIC MODULES #PLC
G	QC2	018164	031777	BC	NN	C23	U	U			UNITS BATTERY CHARGER APPARENTLY INOPERABLE	FAULTY INDUCTIVE CURRENT CONTROL CIRCUIT
G	QC2	018460	060977	BC	NN	E2101	N	U	D		BATTERY CHARGER SUPPLYING CURRENT TO BATTERY FOUN-	-D LOW. FLOATING POTENTIOMETER SET LOW
G	VY1	016217B	101376	BC	UP	B21	N	R	U		CNTRL BTRY CHARGING POWER SUPPLY FAILED	INOPERATIVE VOLTAGE REGULATOR CIRCUIT
G	VY1	018407B	031877	BC	UP	B13	N	T			UPS-1B CONTROL CHARGING POWER SUPPLY FAILED	FAILED CAPACITOR IN ON/OFF CIRCUITRY
G	VY1	021749	061978	BC	NN	B06	N	S	D		AC INPUT BRKR TO CA1 BATT CHRGR TRPD OPEN	SPURIOUS TRP OF AC BRKR IN AN ELEC STERN
G	VY1	025519	031779	BC	UP	B00	N	U			CONTROL CHARGING POWER SUPPLY FAILED	NO CAUSE GIVEN. CAUSED BATTERIES DISCHR

APPENDIX E
ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS
SORTED BY SYSTEM

CODES USED IN LER ONE-LINE DESCRIPTIONS

 NSSS VENDOR
 CODE DESCRIPTION
 B - BABCOCK & WILCOX
 C - COMBUSTION ENGINEERING
 M - WESTINGHOUSE
 G - GENERAL ELECTRIC

EVENT CLASSIFICATION

 CODE DESCRIPTION

D - FREQUENCY
 T - AGE
 U - UNKNOWN

COMPONENT

 CODE DESCRIPTION

 BA - BATTERY
 BC - BATTERY CHARGER

 FAILURE CAUSE
 CODE DESCRIPTION

 00 - UNKNOWN
 01 - PERSONNEL OPERATION
 02 - PERSONNEL MAINTENANCE
 03 - PERSONNEL TESTING
 04 - DESIGN/FABRICATION/CONSTRUCTION/QUALITY CONTROL
 05 - DEFECTIVE PROC. CURES
 06 - EXTREME ENVIRONMENT
 08 - CORROSION
 10 - NORMAL WEAR/NATURAL END OF LIFE
 11 - ELECTRICAL MALFUNCTION
 12 - MECHANICAL MALFUNCTION
 13 - PIECE PART FAILURE
 14 - LOW SPECIFIC GRAVITY
 15 - STRATIFICATION
 16 - HIGH ELECTROLYTE SOLUTION LEVEL
 17 - LOW ELECTROLYTE SOLUTION LEVEL
 18 - INSUFFICIENT CHARGE
 19 - DEFECTIVE VLV/WEAK CELLS
 20 - VOLTAGE REGULATOR MALFUNCTION
 21 - CURRENT LIMITER MALFUNCTION
 22 - CURRENT CONTROLLER MALFUNCTION
 23 - VOLTAGE LIMITER MALFUNCTION
 24 - THERMAL OVERLOAD PROTECTION
 25 - COOLING FAN/VENTILATION MALFUNCTION
 26 - CHARGE CONTROL MALFUNCTION
 27 - CHARGE CONTROL TIMER MALFUNCTION
 28 - RECTIFIER PROBLEM
 29 - SHORT CIRCUIT
 30 - ELECTROLYTE DILUTION
 31 - FAULTY CABLE/CONNECTORS
 32 - CHARGER MALFUNCTION

FAILURE MODE

 CODE DESCRIPTION

 A - REDUCED CAPABILITY
 B - NO OUTPUT
 C - UNKNOWN/UNSPECIFIED/OTHER
 D - HIGH CURRENT/VOLTAGE OUTPUT
 E - LOW OUTPUT VOLTAGE
 F - HIGH AC RIPPLE ON DC OUTPUT
 G - MAINTENANCE REPLACEMENT
 T - TEST NOT PERFORMED

 TYPE EVENT
 CODE DESCRIPTION

 B - RECURRING COMMON CAUSE
 C - COMMON CAUSE
 R - RECURRING
 S - COMMON FAULT
 T - RECURRING COMMON FAULT
 Y - COMMON CAUSE COMMON FAULT
 W - RECURRING COMMON CAUSE COMMON FAULT
 BLANK - RANDOM

ACTIVITY RESULTING IN DISCOVERY

 CODE DESCRIPTION

 A - TESTING(UNSPECIFIED)
 B - NORMAL LOAD TESTING
 C - MONTHLY TESTING
 D - WEEKLY TESTING
 E - QUARTERLY TESTING
 F - REFUELING TESTING
 G - 18 MONTH TESTING
 H - 5 YEAR TESTING
 M - MAINTENANCE
 N - NORMAL PLANT OPERATION
 R - RECORDS REVIEW
 U - UNKNOWN

FLAGGING FIELD

 CODE DESCRIPTION

 A - FAILED COMPONENT CAUSED AN ACCIDENT
 B - COMPONENT FAILED TO MITIGATE AN ACCIDENT
 C - SAFETY SIGNIFICANT
 D - BATTERY # NOT KNOWN
 E - CELL # NOT KNOWN
 F - BATTERY # AND CELL # NOT KNOWN
 N - FROM NSIC DATA BASE

SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
AM	- AREA MONITOR SYSTEM
DB	- EMERGENCY DIESEL GENERATOR
ES	- ENGINEERED SAFETY FEATURE
FP	- FIRE PROTECTION SYSTEM
FW	- FEEDWATER SYSTEM
NM	- NEUTRON MONITORING BATTERY
NN	- UNKNOWN/UNSPECIFIED/OTHER
SA	- AUTOMATIC (REACTOR) DEPRESSURIZATION (ADS)
SP	- SPECIAL USE BATTERIES
ST	- STATION BATTERIES/CHARGERS
SW	- SERVICE WATER BUILDING BATTERIES/CHARGERS
SY	- SWITCHYARD BATTERIES/CHARGERS
UP	- UNINTERRUPTIBLE POWER SYSTEM (UPS)

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY SYSTEM

SYSTEM	CONTROL NUMBER	EVENT DATE	CONTROL POINT	STATUS	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
M	SA2	038683	BA AM 800	N	U	NO CAUSE GIVEN
M	NA1	026265	BA DB T05	R	U	7 DAY SURVEILLANCE OF EMERGENCY DIESEL GENERATOR -- BATTERIES EXCEEDED INTERVAL. PROCEDURAL
M	NA1	026266	BA DB T05	R	U	DIESEL GENERATOR BATTERIES SURVEILLANCE NOT DONE TIME LAG IN IMPLEMENTING NEW PROCEDURES
M	NA1	171672	BA DB A1410	A	T	D/G BATTERY NEAR END OF USEFUL LIFE
M	NA2	036466*	BA DB M14	E	U	1J EMERGENCY FOR 2J & 2H DIESEL GENERATORS FAILED SURVEILLANCE TEST. 4 CELLS REPLACED
M	NA2	036417	BA DB T05	R	U	DATA FROM TWO TESTS ON 2J DIESEL BATTERY FOUND NOT USABLE. NOT COMPARED WITH INITIAL CON
M	SE1	032338	BA DB 830	N	U	D/G BTRY 18-B CELL 51 SHORTED AND FAILED
M	SE1	032342A	BA DB 805	U	D	D/G BTRY 18-B CELLS 49+50+51 DISCHARGED
M	SE1	032342B	BA DB 805	U	D	D/G BTRY 18-B CELLS 49+50+51 DISCHARGED
M	TR1	014263	BA ES T05	R	U	ESF DC PWR SUPPLIES SURV REQ PERFORMED AT WRNG FREQ
B	DB1	021587	BA FP A17	N	U	4 CELLS OF ENGINE BTRY W/ ELECTROLYTE BELOW PLATE FLFC. ADDED BATTERY CELLS UP TO NORMAL
B	DB1	025397	BA FP A17	D	U	ELECTROL LEVEL IN 4 CELLS FOUND LO IN DSL ENG STA--RTING BTRY. DIESEL STILL STARTED
M	PR1	026268	BA FP T05	R	U	DIESEL DRIVEN WEEKLY BATTERY INSPECTION NOT DONE PROCEDURES WERE DEFECTIVE
M	SA1	032162	BA FP T02	R	U	92 DAY & 18 MON SURV NOT DONE ON 24 V STARTG BATT ELECTRICIAN NOT COMPLETING JOB
M	SA1	038834	BA FP B33	N	U	BATTERY CABLE CLAMP FOUND ARCING AND CRACKED CLAMP WAS REPLACED ON #2 FIRE PUMP BTRY
M	SU2	169141	BA FP B13	N	U	SMOKE DET SYS INOP BTRY CHGRG LOST POWER FAULTY POWER SUPPLY CARD IN CHARGER
M	SU2	038470	BA FP 800	U	U	SMOKE DETECTOR BATTERY FOUND NOT TO TAKE A CHARGE NO CAUSE GIVEN
M	SU2	038936A	BA FP B34	A	D	SMOKE DETECTOR BATTERY FAILED CHARGER NOT CHARGING BATTERY
M	SU2	038936B	BA FP 800	A	U	BATTERY CHARGER FOR SMOKE DETECTOR BATTERY FAILED NO CAUSE GIVEN
M	TP1	032622	BA FW B20	M	U	DIESEL-DRIVEN ACWP FAIL TO START FROM MANUAL STG FAILED STARTING BATTERY
B	CP3	017166A	BA NN T03	R	U	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES IDENTIFICATION STICKERS NOT MOVED
B	CP3	017166B	BA NN T03	R	U	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES IDENTIFICATION STICKERS NOT MOVED
B	CP3	017166C	BA NN T03	R	U	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES IDENTIFICATION STICKERS NOT MOVED
B	CP3	021165	BA NN T02	R	V	WRONG BTRY CELLS MONITORED FOR WEEKLY BATT SHPW PERSONNEL NOT FOLLOWING PROCEDURES
B	DF3	015532	BA NN T05	R	U	125-VDC INSTR & CNTRL BATTERIES NOT LOAD TESTED BCTV PROC WRONG DATA IN SUBV PRINTOUT
B	DF3	022183	BA NN B33	B	U	SMOKE FROM 1 TERMINAL OF IEC BATTERY 3CB TERMINAL DFCTV/CNCTNS FOUND DEFECTIVE
B	IT2	023084*	BA NN B13	B	U	2 CHRGRS 2-2A/B FUSE BLEW NO CHGR FOR BANK 2-25B DEFECTIVE GATING FILTER MODULES
C	AR2	026904	BA NN B1306	N	C	BATTERY CHARGER 2031 FAILED. DC OUTPUT LAMP SOCK--ET BURNED UP DUE TO HIGH HEAT/VOLT/DUST
C	AR2	027808	BA NN B21	N	S	BATTERY CHARGER 2032 AC BREAKER TRIPPED CUPRENT SURGED WHEN SHIFTING TO FLOAT
C	AR2	039245*	BA NN B00	N	U	2 OUTPUT BREAKER OF BATTERY CHARGER 2034 TRIPPED OP--EM TWICE. NO CAUSE COULD BE FOUND
C	CC1	021533	BA NN A00	A	U	125 VDC BTRY 22 CELL 54 ICV BFLOW MIN VOLTAGE CAUSE UNKNOWN
C	CC1	037262	BA NN M20	A	U	VOLT OF CELL 18 OF 125 VDC BATTERY 12 FOUND .08V --BELOW MINIMUM. FULL CAPACITY AVAILABLE

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY SYSTEM

PLANT	CONTROL NUMBER	EVENT DATE	COMP	SYSTEM	FAILURE ORDER	ACTIVITY TYPE	CLASS	FAILURE #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
C CC2	017344	021777	BA NN	B01	N S D				#11 125 VDC BATTERY INADVERTENTLY TAKEN OUT OF SERVICE.	SUPERVISOR GAVE PERMISSION
C M12	026979	080379	BA NN	M20	A U				VARIOUS CELLS REPLACED IN 201B BTRY (4 CELLS)	REDUCTION IN CELL VOLT. FULL CAPACITY
C PA1	016178	102076	RC NN	E2201	N D				DC BUS-2 VOLTG FELL VOLTG ON ASSOC AC BUSES FELL	CHRG LMR & OUTPUT BRKR SETTING ERRONEOUS
C SL1	020069	121677	BC NN	B00	N D				OUTPUT LOST FROM "AB" BATTERY CHARGER	POWER SUPPLY BKR TRIPPED FOR NO REASON
C SL1	037962	062481	BC NN	T02	R U D				SURVEILLANCE REQUIREMENTS NOT MET ON "AB" BATTERY-	CHARGER. MISINTERPRETATION OF TECH SPEC
C SL1	038775	091881	BC NN	B24	A R U				1A BATTERY CHARGER SHUTDOWN ON HIGH VOLTAGE	HIGH VOLTAGE DEVICE FOUND DEFECTIVE
W BV1	016357	102476	BA NN	M00	A U				VOLTAGE DECREASED IN CELL 48 BY MORE THAN 0.05V	UNKNOWN. CELL 48 FROM BTRY 3, 1650 A.H.
W BV1	021043	032078	BC NN	E2713	N U				DECR #4 DC BUS VOLTAGE DUE TO A FAULTY BTRY CHRGR	FAILED COLLECTR RESISTR IN CHRGR CNTRL CKT
W BV1	028147	092179	BA NN	M2010	A T				CELL #6 OF BATTERY NO. 1 COULD NOT HOLD ORIGINAL -	VOLTAGE. FULL BATTERY CAPACITY AVAIL.
W BV1	037257	061581	BC NN	B2500	N R D				#2 BATTERY CHARGER OUTPUT BREAKER FAILED OPEN	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
W BV1	038347	080581	BC NN	B2506	N R D				#2 BATTERY CHARGER OUTPUT BREAKER TRIPPED OPEN	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
W BV1	039154	101781	BA NN	M20	E R				2 OF 60 CELLS VOLTAGE FOUND DROPPED BY .05 VDC	NO CAUSE GIVEN, BATTERY HAD FULL CAPACITY
W DC1	025643	032379	BC NN	D01	N U D				125 VDC EQUALIZING CHARGE TOO HIGH, FAILED INVERT-	ER, CAUSED SCRAM AND SI. NO CAUSE
W DC2	021633	060778	BA NN	A14	A U				CD PLANT BTRY CELL 89 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W DC2	021632	061578	BA NN	A14	A U				AB PLANT BTRY CELL 35 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W DC2	039127	101981	BA NN	T05	R U D				SURVEILLANCE NOT PERFORMED ON "N" TRAIN BATTERY	PROCEDURE LACKED SIGNOFF
W HN1	014608A	042576	BC NN	D2833	N U				BTRY CHARGER A WENT INTO OVERCHARGE	FAULTY CNCT ON CHARGER CONTROL TIMER
W HN1	014608B	042576	BC NN	D2122	N U				VOLTG REG SPIKING TO 200 AMPS THEN SHUTTING OFF	FAULTY PHASING CRD IN CURRENT LIMITER CKT
W IP3	014709	051076	BC NN	B2630	A U				BTRY CHRGR TROUBLE ALARMED CHARGER FAN HAD TRPD	AC FAN MTR INOP EXPOSED WIRE BLEW A FUSE
W IP3	015138	060876	BC NN	B13	A S U				# 31 BTRY CHRGR AC BRKR TRIPD BATT CHRGR INOP	PRESSURE SENSOR FAILED TRIPPING BREAKER
W IP3	036207	012481	BC NN	B2123	N U				OUTPUT FROM CHARGER #32 DISCOVERED DROPPING	VOLTAGE AND CURRENT CONTROLLER REPLACED
W IP3	038257	070681	BC NN	B13	N S U				BATTERY CHARGER #32 DISCOVERED TRIPPED	FATLED DP AIR FLOW SENSOR SWITCH
W JF1	027181	090679	BA NN	T03	R U D				QUARTERLY AUXILIARY BUILDING BATTERY VERIFICATION-	NOT PERFORMED ON TIME. PERSONNEL
W PR1	033222	110580	BC NN	A2911	A U				#12 BTRY CHRGR FAILED TO PROVIDE NORMAL OUTPUT	FIRING CARD B NOT PROVIDING PULSE TO SCR
W PR2	014599	041476	BC NN	B2133	B U				#12 BATTERY CHARGER FAILED DISABLED "B" DC POWER	VOLTAGE CNTRL CRD LOOSE IN ITS SOCKET
W RD2	015515	071076	BA NN	B02	M D				BATTERY B LEADS WERE REMOVED RENDERING BATT INOP	PFRS FAILED TO COMPLY W/ T.S. 3.7
W SA1	020738A	020178	BA NN	A34	N U				1C 125V BATTERY VOLTAGE LOW	1C1, 1C2 BATT CHARGER D.C. BRKRS TRPD
W SA1	020738B	020178	BC NN	B00	N U	2			1C1, 1C2 BATT CHARGER D.C. BRKRS TRIPPED	UNKNOWN CAUSE
W SA2	038319	072481	BC NN	B2101	N U D				2C1 BATTERY CHARGER DISCOVERED TRIPPED. VOLTAGE -	SETTING WAS INCORRECTLY SET
W SA2	038327	081281	BC NN	B24	N U				2B1 BATTERY CHARGER WOULD NOT PICK UP 28 VDC LOAD	HIGH VOLTAGE CUT-OUT ACTUATED
W TR1	020885	031778	BA NN	T02	R U D				125 VDC ELECTRICAL SYS OP NOT VERIFIED WK OF 2-26	MAINT PERS FAILED TO INSURE SURV COMPLETED
W TR1	025211A	011979	BA NN	T03	R U D				125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY SYSTEM

P N S L A S Y	CONTROL NUMBER	EVENT DATE	C D I M P	S Y S T E M	F A I L U R E C O D E	A C T I V E C L O S U R E	F A I L U R E C L O S U R E	F A I L U R E C L O S U R E	F A I L U R E C L O S U R E	F A I L U R E C L O S U R E	F A I L U R E C L O S U R E
W	YR1	025211R	011979	BC	NN	T03	R	U	D	125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL
W	Y03	033530A	121180	BC	NN	C00	N	U		NO CAUSE GIVEN	
W	Y03	033530B	121180	BA	NN	T34	M	U	T	PROBLEMS WITH 4B 125 VDC BATTERY CHARGER	
W	Y03	033530C	111701	BA	NN	B20	A	R	U	4B 125 VDC BATT OOS+TECH SPEC EXCEEDED	PROBLEM W/ ASSOCIATED BTRY CHARGER
W	YR1	019476A	101477	BC	NN	B1210	M	R	T	*3A" 125 VDC FAILED TO HOLD A CHARGE	BEING EVALUATED W/ MANUFACTURER
W	YR1	019476B	101477	BC	NN	T01	M	U	D	NO. 2 BATTERY CHARGER TAKEN OUT OF SERVICE	FAILED BEARING
W	YR1	019460	110577	BC	NN	B1210	M	R	T	NO. 1 BATTERY CHARGER CROSS TIED TO NO. 2 BATTERY	OVERSIGHT CAUSE LCD STATED IN TECH SPEC
W	Z11	171128A	121281	BA	NN	B01	M	U	D	NO. 1 BATTERY CHARGER TAKEN OUT OF SERVICE	FAILED BEARING DUE TO NORMAL WEAR
W	Z11	171128B	121281	BC	NN	B01	M	U	D	UNIT 2 212 BATTERY TAKEN OOS ERRONEOUSLY	LICENSED OPERATOR ERROR
W	Z11	172130	121581	BA	NN	C05	U	U	D	UNIT 2 212 CHARGER TAKEN OOS ERRONEOUSLY	LICENSED OPERATOR ERROR
B	CP3	038100	071481	BA	ST	B3002	M	C	D	EQUALIZING CHARGE NOT PLACED ON BATTERY 112	PROCEDURE NOT CLEAR ON COMMUNICATIONS
B	DR1	020448	011978	BA	ST	A1415	E	U		STATION BATTERY SHORTED DURING MAINTENANCE	PERSONNEL ERROR, CAUSED REACTOR TRIP
B	DR1	022362	090578	BA	ST	T02	R	U	9	IN BTRY CELL 32 ELECTROLYTE S.G. DECRS -003 ODT	ELFC, STRAY, DUE TO LO BTRY LOADING
C	AP2	026489	032279	BA	ST	T03	R	U	D	STATION BATTERIES W/ SUPV TEST NOT DONE ON TIME	MISUNDERSTANDING BTWN PERSONNEL
C	PAL	025917	040479	BA	ST	B2005	A	C	D	SURVEILLANCE NOT PERFORMED ON STATION BATTERIES	PERSONNEL OVERSIGHT
C	PAL	036000*	010681	BA	ST	B02	U	U	D	2 CELLS IN STATION BATTERY #2 BURST WHILE TAKING -	--VOLTAGE READINGS, FULL CAPACITY AVAL
W	RV1	017119A	020477	BA	ST	T03	R	U	D	SURVEILLANCE TEST NOT PERFORMED ON #3 & #4 STATIO-	-ED FOR 1 HOUR, PERSONNEL ERROR
W	RV1	017119B	020477	BC	ST	T03	R	U	D	2 OUTPUT BREAKER FOR BOTH STATION BATTERIES WERE OP-	-N BATTERIES, PERSONNEL ERROR
W	RV1	022136	080478	BC	ST	B00	E	U		SURVEILLANCE TEST NOT PERFORMED ON CHARGERS ASSOC-	-ATED WITH #3 & #4 STATION BTRY, PERSON
W	RV1	038825	091081	BC	ST	B33	N	U		NO. 1 BATTERY CHARGER OUTPUT BRKR TRIPPED	IMPROPR OP OF CKTRK, CAUSE OF TRP UNKNOWN
W	MG1	039186	101981	BA	ST	A3308	M	T		#4 STATION BATTERY CHARGER TAKEN OUT OF SERVICE	RAD ELECTRICAL CONNECTION IN OUTPUT
W	NA1	036491A	022881	BA	ST	T02	R	U	D	CELL TO CELL RESISTANCE IN 3 CELLS FOUND HIGH	CORROSION OF TERMINAL CONNECTIONS
W	NA1	036491B	022881	BC	ST	T02	R	U	D	18 MONTH SURVEILLANCE ON D.C. DISTRIBUTION SERVIC-	-E SYSTEM NOT DONE, PERSONNEL OVERSIGHT
W	PR1	030917	033180	BA	ST	T02	R	U	D	18 MONTH SURVEILLANCE ON D.C. DISTRIBUTION SERVIC-	-N SYSTEM NOT DONE, PERSONNEL OVERSIGHT
W	PD2	021898	071678	BA	ST	B3311	N	U		INDIVIDUAL FLOAT CELL VOLT MEAS NOT DONE IN STATI-	-ON BATTERY TEST, PERSONNEL OVERSIGHT
W	T03	022061A	122777	BA	ST	T01	U	U	D	PLASTIC TOP OF 2 STATION "A" BATT CELLS ON FIRE	RESISTING HEATG OF STRAP-CELL TERMINAL
W	T03	022061B	127977	BA	ST	T01	U	U	D	EQUALIZING CHARGES ON STATION BATTERIES NOT PERFO-	-RMED, PERSONNEL ERROR+FULL CAPACITY AVAL
W	YR1	019861	120577	BA	ST	A20	E	U		EQUALIZING CHARGES ON STATION BATTERIES NOT PERFO-	-RMED, PERSONNEL ERROR+FULL CAPACITY AVAL
W	JF1	021235A	041878	BA	SM	B00	E	U		CELL VOLTAGE ON CELL 18 OF BANK 1 FOUND LOW	NO CAUSE FOUND+CELL REPLACED
W	JF1	021235B	041878	BA	SM	B00	E	U		2 CELLS IN SW BLDG "A" BATT BANK 1 FAILED T.S. PFO	CAUSE COULD NOT BE DETERMINED
W	JF1	021235C	041878	BA	SM	B00	E	U		2 CELLS IN SW BLDG B BATT BANK 2 FAILED T.S. PFO	CAUSE COULD NOT BE DETERMINED
W	JF1	032326A	081280	BA	SM	A14	A	R	U	SW BLDG B BTRY SYS LOW SPECIFIC GRAVITY	BATT PLACED ON EQUALIZE & S.G. ACCEPTIBLE
W	JF1	032326B	082580	BA	SM	A14	A	R	U	SW BLDG B BTRY SYS LOW SPECIFIC GRAVITY	NO EXTERNAL CAUSE FOR LOW SPECIFIC GRAV

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY SYSTEM

SYSTEM	CONTROL NUMBER	EVENT DATE	SYMBOL	FAULT	DESCRIPTION	FAILURE CAUSE DESCRIPTION
M JFI	032504	082590	BC	SM B24	M S U	SM B DC DISTRIBUTION SYS INOP NO OUTPUT FROM BATT--CHGR 4. HV SPD RELAY ACTUATED
M JFI	032687	091190	BA	SM A1404	A D	SM BLOG "AM" BATT SYS LO BATT CELL SPECIFIC GRAVITY CLOSE TERM POST PROX/ACID P-SIDUE/DESIGN
M JFI	033007	102190	BA	SM A1404	A D	SM "AM" BTRY SYS LOW CELL SPECIFIC GRAVITY CLOSE TERM POST PROX/ACID W-SIDUE/DESIGN
M JFI	033163	102980	BA	SM A1404	A D	SM BLOG "AM" BATT SYS LOW CELL SPECIFIC GRAVITY CLOSE TERM PROX/ACID RES/POST SEAL DESIGN
G EN2	032981A	032391	BA	AM B1834	N D	POST TREATMENT MON 2011-K615A BATTERY DRAINED BATTERY CHARGER ZAB 24/48 VDC FAILED
G BP1	015444	081276	BA	DB B33	N T	EMERGENCY DIESEL GENERATOR DID NOT START DUE TO L--DISE BATTERY CONNECTION.
G FH1	021719	062778	BA	DB T02	R U D	WPLY PILOT CELL SURV OF IC D/G BTRY NOT COMPLET-- ED ON TIME. PERSONNEL OVERSIGHT
G FN2	036943C	040781	BA	DB A1602	N C D	ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF DIE--SEL GENERATOR BATTERY. PERSONNEL ERROR
G EN2	036943D	040781	BA	DB A1702	N C D	ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF DIE--SEL GENERATOR BATTERY. PERSONNEL ERROR
G OC1	021497A	052478	BA	DB T01	H U D	D/G BTRY LOAD TESTING NOT PERFORMED IN TIME
G OC1	023298A	121378	BA	DB T01	R U D	D/G BTRY NOT TESTED/MONITORED W/IN TIME INTERVAL
G OC1	030599B	022680	BA	DB T02	R U D	DIESEL GENERATOR BTRY SURV TEST NOT PERFORMED
G BP1	019025A	082977	BA	FP B3302	N D	DIESEL FIRE PUMP "AM" BATTERY FOUND WITH NO OUTPUT CONNECTORS NOT TIGHTENED
G BP1	019025B	082977	BA	FP B00	N U	DIESEL FIRE PUMP "BM" BATTERY FOUND WITH NO--OUTPUT. DISCHR WITH NO APPARENT CAUSE
G BP1	021307	050478	BA	FP A17	D U	FIRE PUMP DIESEL STARTG BTRY A CELLS 1.3.5 LO -- ELECTROLYTE SOLN. EXACT CAUSE UNKNOWN
G BP1	021519	052578	BA	FP A1705	D D	PIPE PUMP DIESEL STARTG BTRY "AM" CELLS 2.4.6 LO-- ELECTROLYTE SOLN. INADQ MAINTENANCE PROC
G DP1	018553A	072977	BA	FP B3413	N C D	2 DIESEL FIRE PUMP BATTERIES FAILED TO START DIESEL FAILED FUSE FROM BATTERY CHARGER CIRCUIT
G DP1	018553B	072977	BC	FP B22	N U	FUSE FOUND BLOWN IN DIESEL FIRE PUMP BATTERY CHAR--GER.
G FP1	021433	053178	BA	FP A1420	A U	LO S.G. OF BTRY A2 CELL
G FP1	031743*	062490	BA	FP A14	A T	2 DIESEL FIRE PUMP 24V BATT CELLS A2-6.82-1 LOW S.G. CHARGER D05 DURING SURVEILLANCE
G BF2	045394	070976	BA	NM B3302	M U D	NEUTRON MONITORING BATTERY 2A MADE INOPERABLE
G FP1	171811	123051	BA	NM B18	N D	2 LOW VOLTAGE FROM DIVISION I 24 VDC BATTERIES. CAUS -ED ERATIC READINGS ON LHM & SRM INST
G BP1	038085	072781	BA	NN A20	U U	250 VOLT MAIN BATTERY TAKEN D05 TO BYPASS A CRACK--ED CELL.
G BP1	033637	127380	BA	NN T02	R U D	DC BATTERY MONTHLY TESTS OVERDUE
G BP1	019389	102177	BC	NN R2206	B U	BATT CHGR DC OUTPT FUSE FAILD WHEN CHRG BATT 2B-2 HI CURR/TEMP CAUSD SOLDERD LINKG SEPARATE
G BP1	025637A	032579	BA	NN A3308	B R T	BATTERY 1B2 VOLTAGE FELL TO 102.5V THEN ROSE TO --119V. CORRODED AND LOOSE BTRY CONNECT
G BP1	025637B	032779	PA	NN A3308	B R T	BATTERY 1B1 VOLTAGE FELL TO 96.8V THEN ROSE TO 119V CORRODED AND LOOSE BTRY CONNECTORS
G BP2	044651	021276	BA	NN T05	R U D	MONTHLY INSTEAD OF QUARTERLY BATTERY P.T. PERFORMD WRONG P.T. SCHEDULED BY MISTAKE
G C01	022101A	062778	BC	NN B2333	N T	1A 250V BTRY CHRG TIE BREAKER TRIPPED
G C01	022101B	062778	BC	NN B3304	N U D	1A 250V BTRY CHRG INPUT BREAKER TRIPPED
G DP1	030982	041780	BA	NN T02	R U D	WPLY BATT SURV DOCUMENTATION NOT COMPLETED
G DP1	171665	120881	BC	NN E00	N U	BATTERY CHARGER OUTPUT INCORRECT

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY SYSTEM

PLANT	CONTROL NUMBER	EVENT DATE	COMP	SYSTEM	FAILURE ORDER	ACTIVITY	CLASS	FAILURE	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G DR2	039116	102181	BA NN	T01		R U D			QUARTERLY STORAGE BATTERY SURVEILLANCE DONE 7 DAY--	-S LATE. OVERSIGHT BY OPERATING SHIFT
G DR3	016265A	101876	BA NN	A34		A D			BATTERY IN A DEGRADED CONDITION	
G DR3	016265B	101876	BC NN	C00		A U			CHARGER SUBJECTED BTRY TO "DEEP CYCLING"	CHARGER SUBJECTED BTRY TO "DEEP CYCLING"
G DR3	020853	032878	BA NN	A10		F R T			24/48 V BTRY FAILED THE REFUELLING OUTAGE DISCHRG-	-TEST. 4 CELLS REPLCD NAT'L END OF LIFE
G DR3	025951	042479	BA NN	B01		N U D			UNIT 2'S BATTERY NOT RETURNED TO NORMAL LINEUP	BREAKER COULD HAVE BEEN SHUT AT ANY TIME
G DR3	036569	030381	BA NN	T01		R U D			WEEKLY STORAGE BATTERY SURVEILLANCE DONE 4 DAYS L-	-ATE. OVERSIGHT BY OPERATING SHIFT
G EN1	027782	112679	BA NN	T03		R U D			CELL SU VEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT
G EN2	022208	081678	BA NN	T02		R U D			WKLY PILOT CELL SURV OF PLANT BATT NOT COMPLETED--	ON TIME. NOTICES ROUTED TO ABSENT PERS
G EN2	026657	071879	BA NN	T03		R V D			CELL SURVEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT
G EN2	032981B	032381	BC NN	B00		N U			24/48 VDC BATTERY CHARGER FOUND NOT CHARGING	NO CAUSE GIVEN
G MO1	166730A	061581	BA NN	A3401		A D			250 VDC BATTERY INADVERTENTLY DISCHARGED	PERS DISCONNECTED TEMP BATTERY CHARGER
G MO1	166730B	061581	BC NN	B01		A U D			TEMPORARY BATTERY CHARGER TAKEN OUT OF SERVICE	PERSONNEL ERROR, CAUSED BTRY TO DISCHARGE
G OC1	038737	091181	BA NN	T02		R U D			BATTERY SURVEILLANCE PROCEDURES FOUND NOT TO FULL-	-Y COMPLY WITH NEW REQUIREMENTS.
G PR3	014211	012976	BA NN	A14		B U			B BTRY CAPACITY BELOW DESIGN	CELL S.G. IN LO RNG, PARTIAL ACID RPLCD
G P11	033899	082180	BC NN	B2113		N U			"A" 125 VDC CONTROL BATT CHARGER INOPERABLE	VOLTAGE REGULATOR ELECTRONIC MODULES FPLC
G OC1	019222	092477	BA NN	M2010		U T			BATTERY SYSTEM TAKEN OUT OF SERVICE	REPLACED 12 WEAK CELLS, NORMAL END OF LIFE
G OC2	018164	031777	BC NN	C23		U U			UNITS BATTERY CHARGER APPARENTLY INOPERABLE	FAULTY INDUCTIVE CURRENT CONTROL CIRCUIT
G OC2	018460	060977	BC NN	E2101		N U D			BATTERY CHARGER SUPPLYING CURRENT TO BATTERY FOUN-	-D LOW. FLOATING POTENTIOMETER SET LOW
G VY1	021749	061978	BC NN	B06		N S D			AC INPUT BRKR TO CA1 BATT CHRGR TRPD OPEN	SPURIOUS TRP OF AC BRKR IN AN ELEC STERN
G BP1	015326A	072276	BA SA	A17		C U			RDS BATTERY D PILOT CELL LOW ELECTROLYTE LEVFL	EXACT CAUSE UNKNOWN
G BP1	015326B	072276	BA SA	A1432		C D			RDS BATTERY D PILOT CELL HAD LOW SPECIFIC GRAVITY	ADDITION OF WATER POSSIBLE CAUSE
G BP1	015327A	072876	BA SA	A17		C U			RDS BTRY C PILOT CELL LOW ELECTROLYTE LEVEL	UNKNOWN CAUSE
G BP1	015327B	072976	BA SA	T14		C U D			RDS BTRY C PILOT CELL RDG LO SPECIFIC GRAVITY	DECTV PROC SPECIFIC GRAVITY READ TOO SOON
G BP1	016073B	100376	BA SA	A17		A U			RDS D BTRY PILOT & 3 OTHER CELLS LO ELECTROLYTE -	-LEVEL. UNKNOWN CAUSE
G BP1	016073A	100476	BA SA	A1405		A D			RDS D BTRY PILOT & 3 OTHER CELLS LO SPEC GRAVITY	INCOMPLETE ELECTROLYTE MIXING
G BP1	016305A	102176	BA SA	A14		D U			RDS "A" BTRY PILOT CELL 55 LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G BP1	016459	110476	BA SA	A14		C U			RDS B PILOT CELL LOW SPECIFIC GRAVITY	UNKNOWN CAUSE
G BP1	016305B	112176	BA SA	A14		D U			RDS "A" BTRY PILOT CELL 55 LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G BP1	016584	120276	BA SA	A14		D U			RDS B BTRY PILOT CELL 27 LO SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G BP1	017023	120976	BA SA	A14		D U			RDS B ONE CELL LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G BP1	017024*	010477	BA SA	M14		A R U	2		B CELLS SPECIFIC GRAVITY FOUND BELOW 1.2. EVALUA-	-TION REVEALED ADEQUATE CAPACITY
G BP1	017464	022477	BA SA	M14		C R U			RDS BATTERY B HAD ONE CELL BELOW MINIMUM SPECIFIC-	-GRAVITY. ADEQUATE CAPACITY AVAILABLE

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY SYSTEM

SYSTEM	PLANT	CONTROL NUMBER	EVENT DATE	COMP	UNIT	FALC UO DEE	A C T I V I T Y	C L A S S	F A I L	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G BP1	017463	031777	BA SA M14	C R U						SPECIFIC GRAVITY FOUND LOW IN 5 CELLS OF RDS BTRY-- "A". ADEQUATE CAPACITY AVAILABLE	
G BP1	018096A	042177	BA SA M14	C R U						RDS BATTERY B, CELL 27 FOUND TO HAVE LOW SPECIFIC GRAVITY OF 1.191. FULL CAPACITY AVAILABLE	
G BP1	018096B	042777	BA SA M14	C U						SPECIFIC GRAVITY OF 10 MARGINAL CELLS ADJUSTED BY ADDING WATER TO CELL 27 OF RDS BATTERY "B". FULL CAPACITY AVAILABLE	
G BP1	018462A	061677	BA SA A17	U R U						WATER ADDED TO CELL 27 OF RDS BATTERY "B". NO CAUSE GIVEN FOR LOW WATER LEVEL	
G BP1	018462B	061677	BA SA T1432	C V D						SPECIFIC GRAVITY OF CELL 27 OF RDS BATTERY B LOW WATER ADDED THEN TESTED TOO SOON	
G BP1	019472A	092977	BA SA A17	U R U						WATER ADDED TO CELL 12 OF RDS BATTERY "A". NO CAUSE GIVEN FOR LOW WATER LEVEL	
G BP1	019472B	092977	BA SA A1432	C R D						SPECIFIC GRAVITY OF CELL 12 OF RDS BATTERY "A" LOW WATER ADDED, CHARGE INSUFFICIENT TO MIX	
G BP1	019542A	100877	BA SA A17	U R U						WATER ADDED TO 3 CELLS OF RDS BATTERY "D". NO CAUSE GIVEN FOR LOW WATER LEVEL	
G BP1	019542B	102077	BA SA A1432	C R D						SPECIFIC GRAVITY OF 3 CELLS OF RDS BATTERY "D" LOW WATER ADDED, MIXING WAS INADEQUATE	
G BP1	020176	122277	BA SA A14	C R U						SPECIFIC GRAVITY ON RDS BATTERY "A", CELL 12 LOW EQUALIZING CHARGE FOR 8 HOURS CORRECTED	
G BP1	022664	083178	BA SA A14	C R U						RDS BATTERY A, CELL 12 LOW SPECIFIC GRAVITY READING EXACT CAUSE UNKNOWN	
G BP1	027985	110179	BA SA A1420	C U						SPECIFIC GRAVITY OF CELL 48 OF RDS BATTERY C LOW CELL REPLACED, WOULD NOT TAKE EQUAL CHARGE	
G RP1	030237	012480	BA SA A1420	C U						RDS C BTRY CELL 14 LOW SPECIFIC GRAVITY RDG DEFECTIVE CELL REPLACED	
G BP1	031176	050180	BA SA A1420	C U						RDS BTRY "A" CELL 2 LOW SPECIFIC GRAVITY RDG CELL DID NOT RESPOND ADQ TO EQUALIZG CHRG	
G BP1	031848	071080	BA SA A1420	C U						RDS C BTRY CELLS 35, 54 LOW SPECIFIC GRAVITY RDG CELL DID NOT RESPOND ADQ TO EQUALIZG CHRG	
G BP1	032023	071080	BA SA A20	D U						RDS C BTRY PILOT CELL UNIT-9 INTERNAL RESISTANCE-- INCRS. CAUSE UNKNOWN	
G BP1	032297	080780	BA SA A14	C U						RDS C BTRY CELLS 38, 39, 56 LOW SPECIFIC GRAVITY VENDOR RECOM INCRS IN FLOAT VOLTAGE LEVEL	
G BP1	032656	091180	BA SA A1420	C U						RDS D BATTERY CELL 12 LOW SPECIFIC GRAVITY RDG CELL DID NOT ADQ RESPOND TO EQUALIZG CHRG	
G BP1	033544	121190	BA SA A1402	C D						21 CELLS OF RDS "A" BATTERY LOW SPECIFIC GRAVITY CELL TERMINALS INADQ CLEANED BY MAINT PER	
G BP1	037338	010281	BA SA A1420	C R U						RDS CH D BATTERY CELL 56 HAD LOW SG, WOULD NOT RESPOND TO EQUALIZING CHARGE.	
G BP1	038112	081581	BA SA A1602	A C D						FOUND PILOT CELL IN CH A POS POWER SUPPLY WITH A HIGH ELEC LEVEL. POSSIBLY OVERFILLED	
G BP1	038785	091581	BA SA A1420	C U						"A" RDS BTRY CELL #5 LOW SPECIFIC GRAVITY CELL DIDN'T RESPOND ADQ TO EQUALIZG CHRG	
G BF2	025671	041979	BA SP B3302	N C D						BROKEN TERMINAL DISCOVERED ON S/D BOARD "D" BTRY PERSONNEL ERROR. ALSO AFFECTED UNIT 1	
G BP1	015248A	063076	BC ST B29	N U						STATION BATTERY CHARGER FAILED DEFECTIVE SILICON RECTIFIERS	
G BP1	015248B	063076	BA ST A18	N D						LOAD ON BTRY REDUCED VOLTAGE & SPECIFIC GRAVITY STATION BATTERY CHARGER HAD FAILED	
G BP1	038592	083181	BA ST A2014	C C D						LOW SG IN CELL 43 OF ST BTRY, CELL FOUND CRACKED.-- THIS LEAD TO DILUTION, CRACKED WHEN MOVED	
G CO1	037646	050581	BC ST G29	B U						HIGH RIPPLE FROM BATTERY CHARGER WHICH FAILED INVERTER 1A. FAILED SCR	
G CO1	027938	052881	BA ST T03	R U D						SG TESTS FOR 125V 1A8B AND 250V 1B NOT PERFORMED PROPERLY. PERSONNEL USED WRONG HYDREM	
G EN1	021475*	060478	BC ST M1304	M D	2					HEAT-SENSITIVE XSTR ON BATT CHRGR FIRING MODUL CRD SHOULD BE A NON-HEAT-SENSITIVE TRANSISTOR	
G EN2	030651*	032580	BC ST A2122	G U	2					EMER STATION BATT CHRGR 26, 2J FAILED TO HOLD LOAD VOLTG CNTRL & CURR LMT MODULES TUNED	
G EN2	030711A	032780	BC ST A29	G U	2					STATION BATT CHRGR 2A, 2B FAILED TO MAINTAIN LOADS SILICON CNTRL RECTIFIERS NEED LOAD BALANC	
G EN2	030711B	032780	BC ST A22	G U						STATION BATT CHRGR 2C FAILED TO MAINTAIN LOAD CURRENT LIMIT MODULE NEEDED ADJUSTMENT	

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY SYSTEM

SYSTEM	CONTROL NUMBER	EVENT DATE	LOCATION	STATUS	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G	FN2	033891	081180 BA ST B30	M U	DC BATT GROUND ON 28 STATION SERVICE BATTERY	NO CAUSE GIVEN
G	FN2	036943A	040781 BA ST A1602	N C D	2 ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF ST	--BTTPYS 2R42-S001A6B. PERSONNEL ERROR
G	FN2	036943B	040781 BA ST A1702	N C D	2 ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF ST	--TTPYS 2R42-S001A6B. PERSONNEL ERROR
G	FP1	019457	102077 BA ST A20	U	STATION BATTERY "B" FOUND TO HAVE CRACKED CELL	NO CAUSE KNOWN FOR CRACKED CELL #228
G	FP1	026922	090479 BA ST A20	N U	LEAKING CELL NOTED IN BATTERY "B". BATTERY TEMPOR-	--ARILY INOP WHILE CELL JUMPERED
G	FP1	033280	111780 BA ST A10	N Y	STATION BTRY B MADE INOP TO JUMP A CELL	CELL #8 POOR PERFORMANCE DUE TO AGE
G	OC1	021497B	022478 BA ST T01	M U D	STATION BTRY LOAD TESTING NOT PERFORMED IN TIME	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G	OC1	023298B	121378 BA ST T01	R U D	STATION BTRY NOT TEST/MONITOR W/IN TIME INTERVAL	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G	OC1	030598A	022880 BA ST T02	R U D	MAIN STATION BTRY SURV TEST NOT PERFORMED	PLANT PERS. FAILED TO ADHERE TO SUPV SCHEDULE
G	M11	014478	040776 BA SY T01	R U D	SWITCHYARD BTRY SURVEILLANCE NOT PERFORMED W/IN--	REQ TIME PERIOD. PERSONNEL ERROR
G	OC1	018293A	062877 BA SY B34	U C D	ONE OF TWO SWITCHING STATION BATTERIES FOUND ODS	--FOR 11 DAYS. BATTERY CHARGER FAILED
G	OC1	018293B	062877 RC SY B2713	U	BATTERY CHARGER FOR SWITCHING STATION BATTERY #DU--	--NO ODS AFTER 11 DAYS
G	P11	027950A	122379 BC SY B03	U R U	SWITCHYARD 125 VDC BATTERY CHARGER FAILED	NO CAUSE GIVEN
G	P11	027950B	122479 BC SY B00	N R U	SWITCHYARD 125 VDC BACKUP BATTERY CHARGER FAILED	NO CAUSE GIVEN
G	BP1	017704*	033077 BA UP B3304	N C D	4 NO OUTPUT FROM ALL UPS BATTERY BANKS	CONNECTORS NOT TIGHTENED DURING INSTAL
G	VY1	016217A	101376 BA UP A34	N R U	UPS--1B CTRL PWR BTRY VOLTAGE WAS LUM	CTRL BATT CHRGNG POWER SUPPLY FAILED
G	VY1	016217B	101376 BC UP B21	N R U	CTRL BTRY CHARGING POWER SUPPLY FAILED	INOPERATIVE VOLTAGE REGULATOR CIRCUIT
G	VY1	018407A	031877 BA UP A3413	N R D	UPS--1B ALARMED DUE TO LOW VOLTAGE, CAUSED SCRAM	CAPACITOR FAILED IN CHARGING POWER SUPPLY
G	VY1	018407B	031877 BC UP B13	N T	UPS--1B CONTROL CHARGING POWER SUPPLY FAILED	FAILED CAPACITOR IN ON/OFF CIRCUITRY
G	VY1	025519	031779 BC UP B00	N U	CONTROL CHARGING POWER SUPPLY FAILED	NO CAUSE GIVEN. CAUSED BATTERIES DISCHR

APPENDIX F
ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS
SORTED BY FAILURE MODE

SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
AM	- AREA MONITOR SYSTEM
DB	- EMERGENCY DIESEL GENERATOR
ES	- ENGINEERED SAFETY FEATURE
FP	- FIRE PROTECTION SYSTEM
FW	- FEEDWATER SYSTEM
NM	- NEUTRON MONITORING BATTERY
NN	- UNKNOWN/UNSPECIFIED/OTHER
SA	- AUTOMATIC (REACTOR) DEPRESSURIZATION (ADS)
SP	- SPECIAL USE BATTERIES
ST	- STATION BATTERIES/CHARGERS
SW	- SERVICE WATER BUILDING BATTERIES/CHARGERS
SY	- SWITCHYARD BATTERIES/CHARGERS
UP	- UNINTERRUPTIBLE POWER SYSTEM (UPS)

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE MODE

NSYS	PLANT	CONTROL NUMBER	EVENT DATE	COMP	SYSTEM	FAILURE CODE	ACTIVITY TYPE	CLASS	FAIL	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
B	DB1	020448	011978	BA	ST	A1415	E	U		3N BTRY CELL 32 ELECTROLYTE S.G. DECREAS .003 OUT	ELFC. STRAT. DUE TO LO BTRY LOADING
B	DB1	021587	042778	BA	FP	A17	N	U		4 CELLS OF ENGINE BTRY W/ ELECTROLYTE BELOW PLATE	ELEC. ADDED BROUGHT CELLS UP TO NORMAL
B	DB1	025397	020879	BA	FP	A17	D	U		ELECTROL LEVEL IN 4 CELLS FOUND LO IN DSL ENG STA-	-RTING BTRY. DIESEL STILL STARTED
C	CC1	021533	050378	BA	NN	A00	A	U		125 VDC BTRY 22 CELL 54 ICV BELOW MIN VOLTAGE	CAUSE UNKNOWN
W	DC2	021633	060778	BA	NN	A14	A	U		CO PLANT BTRY CELL 89 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W	DC2	021632	061578	BA	NN	A14	A	U		AB PLANT BTRY CELL 35 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W	JF1	032332A	081280	BA	SW	A14	A	R	U	SW BLDG B BTRY SYS LOW SPECIFIC GRAVITY	BATT PLACED ON EQUALIZE & S.G. ACCEPTABLE
W	JF1	032332B	082590	BA	SW	A14	A	R	U	SW BLDG B BTRY SYS LOW SPECIFIC GRAVITY	NO EXTERNAL CAUSE FOR LOW SPECIFIC GRAV
W	JF1	032687	091180	BA	SW	A1404	A	D		SW BLDG "A" BATT SYS LO BATT CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN
W	JF1	033007	102180	BA	SW	A1404	A	D		SW "A" BTRY SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN
W	JF1	033163	102880	BA	SW	A1404	A	D		SW BLDG "A" BATT SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM PROX/ACID RES/POST SEAL DESIGN
W	MG1	039186	101981	BA	ST	A3303	M	T		CELL TO CELL RESISTANCE IN 3 CELLS FOUND HIGH	CORROSION OF TERMINAL CONNECTIONS
W	NA1	171672	120181	BA	DB	A1410	A	T		14 EMERGENCY D/G INDP CELL S.G. BELOW 1.2	D/G BATTERY NEAR END OF USEFUL LIFE
W	PR1	033222	110580	BC	NN	A2911	A	U		#12 BTRY CHRGR FAILED TO PROVIDE NORMAL OUTPUT	FIRING CARD B NOT PROVIDING PULSE TO SCR
W	SA1	020738A	020178	BA	NN	A34	N	U		1C 125V BATTERY VOLTAGE LOW	IC1, IC2 BATT CHARGER D.C. BRKRS TRPD
W	YR1	019861	120577	BA	ST	A20	E	U		CELL VOLTAGE ON CELL 18 OF BANK 1 FOUND LOW	NO CAUSE FOUND, CELL REPLACED
G	BF1	038085	072281	BA	NN	A20	U	U		250 VOLT MAIN BATTERY TAKEN ODS TO BYPASS A CRACK-	-FD CELL.
G	BP1	015248B	063076	BA	ST	A18	N	D		LOAD ON BTRY REDUCED VOLTAGE & SPECIFIC GRAVITY	STATION BATTERY CHARGER HAD FAILED
G	BP1	015326A	072276	BA	SA	A17	C	U		RDS BATTERY D PILOT CELL LOW ELECTROLYTE LEVEL	EXACT CAUSE UNKNOWN
G	BP1	015326B	072276	BA	SA	A1432	C	D		RDS BATTERY D PILOT CELL HAD LOW SPECIFIC GRAVITY	ADDITION OF WATER POSSIBLE CAUSE
G	BP1	015327A	072876	BA	SA	A17	C	U		RDS BTRY C PILOT CELL LOW ELECTROLYTE LEVEL	UNKNOWN CAUSE
G	BP1	016073B	100376	BA	SA	A17	A	U		RDS D BTRY PILOT & 3 OTHER CELLS LO ELECTROLYTE -	-LEVEL. UNKNOWN CAUSE
G	BP1	016073A	100476	BA	SA	A1405	A	D		RDS D BTRY PILOT & 3 OTHER CELLS LO SPEC GRAVITY	INCOMPLETE ELECTROLYTE MIXING
G	BP1	016305A	102176	BA	SA	A14	D	U		RDS "A" BTRY PILOT CELL 55 LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BP1	016459	110476	BA	SA	A14	C	U		RDS B PILOT CELL LOW SPECIFIC GRAVITY	UNKNOWN CAUSE
G	BP1	016305B	112176	BA	SA	A14	D	U		RDS "A" BTRY PILOT CELL 55 LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BP1	016584	120276	BA	SA	A14	D	U		RDS B BTRY PILOT CELL 27 LO SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BP1	017023	120976	BA	SA	A14	D	U		RDS B ONE CELL LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BP1	018462A	061677	BA	SA	A17	U	P	U	WATER ADDED TO CELL 27 OF RDS BATTERY "B"	NO CAUSE GIVEN FOR LOW WATER LEVEL
G	BP1	019472A	092977	BA	SA	A17	U	R	U	WATER ADDED TO CELL 12 OF RDS BATTERY "A"	NO CAUSE GIVEN FOR LOW WATER LEVEL
G	BP1	019472B	092977	BA	SA	A1432	C	R	D	SPECIFIC GRAVITY OF CELL 12 OF RDS BATTERY "A" LOW	WATER ADDED, CHARGE INSUFFICIENT TO MI
G	BP1	019542A	100877	BA	SA	A17	U	R	U	WATER ADDED TO 3 CELLS OF RDS BATTERY "D"	NO CAUSE GIVEN FOR LOW WATER LEVEL

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE MODE

PLANT	CONTROL NUMBER	EVENT DATE	CDMP	SYSTEM	FAULT CODE	PRIORITY	CLASS	FAILURE #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G BP1	019542B	102077	BA SA	A1432	C R D				SPECIFIC GRAVITY OF 3 CELLS OF RDS BATTERY "M" LOW WATER ADDED, MIXING WAS INADEQUATE	
G BP1	020176	122277	BA SA	A14	C R U				SPECIFIC GRAVITY ON RDS BATTERY "M", CELL 12 LOW	EQUALIZING CHARGE FOR 8 HOURS CORRECTED
G BP1	021307	050478	BA FP	A17	D U				FIRE PUMP DIESEL STARTG BTRY A CELLS 1,3,5 LO	ELECTROLYTE SOLN. EXACT CAUSE UNKNOWN
G BP1	021519	052578	BA FP	A1705	D D				FIRE PUMP DIESEL STARTG BTRY "M" CELLS 2,4,6 LO	ELECTROLYTE SOLN. INADQ MAINTENANCE PROC
G BP1	022664	083178	BA SA	A14	C R U				RDS BATTERY A, CELL 12 LO SPECIFIC GRAVITY READING	EXACT CAUSE UNKNOWN
G BP1	027985	110179	BA SA	A1420	C U				SPECIFIC GRAVITY OF CELL 48 OF RDS BATTERY C LOW	CELL REPLACED, WOULD NOT TAKE EQUAL CHARGE
G BP1	030237	012480	BA SA	A1420	C U				RDS C BTRY CELL 14 LOW SPECIFIC GRAVITY RDG	DEFECTIVE CELL REPLACED
G BP1	031176	050180	BA SA	A1420	C U				RDS BTRY "M" CELL 2 LOW SPECIFIC GRAVITY RDG	CELL DID NOT RESPOND ADQ TO EQUALIZG CHRGE
G BP1	031848	071080	BA SA	A1420	C U				RDS C BTRY CELLS 35,54 LOW SPECIFIC GRAVITY RDG	CELL DID NOT RESPOND ADQ TO EQUALIZG CHRGE
G BP1	032023	071880	BA SA	A20	D U				RDS C BTRY PILOT CELL UNIT-9 INTERNAL RESISTANCE-	INCRS. CAUSE UNKNOWN
G BP1	032297	080780	BA SA	A14	C U				RDS C BTRY CELLS 38,39,56 LOW SPECIFIC GRAVITY	VENDOR RECOM INCRS IN FLOAT VOLTAGE LEVEL
G BP1	032656	091180	BA SA	A1420	C U				RDS D BATTERY CELL 12 LOW SPECIFIC GRAVITY RDG	CELL DID NOT ADQ RESPOND TO EQUALIZG CHRGE
G BP1	033544	121180	BA SA	A1402	C D				21 CELLS OF RDS "M" BATTERY LOW SPECIFIC GRAVITY	CELL TERMINALS INADQ CLEANED BY MAINT PER
G BP1	037338	010281	BA SA	A1420	C R U				RDS CH D BATTERY CELL 56 HAD LOW SG, WOULD NOT RES-	POND TO EQUALIZING CHARGE.
G BP1	038112	081581	BA SA	A1602	A C D				FOUND PILOT CELL IN CH A RDS POWER SUPPLY WITH A -	HIGH ELEC LEVEL. POSSIBLY OVERFILLED
G BP1	038592	083181	BA ST	A2014	C C D				LOW SG IN CELL 43 OF ST BTRY, CELL FOUND CRACKED.-	THIS LEAD TO DILUTION, CRACKED WHEN MOVED
G BP1	038785	091581	BA SA	A1420	C U				"M" RDS BTRY CELL #5 LOW SPECIFIC GRAVITY	CELL DIDN'T RESPOND ADQ TO EQUALIZG CHRGE
G BP1	025637A	032579	BA NN	A3308	B R T				BATTERY 1B2 VOLTAGE FELL TO 102.5V THEN ROSE TO -	118V. CORRODED AND LOOSE BTRY CONNECT
G BP1	025637B	032779	BA NN	A3308	B R T				BTRY 1B1 VOLTAGE FELL TO 96.8V THEN ROSE TO 118V	CORRODED AND LOOSE BTRY CONNECTORS
G DR3	016265A	101876	BA NN	A34	A D				BATTERY IN A DEGRADED CONDITION	CHARGER SUBJECTED BTRY TO "DEEP CYCLING"
G DR3	020853	032878	BA NN	A10	F R T				24/48 V BTRY FAILED THE REFUELING OUTAGE DISCHRG-	TEST. 4 CELLS REPLCD NAT'L END OF LIFE
G EN2	030651*	032580	BC ST	A2122	G U	2			EMER STATION BATT CHRGR 2G, 2J FAILED TO HOLD LOAD	VOLTG CNTRL & CURR LMT MODULES TUNED
G EN2	030711A	032780	BC ST	A29	G U	2			STATION BATT CHRGR 2A, 2B FAILED TO MAINTAIN LOADS	SILICON CNTRL RECTIFIERS NEED LOAD BALANC
G EN2	030711B	032780	BC ST	A22	G U				STATION BATT CHRGR 2C FAILED TO MAINTAIN LOAD	CURRENT LIMIT MODULE NEEDED ADJUSTMENT
G EN2	036943A	040781	BA ST	A1602	N C D	2			ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF ST -	BTRY'S 2R42-S001A6B. PERSONNEL ERROR
G EN2	036943B	040781	BA ST	A1702	N C D	2			ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF ST B-	TTRY'S 2R42-S001A6B. PERSONNEL ERROR
G EN2	036943C	040781	BA DB	A1602	N C D				ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF DTE-	SEL GENERATOR BATTERY. PERSONNEL ERROR
G EN2	036943D	040781	BA DB	A1702	N C D				ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF DIES-	EL GENERATOR BATTERY. PERSONNEL ERROR
G FP1	019457	102077	BA ST	A20	U U				STATION BATTERY "B" FOUND TO HAVE CRACKED CELL	NO CAUSE KNOWN FOR CRACKED CELL #22B
G FP1	021433	053178	BA FP	A1420	A U				LU S.G. OF BTRY A2 CELL 1	BAD CELL IN BATTERY
G FP1	026922	090479	BA ST	A20	N U				LEAKING CELL NOTED IN BATTERY "B". BATTERY TEMPOR-	ARILY INOP WHILE CELL JUMPERED
G FP1	031743*	062880	BA FP	A14	A T	2			DIESEL FIRE PUMP 24V BATT CELLS A2-6, B2-1 LOW S.G.	CHARGER OOS DURING SURVEILLANCE

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE MODE

PLANT	CONTROL NUMBER	EVENT DATE	SYSTEM	STATUS	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G	FPI 033280	111780	BA ST A10	N T	STATION BTRY B MADE INOP TO JUMP A CELL	CELL #B POOR PERFORMANCE DUE TO AGE
G	M01 165730A	061591	BA NN A3401	A D	250 VDC BATTERY INADVERTENTLY DISCHARGED	PEPS DISCONNECTED TEMP BATTERY CHARGER
G	PH3 014211	012976	BA NN A14	B U	B BTRY CAPACITY BELOW DESIGN	CELL S-G. IN LD RING, PARTIAL ACID REPLCD
G	VY1 016217A	101376	BA UP A34	N R U	UPS-1B CNTRL PWR BTRY VOLTAGE WAS LOW	CNTRL BATT CHRGNG PWR SUPPLY FAILED
G	VY1 018407A	031877	BA UP A3413	N R D	UPS-1B ALARMED DUE TO LOW VOLTAGE-CAUSED SCRAM	CAPACITOR FAILED IN CHARGING PWR SUPPLY
B	CP3 038100	071481	PA ST B3002	N C D	STATION BATTERY SHORTED DURING MAINTENANCE	PERSONNEL ERROR. CAUSED REACTOR TRIP
B	DE3 022183	072778	BA NN B33	B U	SMOKE FROM 1 TERMINAL OF 16C BATTERY 3CB	TERMINAL DFCIV/CNNECTNS FOUND DEFECTIVE
B	T12 023084*	111278	BC NN B13	B U	2 CHRGPS 2-2A/B FUSE BLEW NO CHRGR FOR BANK 2-258	DEFECTIVE GATING FILTER MODULES
C	AP2 026904	080979	BC NN B1306	N C D	BATTERY CHARGER 2031 FAILED. DC OUTPUT LAMP SOCK--	--ET BURNED UP DUE TO HIGH HEAT, VOLT, DUST
C	AR2 027808	121179	BC NN B21	N S D	BATTERY CHARGER 2032 AC BREAKER TRIPPED	CURRENT SURGED WHEN SHIFTING TO FLOAT
C	AR2 030245*	110591	BC NN B00	N U	2 OUTPUT BREAKER OF BATTERY CHARGER 2034 TRIPPED OP--	--EN TWICE. NO CAUSE COULD BE FOUND
C	CC2 017344	021777	BA NN B01	N S D	#11 125 VDC BATTERY INADVERTENTLY TAKEN OUT OF SE--	--RVICE. SUPERVISOR GAVE PERMISSION
C	PA1 025917	040479	PA ST B2005	A C D	2 CELLS IN STATION BATTERY #2 BURST WHILE TAKING --	--VOLTAGE READINGS. FULL CAPACITY AVAL
C	PA1 036000*	010681	BA ST B02	U D	2 OUTPUT BREAKER FOR BOTH STATION BATTERIES WERE OP--	--ENED FOR 1 HOUR. PERSONNEL ERROR
C	SL1 020269	121677	BC NN B00	M D	OUTPUT LOST FROM "ARM" BATTERY CHARGER	POWER SUPPLY BKR TRIPPED FOR NO REASUN
C	SL1 039775	091281	BC NN B24	A R U	1A BATTERY CHARGER SHUTDOWN ON HIGH VOLTAGE	HIGH VOLTAGE DEVICE FOUND DEFECTIVE
M	BV1 022136	080478	BC ST B00	B U	#4 STATION BTRY CHGR OUTPUT BKR TRIPPED	IMPROPR OP OF CK-BRK. CAUSE OF TPP UNKNOWN
M	RV1 037757	061581	BC NN B2506	N R D	#2 BATTERY CHARGER OUTPUT BREAKER TRIPPED OPEN	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
M	BV1 039347	080581	BC NN B2506	N R D	#2 BATTERY CHARGER OUTPUT BREAKER TRIPPED OPEN	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
M	RV1 038825	091081	BC ST B33	N U	#4 STATION BATTERY CHARGER TAKEN OUT OF SERVICE	WAD ELECTRICAL CONNECTION IN OUTPUT
M	IP3 014709	051076	BC NN B2630	A U	BTRY CHGR TROUBLE ALARMED CHARGER FAN HAD TRPD	AC FAN MTR INOP EXPOSED WIRE BLEW A FUSE
M	IP3 015138	060876	BC NN B13	A S U	# 31 BTRY CHGR AC BKR TRIPD BATT CHGR INOP	PRESSURE SENSOR FAILED TRIPPING BREAKER
M	IP3 036207	012481	BC NN B2123	N U	OUTPUT FROM CHARGER #32 DISCOVERED DRIPPING	VOLTAGE AND CURRENT CONTROLLER REPLACED
M	IP3 039257	070681	BC NN B13	N S U	BATTERY CHARGER #32 DISCOVERED TRIPPED	FAILED OP AIR FLOW SENSOR SWITCH
M	JF1 021235A	041078	BA SW B00	E U	2 CELLS IN SW BLDG "A" BATT BANK 1 FAILED T.S. REO	CAUSE COULD NOT BE DETERMINED
M	JF1 021235B	041878	BA SW B00	E U	2 CELLS IN SW BLDG B BATT BANK 2 FAILED T.S. REO	CAUSE COULD NOT BE DETERMINED
M	JF1 032504	082580	BC SW B24	M S U	SW B DC DISTRIBUTION SYS INOP NO OUTPUT FROM BATT--	--CHGR 4. HW S/D RELAY ACTUATED
M	PP2 014599	041476	BC NN B2133	B U	#12 BATTERY CHARGER FAILED DISABLED "B" DC POWER	VOLTAGE CNTRL CRD LUDSE IN ITS SOCKET
M	R02 015515	071076	BA NN B02	M D	BATTERY B LEADS WERE REMOVED RENDERING BATT INOP	PEPS FAILED TO COMPLY W/ T.S. 3.7
M	P02 021076	071678	BA ST B3111	N D	PLASTIC TOP OF 2 STAIN "A" BATT CELLS ON FIRE	RESISTIC HEATG OF STRAP-CELL TERMINAL
M	S41 020738B	020178	BC NN B00	N U	2 1C1-1C2 BATT CHARGER D.C. BKRS TRIPPED	UNKNOWN CAUSE
M	S41 038836	091881	BA FP B33	N U	BATTERY CABLE CLAMP FOUND ARCING AND CRACKED	CLAMP WAS REPLACED ON #2 FIRE PUMP BTRY

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE MODE

P N S T	C A M N O R E	C O N T R O L N U M B E R	E V E N T D A T E	C O D E	S Y S T E M	F A C T O R Y C A U S E	F A I L U R E M O D E D E S C R I P T I O N	F A I L U R E C A U S E D E S C R I P T I O N			
W	S42	039319	072481	BC	NN	R2101	N	U	D	2C1 BATTERY CHARGER DISCOVERED TRIPPED. VOLTAGE --SETTING WAS INCORRECTLY SET	
W	S42	038327	081281	BC	NN	B24	N	U	U	2B1 BATTERY CHARGER WOULD NOT PICK UP 28 VDC LOAD HIGH VOLTAGE CUT-OUT ACTUATED	
W	S42	039683	090681	BA	AM	B00	N	U	U	RAD MONITOR 2R12A BATTERY PACK FAILED	NO CAUSE GIVEN
W	S41	032338	080780	BA	OB	B30	N	U	U	D/G BTRY 18-B CELL 51 SHORTED AND FAILED	NO CAUSE GIVEN
W	S11	032342A	081280	RA	OB	B05	U	D	D	D/G BTRY 18-B CELLS 49,50,51 DISCHARGED	INADEQUATE PROCEDURE
W	S11	032342B	081380	RA	OB	B05	U	D	D	D/G BTRY 18-B CELLS 49,50,51 DISCHARGED	INADEQUATE PROCEDURE
W	S02	169141	081981	9C	FP	B13	N	U	U	SMOKE DET SYS INOP BTRY CHGRG LOST POWER	FAULTY POWER SUPPLY CARD IN CHARGER
W	S02	038470	090681	BA	FP	B00	U	U	U	SMOKE DETECTOR BATTERY FOUND NOT TO TAKE A CHARGE	NO CAUSE GIVEN
W	S02	039936A	100181	BA	FP	B34	A	D	D	SMOKE DETECTOR BATTERY FAILED	CHARGER NOT CHARGING BATTERY
W	S02	039936B	100181	BC	FP	B00	A	U	U	BATTERY CHARGER FOR SMOKE DETECTOR BATTERY FAILED	NO CAUSE GIVEN
W	T01	032622	090380	BA	FW	B20	N	U	U	DIESEL-DRIVEN AFMP FAIL TO START FROM MANUAL SIG	FAILED STARTING BATTERY
W	T03	039363	111281	BA	NN	B20	A	R	U	"2A" 125 VDC FAILED TO HOLD A CHARGE	BEING EVALUATED W/ MANUFACTURER
W	T01	019476A	101477	BC	NN	B1210	N	R	T	NO. 2 BATTERY CHARGER TAKEN OUT OF SERVICE	FAILED BEARING
W	T01	019640	110577	PC	NN	B1210	N	R	T	NO. 1 BATTERY CHARGER TAKEN OUT OF SERVICE	FAILED BEARING DUE TO NORMAL WEAR
W	T11	171128A	121281	BA	NN	B01	M	U	D	UNIT 2 212 BATTERY TAKEN 005 ERRONEOUSLY	LICENSED OPERATOR ERROR
W	T11	171128B	121281	BC	NN	B01	M	U	D	UNIT 2 212 CHARGER TAKEN 005 ERRONEOUSLY	LICENSED OPERATOR ERROR
G	R02	015394	070976	BA	NN	B302	M	U	D	NEUTRON MONITORING BATTERY 2A MADE INOPERABLE	CNCR BKRN OFF A CELL POST PERS ERROR
G	R02	025671	041979	BA	SP	B302	N	C	D	BROKEN TERMINAL DISCOVERED ON 57D BOARD "D" BTRY	PERSONNEL ERROR. ALSO AFFECTED UNIT 1
G	R01	015241	063076	BC	ST	B29	N	U	U	STATION BATTERY CHARGER FAILED	DEFECTIVE SILICON RECTIFIERS
G	R01	015444	081276	BA	OB	B33	N	T	T	EMERGENCY DIESEL GENERATOR DID NOT START DUE TO L-	--NOSE BATTERY CONNECTION.
G	R01	017704*	033077	BA	UP	B304	N	C	D	NO OUTPUT FROM ALL UPS BATTERY BANKS	CONNECTORS NOT TIGHTENED DURING INSTAL
G	R01	019025A	082977	BA	FP	B302	N	D	D	DIESEL FIRE PUMP "A" BATTERY FOUND WITH NO OUTPUT	CONNECTORS NOT TIGHTENED
G	R01	019025B	082977	BA	FP	B00	N	U	U	DIESEL FIRE PUMP "B" BATTERY FOUND WITH NO OUTPUT	CONNECTORS NOT TIGHTENED
G	R01	019389	102177	PC	NN	B2206	B	U	U	RAT CHGR DC OUTPT FUSE FAIL WHEN CHRG BATT 2A-2	--OUTPUT. DISCHR WITH NO APPARENT CAUSE
G	C01	022101A	062778	BC	NN	B233	N	T	T	1A 250V BTRY CHGR 1E BREAKER TRIPPED	HI CURR/TEMP CAUSD SOLDERD LINKG SEPARATE
G	C01	022101B	062778	PC	NN	B304	N	U	D	1A 250V BTRY CHGR INPUT BREAKER TRIPPED	POOR CNCR CNCTIS IN CURRENT MODULE
G	R01	018553A	072977	BA	FP	B3413	N	C	D	DIESEL FIRE PUMP BATTERIES FAILED TO START DIESEL	LOOSE CNCR CNCT AT CHGR INPUT BKR PHASE A
G	R01	018553B	072977	BC	FP	B22	N	U	U	FUSE FOUND BLOWN IN DIESEL FIRE PUMP BATTERY CHAR-	FAILED FUSE FROM BATTERY CHARGER CIRCUIT
G	R03	025951	042479	BA	NN	B01	N	U	D	UNIT 2'S BATTERY NOT RETURNED TO NORMAL LINEUP	BREAKER COULD HAVE BEEN SHUT AT ANY TIME
G	R02	033891	081180	RA	ST	B30	M	U	U	DC BATT GROUND ON 2B STATION SERVICE BATTERY	NO CAUSE GIVEN
G	R02	032981A	032381	RA	AM	B1834	N	D	D	POST TREATMENT MON 2011-KA15A BATTERY DRAINED	BATTERY CHARGER 2AB 24/48 VDC FAILED
G	R02	032481B	032381	BC	NN	P00	N	U	U	24/48 VDC BATTERY CHARGER FOUND NOT CHARGING	NO CAUSE GIVEN

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE MODE

PLANT	CONTROL NUMBER	EVENT DATE	COMP	SYSTEM	FAILURE MODE	ACTIVITY	TYPE	CLASS	FAIL #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G FPI	171811	123081	BA	NM	B18	N	D	2		LOW VOLTAGE FROM DIVISION I 24 VDC BATTERIES, CAUS	-ED ERRATIC READINGS ON LRM & SRM INS!
G MD1	1667308	061581	BC	NN	B01	A	U	D		TEMPORARY BATTERY CHARGER TAKEN OUT OF SERVICE	PERSONNEL ERROR, CAUSED BTRY TO DISCHARGE
G DC1	018293A	062877	BA	SY	B34	U	C	D		ONE OF TWO SWITCHING STATION BATTERIES FOUND OOS -	-FOR 11 DAYS. BATTERY CHARGER FAILED
G DC1	018293B	062877	BC	SY	B2713	U	U			BATTERY CHARGER FOR SWITCHING STATION BATTERY FOU-	-ND OOS AFTER 11 DAYS
G P11	027950A	122379	BC	SY	B00	U	R	U		SWITCHYARD 125 VDC BATTERY CHARGER FAILED	NO CAUSE GIVEN
G P11	027950B	122479	BC	SY	B00	N	R	U		SWITCHYARD 125 VDC BACKUP BATTERY CHARGER FAILED	NO CAUSE GIVEN
G P11	033899	082180	BC	NN	B2113	N	U			"A" 125 VDC CONTROL BATT CHARGER INOPERABLE	VOLTAGE REGULATOR ELECTRONIC MODULES #PLC
G VY1	0162178	101376	BC	UP	B21	N	R	U		CTRL BTRY CHARGING POWER SUPPLY FAILED	INOPERATIVE VOLTAGE REGULATOR CIRCUIT
G VY1	0184078	031877	BC	UP	B13	N	T			UPS-1B CONTROL CHARGING POWER SUPPLY FAILED	FAILED CAPACITOR IN ON/OFF CIRCUITRY
G VY1	021749	061978	BC	NN	B06	N	S	D		AC INPUT BRKR TO CA1 BATT CHRGR TRPD OPEN	SPURIOUS TRP OF AC BRKR IN AN ELEC STERN
G VY1	025519	031779	BC	UP	B00	N	U			CONTROL CHARGING POWER SUPPLY FAILED	NO CAUSE GIVEN. CAUSED BATTERIES DISCHR
M TU3	033530A	121180	BC	NN	C00	N	U			PROBLEMS WITH 48 125 VDC BATTERY CHARGER	NO CAUSE GIVEN
M Z11	172130	121581	BA	NN	C05	U	U	D		EQUALIZING CHARGE NOT PLACED ON BATTERY 112	PROCEDURE NOT CLEAR ON COMMUNICATIONS
G DP3	0162658	101876	BC	NN	C00	A	U			CHARGER SUBJECTED BTRY TO "DEEP CYCLING"	UNKNOWN CAUSE
G QC2	018164	031777	BC	NN	C23	U	U			UNITS BATTERY CHARGER APPARENTLY INOPERABLE	FAULTY INDUCTIVE CURRENT CONTROL CIRCUIT
M DC1	025643	032379	BC	NN	D01	N	U	D		125 VDC EQUALIZING CHARGE TOO HIGH, FAILED INVERT-	-ER, CAUSED SCRAM AND SE. NO CAUSE
M HN1	014608A	042576	BC	NN	D2833	N	U			BTRY CHARGER A WENT INTO OVERCHARGE	FAULTY CNTCT ON CHARGER CONTROL TIMER
M HN1	014608B	042576	BC	NN	D2122	N	U			VOLTG REG SPIKING TO 200 AMPS THEN SHUTTING OFF	FAULTY PHASING CRD IN CURRENT LIMITER CKT
C PA1	016178	102076	BC	NN	E2201	N	D			DC BUS-2 VOLTG FELL VOLTG ON ASSOC AC BUSES FELL	CHRR LMTR & OUTPUT BRKR SETTING ERRONEOUS
M BV1	021043	032078	BC	NN	E2713	N	U			DECR #4 DC BUS VOLTAGE DUE TO A FAULTY BTRY CHRGR	FAILD COLLECTR RESISTR IN CHRGR CNTRL CKT
G DA1	171665	120881	BC	NN	F00	N	U			BATTERY CHARGER OUTPUT INCORRECT	UNKNOWN
G QC2	018460	060977	BC	NN	E2101	N	U	D		BATTERY CHARGER SUPPLYING CURRENT TO BATTERY FOUN-	-D LOW. FLOATING POTENTIOMETER SET LOW
G CD1	037646	050581	BC	ST	G29	B	U			HIGH RIPPLE FROM BATTERY CHARGER WHICH FAILED INV-	-FRER 1A. FAILED SCR
C CC1	037262	050681	BA	NN	M20	A	U			VOLT OF CELL 18 OF 125 VDC BATTERY 12 FOUND LOW -	-BELOW MINIMUM. FULL CAPACITY AVAILAEE
C MI2	026979	080379	BA	NN	M20	A	U			VARIOUS CELLS REPLACED IN 2018 BTRY (4 CELLS)	REDUCTION IN CELL VOLT. FULL CAPACITY
M BV1	016357	102476	BA	NN	M00	A	U			VOLTAGE DECREASED IN CELL 48 BY MORE THAN 0.05V	UNKNOWN. CELL 48 FROM BTRY 3, 1650 Z.H.
M BV1	028147	092179	BA	NN	M2010	A	T			CELL #6 OF BATTERY NO. 1 COULD NOT HOLD ORIGINAL -	-VOLTAGE. FULL BATTERY CAPACITY AVAIL.
M BV1	039154	101781	BA	NN	M20	E	R	U		2 OF 60 CELLS VOLTAGE FOUND DROPPED BY .05 VDC	NO CAUSE GIVEN, BATTERY HAD FULL CAPACITY
M NA2	036466*	021881	BA	DB	M14	E	U	2		BATTERIES FOR 2J & 2H DIESFL GENERATORS FAILED SU-	-PVEILLANCE TEST. 4 CELLS REPLACED
G BP1	017024*	010477	BA	SA	M14	A	R	U	2	B CELLS SPECIFIC GRAVITY FOUND BELOW 1.2. EVALUA-	-TION REVEALED ADEQUATE CAPACITY
G BP1	017464	022477	BA	SA	M14	C	R	U		RDS BATTERY B HAD ONE CELL BELOW MINIMUM SPECIFIC-	-GRAVITY. ADEQUATE CAPACITY AVAILABLE
G BP1	017463	031777	BA	SA	M14	C	R	U		SPECIFIC GRAVITY FOUND LOW IN 5 CELLS OF PDS BTRY-	-"A". ADEQUATE CAPACITY AVAILABLE

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE MODE

CONTROL NUMBER	EVENT DATE	CONTROL	SYSTEM	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G RP1 018096A	042177	BA SA M14	C R U	RDS BATTERY B-CELL 27 FOUND TO HAVE LOW SPECIFIC --	--GRAVITY OF 1.191. FULL CAPACITY AVAIL
G RP1 018096B	042777	BA SA M14	C U	SPECIFIC GRAVITY OF 10 MARGINAL CELLS ADJUSTED OF--	--RDS BATTERY B. FULL CAPACITY AVAILABLE
G EN1 021475*	060478	BC ST M1304	M D	2 HEAT-SENSITIVE XSTR ON BATT CHRG FIRMING MODUL CPD	SHOULD BE A NON-HEAT-SENSITIVE TRANSISTOR
G OC1 019222	092477	BA NN M2010	U T	BATTERY SYSTEM TAKEN OUT OF SERVICE	REPLACED 12 WEAR CELLS,NORMAL END OF LIFE
B CP3 017166A	011277	BA NN T03	R U D	INCORRECT PILOT CELLS TESTED FOR 3A7B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B CP3 017166B	020277	BA NN T03	R U D	INCORRECT PILOT CELLS TESTED FOR 3A7B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B CH3 017166C	020977	BA NN T03	R U D	INCORRECT PILOT CELLS TESTED FOR 3A7B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B CP3 021165	040578	BA NN T02	R V D	WPONG BTRY CELLS MONITORED FOR WEEKLY BATT SURV	PERSONNEL NOT FOLLOWING PROCEDOUES
B DB1 022362	090578	BA ST T02	R U D	STATION BATTERIES WKLY SURV TEST NOT DONE ON TIME	MISUNDERSTANDING BTWN PERSONNEL
B DE3 015532	081876	BA NN T05	R U D	125-VDC INSTR & CTRL BATTERIES NOT LOAD TESTED	DECTV PROC WRONG DATA IN SURV PRINTOUT
C AR2 026489	052279	BA ST T03	R U D	SURVEILLANCE NOT PERFORMED ON STATION BATTERIES	PERSONNEL OVERSIGHT
C SL1 037962	062481	BC NN T02	R U D	SURVEILLANCE REQUIREMENTS NOT MET ON "AB" BATTERY--	--CHARGER. MISINTERPRETATION OF TECH SPEC
M BV1 017119A	020477	BA ST T03	R U D	SURVEILLANCE TEST NOT PERFORMED ON #3 & #4 STATION--	--N BATTERIES. PERSONNEL ERROR
M BV1 017119B	020477	BC ST T03	R U D	SURVEILLANCE TEST NOT PERFORMED ON CHARGERS ASSOC--	--TATED WITH #3 & #4 STATION BTRY. PERSON
M DC2 039127	101981	BA NN T05	R U D	SURVEILLANCE NOT PERFORMED ON "M" TRAIN BATTERY	PROCEDURE LACKED SIGMOFF
M JF1 027181	090679	BA NN T03	R U D	QUARTERLY AUXILIARY BUILDING BATTERY VERIFICATION--	--NOT PERFORMED ON TIME. PERSONNEL
M HA1 026565	062879	BA DB T05	R U D	7 DAY SURVEILLANCE OF EMERGENCY DIESEL GENERATOR --	--BATTERIES EXCEEDED INTERVAL. PROCEDURAL
M HA1 026656	073179	BA DB T05	R U D	DIESEL GENERATOR BATTERIES SURVEILLANCE NOT DONE	TIME LAG IN IMPLEMENTING NEW PROCEDURES
M HA1 036491A	022891	BA ST T02	R U D	18 MONTH SURVEILLANCE ON D.C. DISTRIBUTION SERVIC--	--E SYSTEM NOT DONE. PERSONNEL OVERSIGHT
M HA1 036491B	022891	BC ST T02	R U D	18 MONTH SURVEILLANCE ON D.C. DISTRIBUTION SERVIC--	--B SYSTEM NOT DONE. PERSONNEL OVERSIGHT
M HA2 036417	022081	BA DB T05	R U D	DATA FROM TWO TESTS ON 24 DIESEL BATTERY FOUND NO--	--T USABLE. NOT COMPARED WITH INITIAL CON
M PP1 026268	053179	BA FP T05	R U D	DIESEL DRIVEN WEEKLY BATTERY INSPECTION NOT DONE	PROCEDURES WERE DEFECTIVE
M PP1 030917	033180	BA ST T02	R U D	INDIVIDUAL FLOAT CELL VOLT MEAS NOT DONE IN STATI--	--DN BATTERY TEST. PERSONNEL OVERSIGHT
M SA1 032162	072180	BA FP T02	R U D	92 DAY & 18 MON SURV NOT DONE ON 24 V STARTG BATT	ELECTRICIAN NOT COMPLETING JOB
M TP1 0184563	032476	BA ES T05	R U D	ESF DC PWR SUPPLIES SURV REQ PERFORMED AT WONG FREQ	PROCEDURE DID NOT USE FREQ REQ BY T.S.
M TP1 020885	031778	BA NN T02	R U D	125 VDC ELECTRICAL SYS OP NOT VERIFIED WK OF 2-26	MAINT PERS FAILED TO INSURE SURV COMPLETED
M TP1 025211A	011979	BA NN T03	R U D	125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL
M TP1 025211B	011979	BC NN T03	R U D	125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL
M T03 022061A	122277	BA ST T01	U U D	EQUALIZING CHARGES ON STATION BATTERIES NOT PERFO--	--MED. PERSONNEL ERROR,FULL CAPACITY AVL
M T03 022061B	122977	BA ST T01	U U D	EQUALIZING CHARGES ON STATION BATTERIES NOT PERFO--	--MED. PERSONNEL ERROR,FULL CAPACITY AVL
M T03 033510B	121180	BA NN T34	N U T	48 125 VDC BATT 005,TECH SPEC EXCEEDED	PROBLEM W/ ASSOCIATED BTRY CHARGER
M YP1 019476B	101477	BC NN T01	N U D	NO. 1 BATTERY CHARGER CROSS TIED TO NO. 2 BATTERY	OVERSIGHT CAUSE LCO STATED IN TECH SPEC

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE MODE

PLANT NUMBER	CONTROL NUMBER	EVENT DATE	SYSTEM	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G BPI	0153278	072976	BA SA T14	ROS BTRY C PILOT CELL ROG LO SPECIFIC GRAVITY	DECTV PROC SPECIFIC GRAVITY READ TOO SOON
G BPI	0184628	061677	BA SA T1432	SPECIFIC GRAVITY OF CELL 27 OF ROS BATTERY B LOW	WATER ADDED THEM TESTED TOO SOON
G BPI	033637	122380	BA NN T02	DC BATTERY MONTHLY TESTS OVERDUE	INADU ADMIN CONTROLS & PERSONNEL ERROR
G BPI	014651	021276	BA NN T05	MONTHLY INSTEAD OF QUARTERLY BATTERY P.T. PERFORMED	WRONG P.T. SCHEDULED BY MISTAKE
G C01	037938	052891	BA ST T03	SG TESTS FOR 125V 1A68 AND 250V 1B NOT PERFORMED	--PROPERLY. PERSONNEL USED WRONG HYDROM
G DA1	030982	041780	BA NN T02	WKLV BATT SURV DOCUMENTATION NOT COMPLETED	PERSONNEL ERROR-NONLIC. OPERATIONS PEFS
G DR2	032116	102181	BA NN T01	QUARTERLY STORAGE BATTERY SURVEILLANCE DONE 3 DAY--	--S LATE. OVERSIGHT BY OPERATING SHIFT
G DP3	036569	030391	BA NN T01	WEEKLY STORAGE BATTERY SURVEILLANCE DONE 4 DAYS L--	--ATE. OVERSIGHT BY OPERATING SHIFT
G EN1	021719	062778	BA DB T02	WKLV PILOT CELL SURV OF IC D/G BTRY NOT COMPLET--	ED ON TIME. PERSONNEL OVERSIGHT
G EN1	027762	112679	PA NN T03	CELL SURVEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT
G EN2	022208	081678	BA NN T02	WKLV PILOT CELL SURV OF PLANT BATT NOT COMPLETED--	ON TIME. NOTICES ROUTED TO ABSENT PEFS
G EN2	026657	071879	BA NN T03	CELL SURVEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT
G M11	014478	040776	BA SY T01	SWITCHYARD BTRY SURVEILLANCE NOT PERFORMED W/IN--	REQ TIME PERIOD. PERSONNEL ERROR
G DC1	021497A	052478	BA DB T01	D/G BTRY LOAD TESTING NOT PERFORMED IN TIME	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	021497B	052478	BA ST T01	STATION BTRY LOAD TESTING NOT PERFORMED IN TIME	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	023298A	121378	BA DB T01	D/G BTRY NOT TESTED/MONITORED W/IN TIME INTERVAL	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	023298B	121378	BA ST T01	STATION BTRY NOT TEST/MONITOR W/IN TIME INTERVAL	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	030599A	022880	BA ST T02	MAIN STATION BTRY SURV TEST NOT PERFORMED	PLANT PEFS FAILED TO ADHERE TO SURV SCHEDULE
G DC1	030599B	022880	BA DB T02	DIESEL GENERATOR BTRY SURV TEST NOT PERFORMED	PLANT PEFS FAILED TO ADHERE TO SURV SCHEDULE
G DC1	038737	091181	BA NN T02	BATTERY SURVEILLANCE PROCEDURES FOUND NOT TO FULL--	--Y COMPLY WITH NEW REQUIREMENTS.

APPENDIX G
ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS
SORTED BY FAILURE CAUSE

CODES USED IN LER ONE-LINE DESCRIPTIONS

MSSS VENDOR

CODE	DESCRIPTION
B	BABCOCK & WILCOX
C	COMBUSTION ENGINEERING
M	WESTINGHOUSE
G	GENERAL ELECTRIC

EVENT CLASSIFICATION

CODE	DESCRIPTION
------	-------------

D - FREQUENCY
T - AGE
U - UNKNOWN

COMPONENT

CODE	DESCRIPTION
------	-------------

BA - BATTERY
BC - BATTERY CHARGER

CODE	DESCRIPTION
00	UNKNOWN
01	PERSONNEL OPERATION
02	PERSONNEL MAINTENANCE
03	PERSONNEL TESTING
04	DESIGN/FABRICATION/CONSTRUCTION/QUALITY CONTROL
05	DEFECTIVE PROCEDURES
06	EXTREME ENVIRONMENT
08	CORROSION
10	NORMAL WEAR/NATURAL END OF LIFE
11	ELECTRICAL MALFUNCTION
12	MECHANICAL MALFUNCTION
13	PIECE PART FAILURE
14	LOW SPECIFIC GRAVITY
15	STRATIFICATION
16	HIGH ELECTROLYTE SOLUTION LEVEL
17	LOW ELECTROLYTE SOLUTION LEVEL
18	INSUFFICIENT CHARGE
20	DEFECTIVE/WEAK CELLS
21	VOLTAGE REGULATOR MALFUNCTION
22	CURRENT LIMITER MALFUNCTION
23	CURRENT CONTROLLER MALFUNCTION
24	VOLTAGE LIMITER MALFUNCTION
25	THERMAL OVERLOAD PROTECTION
26	COOLING FAN/VENTILATION MALFUNCTION
27	CHARGE CONTROL MALFUNCTION
28	CHARGE CONTROL TIMER MALFUNCTION
29	RECTIFIER PROBLEM
30	SHORT CIRCUIT
32	ELECTROLYTE DILUTION
33	FAULTY CABLE/CONNECTORS
34	CHARGER MALFUNCTION

FAILURE MODE

CODE	DESCRIPTION
A	REDUCED CAPABILITY
B	NO OUTPUT
C	UNKNOWN/UNSPECIFIED/OTHER
D	HIGH CURRENT/VOLTAGE OUTPUT
E	LOW OUTPUT VOLTAGE
G	HIGH AC RIPPLE ON DC OUTPUT
M	MAINTENANCE REPLACEMENT
T	TEST NOT PERFORMED

TYPE EVENT

CODE	DESCRIPTION
------	-------------

B - RECURRING COMMON CAUSE
C - COMMON CAUSE
R - RECURRING
S - COMMAND FAULT
T - RECURRING COMMAND FAULT
J - COMMON CAUSE COMMAND FAULT
V - RECURRING COMMON CAUSE COMMAND FAULT
BLANK - RANDOM

ACTIVITY RESULTING IN DISCOVERY

CODE	DESCRIPTION
------	-------------

A - TESTING(UNSPECIFIED)
B - NORMAL LOAD TESTING
C - MONTHLY TESTING
D - WEEKLY TESTING
E - QUARTERLY TESTING
F - REFUELING TESTING
G - 18 MONTH TESTING
H - 3 YEAR TESTING
M - MAINTENANCE
N - NORMAL PLANT OPERATION
R - RECORDS REVIEW
U - UNKNOWN

FLAGGING FIELD

CODE	DESCRIPTION
------	-------------

A - FAILED COMPONENT CAUSED AN ACCIDENT
B - COMPONENT FAILED TO MITIGATE AN ACCIDENT
C - SAFETY SIGNIFICANT
CO - CELL # NOT KNOWN
CP - CELL # NOT KNOWN
CP - FAIL # AND CELL # NOT KNOWN
N - FROM NSIC DATA BASE

SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
AM	- AREA MONITOR SYSTEM
DB	- EMERGENCY DIESEL GENERATOR
ES	- ENGINEERED SAFETY FEATURE
FP	- FIRE PROTECTION SYSTEM
FW	- FEEDWATER SYSTEM
NM	- NEUTRON MONITORING BATTERY
NN	- UNKNOWN/UNSPECIFIED/OTHER
SA	- AUTOMATIC (REACTOR) DEPRESSURIZATION (ADS)
SP	- SPECIAL USE BATTERIES
ST	- STATION BATTERIES/CHARGERS
SW	- SERVICE WATER BUILDING BATTERIES/CHARGERS
SY	- SWITCHYARD BATTERIES/CHARGERS
UP	- UNINTERRUPTIBLE POWER SYSTEM (UPS)

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE CAUSE

UNION	PLANT	CONTROL NUMBER	EVENT DATE	COMP	STATION	FAILURE CODE	ACTIVITY	CLASS	FAILURE #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
C	AR2	039245*	110581	BC	NN	800	N	U	2	OUTPUT BREAKER OF BATTERY CHARGER 2034 TRIPPED OP-	-FN TWICE. NO CAUSE COULD BE FOUND
C	CC1	021533	050378	BA	NN	400	A	U		125 VDC BTRY 22 CELL 54 ICV BELOW MIN VOLTAGE	CAUSE UNKNOWN
C	SL1	020069	121677	BC	NN	800	N	D		OUTPUT LOST FROM "AB" BATTERY CHARGER	POWER SUPPLY BRK TRIPPED FOR NO REASON
W	BV1	016357	102476	BA	NN	800	A	U		VOLTAGE DECREASED IN CELL 48 BY MORE THAN 0.05V	UNKNOWN. CELL 48 FROM BTRY 3, 1650 A.H.
W	RV1	022136	080478	BC	ST	800	B	U		#4 STATION BTRY CHRGR OUTPUT BRKR TRIPPED	IMPROPR OP OF CKTWRK. CAUSE OF TRP UNKNOWN
W	JF1	021235A	041878	BA	SW	800	E	U		2 CELLS IN SW BLDG "A" BATT BANK 1 FAILED T.S. REQ	CAUSE COULD NOT BE DETERMINED
W	JF1	021235B	041878	BA	SW	800	E	U		2 CELLS IN SW BLDG B BATT BANK 2 FAILED T.S. REQ	CAUSE COULD NOT BE DETERMINED
W	SA1	0207388	020178	BC	NN	800	N	U	2	IC1, IC2 BATT CHARGER D.C. BRKRS TRIPPED	UNKNOWN CAUSE
W	SA2	038483	090681	BA	AM	800	N	U		RAD MONITOR 2R12A BATTERY PACK FAILED	NO CAUSE GIVEN
W	SU2	038470	090451	BA	FP	800	U	U		SMOKE DETECTOR BATTERY FOUND NOT TO TAKE A CHARGE	NO CAUSE GIVEN
W	SU2	0389368	100181	BC	FP	800	A	U		BATTERY CHARGER FOR SMOKE DETECTOR BATTERY FAILED	NO CAUSE GIVEN
W	TU3	033530A	121180	BC	NN	800	N	U		PROBLEMS WITH 48 125 VDC BATTERY CHARGER	NO CAUSE GIVEN
G	BP1	0190258	082977	BA	FP	800	N	U		DIESEL FIRE PUMP "B" BATTERY FOUND FAILED WITH NO-	-OUTPUT. DISCHR WITH NO APPARENT CAUSE
G	DA1	171665	120881	BC	NN	800	N	U		BATTERY CHARGER OUTPUT INCORRECT	UNKNOWN
G	DR3	0162658	101876	BC	NN	800	A	U		CHARGER SUBJECTED BTRY TO "DEEP CYCLING"	UNKNOWN CAUSE
G	EN2	0329818	032381	BC	NN	800	N	U		24748 VDC BATTERY CHARGER FOUND NOT CHARGING	NO CAUSE GIVEN
G	PI1	0279504	122379	BC	SY	800	U	R	U	SWITCHYARD 125 VDC BATTERY CHARGER FAILED	NO CAUSE GIVEN
G	PI1	0279508	122479	BC	SY	800	N	R	U	SWITCHYARD 125 VDC BACKUP BATTERY CHARGER FAILED	NO CAUSE GIVEN
G	YY1	025519	031779	BC	UP	800	N	U		CONTROL CHARGING POWER SUPPLY FAILED	NO CAUSE GIVEN. CAUSED BATTERIES DISCHR
C	CC2	017344	021777	BA	NN	801	N	S	D	#11 125 VDC BATTERY INADVERTENTLY TAKEN OUT OF SE-	-VICE. SUPERVISOR GAVE PERMISSION
W	DC1	025643	032379	BC	NN	801	N	U	D	125 VDC EQUALIZING CHARGE TOO HIGH, FAILED INVERT-	-ER, CAUSED SCRAM AND ST. NO CAUSE
W	TU3	022061A	122277	BA	ST	801	U	U	D	EQUALIZING CHARGES ON STATION BATTERIES NOT PERFO-	-RMD. PERSONNEL ERROR, FULL CAPACITY AVE
W	TU3	022061B	122977	BA	ST	801	U	U	D	EQUALIZING CHARGES ON STATION BATTERIES NOT PERFO-	-RMD. PERSONNEL ERROR, FULL CAPACITY AVE
W	YP1	019476B	101477	BC	NN	801	N	U	D	NO. 1 BATTERY CHARGER CROSS TIED TO NO. 2 BATTERY	OVERSIGHT CAUSE LCD STATED IN TECH SPEC
W	Z11	171128A	121281	BA	NN	801	M	U	D	UNIT 2 212 BATTERY TAKEN OOS ERRONEOUSLY	LICENSED OPERATOR ERROR
W	Z11	171128B	121281	BC	NN	801	M	U	D	UNIT 2 212 CHARGER TAKEN OOS ERRONEOUSLY	LICENSED OPERATOR ERROR
G	DR2	039116	102181	BA	NN	801	R	U	D	QUARTERLY STORAGE BATTERY SURVEILLANCE DONE 3 DAY-	-S LATE. OVERSIGHT BY OPERATING SHIFT
G	DR3	025951	042479	BA	NN	801	N	U	D	UNIT 2'S BATTERY NOT RETURNED TO NORMAL LINEUP	BRKAKER COULD HAVE BEEN SHUT AT ANY TIME
G	DR3	036569	030381	BA	NN	801	R	U	D	WEEKLY STORAGE BATTERY SURVEILLANCE DONE 4 DAYS L-	-ATE. OVERSIGHT BY OPERATING SHIFT
G	HT1	014478	040776	BA	SY	801	R	U	D	SWITCHYARD BTRY SURVEILLANCE NOT PERFORMED W/IN--	REQ TIME PERIOD. PERSONNEL ERROR
G	MO1	166730B	061581	BC	NN	801	A	U	D	TEMPORARY BATTERY CHARGER TAKEN OUT OF SERVICE	PERSONNEL ERROR, CAUSED BTRY TO DISCHARGE
G	DC1	021497A	052478	BA	DR	801	N	U	D	D/G BTRY LOAD TESTING NOT PERFORMED IN TIME	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE CAUSE

PLANT	CONTROL NUMBER	EVENT DATE	LOCATION	STATUS	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G DC1	0214978	052478	BA ST 101	N U D	STATION BTRY LOAD TESTING NOT PERFORMED IN TIME	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	023298A	121378	RA DB 101	R U D	D/G BTRY NOT TESTED/MONITORED W/IN TIME INTERVAL	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	023298B	121378	BA ST 101	R U D	STATION BTRY NOT TEST/MONITOR W/IN TIME INTERVAL	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
B CR3	021165	040578	BA NN 102	R V D	WRONG BTRY CELLS MONITORED FOR WEEKLY BATT SURV	PERSONNEL NOT FOLLOWING PROCEDURES
B BH1	022362	090578	BA ST 102	R U D	STATION BATTERIES WKLY SURV TEST NOT DONE ON TIME	MISUNDERSTANDING BTWN PERSONNEL
C PA1	036000*	010681	RA ST 802	U U D	2 OUTPUT BREAKER FOR BOTH STATION BATTERIES WERE OPENED FOR 1 HOUR.	PERSONNEL ERROR
C SL1	037962	062481	BC NN 102	R U D	SURVEILLANCE REQUIREMENTS NOT MET ON "AB" BATTERY	-CHARGER. MISINTERPRETATION OF TECH SPEC
M NA1	036491A	022481	BA ST 102	R U D	18 MONTH SURVEILLANCE ON D.C. DISTRIBUTION SERVIC-	-E SYSTEM NOT DONE. PERSONNEL OVERSIGHT
M NA1	036491B	022481	BC ST 102	R U D	18 MONTH SURVEILLANCE ON D.C. DISTRIBUTION SERVIC-	-B SYSTEM NOT DONE. PERSONNEL OVERSIGHT
M PF1	030917	033180	BA ST 102	R U D	INDIVIDUAL FLOAT CELL VOLT MEAS NOT DONE IN STATION	-ON BATTERY TEST. PERSONNEL OVERSIGHT
M R02	015515	071076	BA NN 802	M D	BATTERY B LEADS WERE REMOVED RENDERING BATT INOP	PERFS FAILED TO COMPLY W/ T.S. 3.7
M SA1	032162	072180	BA FP 102	R U D	92 DAY 6 18 MON SURV NOT DONE ON 24 V STARTG BATT	ELECTRICIAN NOT COMPLETING JOB
H TP1	020895	031778	BA NN 102	R U D	125 VDC ELECTRICAL SYS OP NOT VERIFIED MK OF 2-26	MAINT PERFS FAILED TO INSURE SURV COMPLETED
G PP1	033637	122380	BA NN 102	M U D	DC BATTERY MONTHLY TESTS OVERDUE	INADQ ADMIN CONTROLS & PERSONNEL ERROR
G DA1	030882	041780	BA NN 102	R U D	WKLY BATT SURV DOCUMENTATION NOT COMPLETED	PERSONNEL ERROR-NONLIC. OPERATIONS PERFS
G EN1	021719	062778	BA DB 102	R U D	WKLY PILOT CELL SURV OF 1C D/G BTRY NOT COMPLETED	ED ON TIME. PERSONNEL OVERSIGHT
G EN2	022208	081678	BA NN 102	R U D	WKLY PILOT CELL SURV OF PLANT BATT NOT COMPLETED	ON TIME. NOTICES ROUTED TO ABSENT PERFS
G DC1	030599A	022880	BA ST 102	R U D	MAIN STATION BTRY SURV TEST NOT PERFORMED	PLANT PERFS FAILED TO ADHERE TO SURV SCHEDULE
G DC1	030599B	022880	BA DB 102	R U D	DIESEL GENERATOR BTRY SURV TEST NOT PERFORMED	PLANT PERFS FAILED TO ADHERE TO SURV SCHEDULE
G DC1	038737	091181	BA NN 102	R U D	BATTERY SURVEILLANCE PROCEDURES FOUND NOT TO FULLY	-Y COMPLY WITH NEW REQUIREMENTS.
B CR3	017166A	011277	BA NN 103	R U D	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B CR3	017166B	020277	BA NN 103	R U D	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B CR3	017166C	020977	BA NN 103	R U D	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
C AR2	026489	052279	BA ST 103	R U D	SURVEILLANCE NOT PERFORMED ON STATION BATTERIES	PERSONNEL OVERSIGHT
M BV1	017119A	020477	BA ST 103	R U D	SURVEILLANCE TEST NOT PERFORMED ON #3 & #4 STATION	-N BATTERIES. PERSONNEL ERROR
M BV1	017119B	020477	BC ST 103	R U D	SURVEILLANCE TEST NOT PERFORMED ON CHARGERS ASSOC-	-ATED WITH #3 & #4 STATION BTRY. PERSONNEL
M JF1	027181	090679	BA NN 103	R U D	QUARTERLY AUXILIARY BUILDING BATTERY VERIFICATION	-NOT PERFORMED ON TIME. PERSONNEL
M TR1	025211A	011979	BA NN 103	R U D	125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL
M TP1	025211B	011979	BC NN 103	R U D	125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL
G CD1	037938	052681	BA ST 103	R U D	5G TESTS FOR 125V 1A6B AND 250V 1B NOT PERFORMED	-PROPERLY. PERSONNEL USED WRONG HYDROM
G EN1	027782	112679	BA NN 103	R U D	CELL SURVEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT
G EN2	026657	071879	BA NN 103	R V D	CELL SURVEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE CAUSE

UNION	PLANT	CONTROL NUMBER	EVENT DATE	CDMP	STATUS	FAILURE CODE	ACTIVITY TYPE	CLASS	FAIL #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
B DE3		015532	081876	BA	NN	T05	R U D			125-VDC INSTR & CNTRL BATTERIES NOT LOAD TESTED	DFCIV PROC: WRONG DATA IN SURV PRINTOUT
W DC2		039127	101981	BA	NN	T05	R U D			SURVEILLANCE NOT PERFORMED ON "NM" TRAIN BATTERY	PROCEDURE LACKED SIGNOFF
W NA1		026565	062879	BA	DB	T05	R U D			7 DAY SURVEILLANCE OF EMERGENCY DIESEL GENERATOR -	-BATTERIES EXCEEDED INTERVAL. PROCEDURAL
W NA1		026656	073179	BA	DB	T05	R U D			DIESEL GENERATOR BATTERIES SURVEILLANCE NOT DONE	TIME LAG IN IMPLEMENTING NEW PROCEDURES
W NA2		036417	022081	BA	DB	T05	R U D			DATA FROM TWO TESTS ON 2J DIESEL BATTERY FOUND NO-	-T USABLE. NOT COMPARED WITH INITIAL CON
W PF1		026268	053179	BA	FP	T05	R U D			DIESEL DRIVEN WEEKLY BATTERY INSPECTION NOT DONE	PROCEDURES WERE DEFECTIVE
W SE1		032342A	081280	BA	DB	B05	U D			D/G BTRY 1B-B CELLS 49,50,51 DISCHARGED	INADEQUATE PROCEDURE
W SE1		032342B	081380	BA	DB	B05	U D			D/G BTRY 1B-B CELLS 49,50,51 DISCHARGED	INADEQUATE PROCEDURE
W TR1		014563	032476	BA	ES	T05	R U D			ESF DC PWR SUPPLIES SURV REQ PERFORMD AT WRNG FREQ	PROCEDURE DID NOT USE FREQ REQ BY T.S.
W Z11		172130	121581	BA	NN	C05	U U D			EQUALIZING CHARGE NOT PLACED ON BATTERY 112	PROCEDURE NOT CLEAR ON COMMUNICATIONS
G BR2		014651	021276	BA	NN	T05	R U D			MONTHLY INSTEAD OF QUARTERLY BATTERY P.T. PERFORMD	WRONG P.T. SCHEDULED BY MISTAKE
G VY1		021749	061978	BC	NN	B06	N S D			AC INPUT BRKR TO C&I BATT CHRGR TRPD OPEN	SPURIOUS TRP OF AC BRKR IN AN ELEC STERN
G DP3		020853	032878	BA	NN	A10	F R T			24/48 V BTRY FAILED THE REFUELING OUTAGE DISCHRG-	-TEST. 4 CELLS REPLCD NAT'L END OF LIFE
G FP1		033280	111780	BA	ST	A10	N T			STATON BTRY B MADE INDP TO JUMP A CELL	CELL #8 POOR PERFORMANCE DUE TO AGE
W YR1		019476A	101477	BC	NN	B1210	N R T			NO. 2 BATTERY CHARGER TAKEN OUT OF SERVICE	FAILED BEARING
W YR1		019640	110577	BC	NN	B1210	N R T			NO. 1 BATTERY CHARGER TAKEN OUT OF SERVICE	FAILED BEARING DUE TO NORMAL WEAR
B T12		023084*	111278	BC	NN	B13	B U	2		CHRGRS 2-2A/B FUSE BLEW NO CHRGR FOR BANK 2-25B	DEFECTIVE GATING FILTER MODULES
C AR2		026904	080979	BC	NN	B1306	N C D			BATTERY CHARGER 2031 FAILED. DC OUTPUT LAMP SOCK-	-ET BURNED UP DUE TO HIGH HEAT, VOLT, DIST
W IP3		015138	060876	BC	NN	B13	A S U			# 31 BTRY CHRGR AC BRKR TRIPD BATT CHRGR INDP	PRESSURE SENSOR FAILED TRIPPING BREAKER
W IP3		038257	070681	BC	NN	B13	N S U			BATTERY CHARGER #32 DISCOVERED TRIPPED	FAILED DP AIR FLOW SENSOR SWITCH
W SU2		169141	081981	BC	FP	B13	N U			SMOKE DET SYS INDP BTRY CHRGR LOST POWER	FAULTY POWER SUPPLY CARD IN CHARGER
G EN1		021475*	060478	BC	ST	M1304	M D	2		HEAT-SENSITIVE XSTR ON BATT CHRGR FIRING MODUL CRD	SHOULD BE A NON-HEAT-SENSITIVE TRANSISTOR
G VY.		018407B	031877	BC	UP	B13	N T			UPS-1B CONTROL CHARGING POWER SUPPLY FAILED	FAILED CAPACITOR IN ON/OFF CIRCUITRY
B DB.		020448	011978	BA	ST	A1415	E U			1N BTRY CELL 32 ELECTROLYTE S.G. DECRS .003 NOT	ELEC. STRAT. DUE TO LG BTRY LOADING
W DC2		021633	060778	BA	NN	A14	A U			CD PLANT BTRY CELL 89 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W DC2		021632	061578	BA	NN	A14	A U			AB PLANT BTRY CELL 35 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W JF1		032332A	081280	BA	SW	A14	A R U			SW BLDG B BTRY SYS LOW SPECIFIC GRAVITY	BATT PLACED ON EQUALIZE & S.G. ACCEPTABLE
W JF1		032332B	082580	BA	SW	A14	A R U			SW BLDG B BTRY SYS LOW SPECIFIC GRAVITY	NO EXTERNAL CAUSE FOR LOW SPECIFIC GRAY
W JF1		032687	091180	BA	SW	A1404	A D			SW BLDG "AM" BATT SYS LD BATT CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN
W JF1		033007	102180	BA	SW	A1404	A D			SW "AM" BTRY SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN
W JF1		033163	102880	BA	SW	A1404	A D			SW BLDG "AM" BATT SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM PROX/ACID RES/POST SEAL DESIGN
W NA1		171472	120181	BA	DB	A1410	A T			1J EMERGENCY D/G INDP CELL S.G. BELOW 1.2	D/G BATTERY NEAR END OF USEFUL LIFE

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE CAUSE

SYSTEM	CONTROL NUMBER	EVENT DATE	UNIT	STATUS	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
W	HAZ 036466*	021881	BA DB M14	E U	2 BATTERIES FOR 2J & 2H DIESEL GENERATORS FAILED SU-	--REVEILLANCE TEST, 4 CELLS REPLACED
G	BPI 0193268	072276	BA SA A1432	C D	RDS BATTERY D PILOT CELL HAD LOW SPECIFIC GRAVITY	ADDITION OF WATER POSSIBLE CAUSE
G	BPI 0193278	072976	BA SA T14	C U D	RDS BTRY C PILOT CELL RDG 10 SPECIFIC GRAVITY	DFCTV PROC SPECIFIC GRAVITY READ TOO SOON
G	BPI 016073A	100476	BA SA A1405	A D	RDS D BTRY PILOT & 3 OTHER CELLS LD SPEC GRAVITY	INCOMPLETE ELECTROLYTE MIXING
G	BPI 016302A	102176	BA SA A14	D U	RDS "A" BTRY PILOT CELL 55 LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BPI 016459	110476	BA SA A14	C U	RDS B PILOT CELL LOW SPECIFIC GRAVITY	UNKNOWN CAUSE
G	BPI 016302B	112176	BA SA A14	D U	RDS "A" BTRY PILOT CELL 55 LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BPI 016594	120276	BA SA A14	D U	RDS B BTRY PILOT CELL 27 LD SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BPI 017023	120976	BA SA A14	D U	RDS B ONE CELL LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G	BPI 017024*	010477	BA SA M14	A R U	2 B CELLS SPECIFIC GRAVITY FOUND BELOW 1.2. EVALUA-	--TION REVEALED ADEQUATE CAPACITY
G	BPI 017464	022477	BA SA M14	C R U	RDS BATTERY B HAD ONE CELL BELOW MINIMUM SPECIFIC-	--GRAVITY. ADEQUATE CAPACITY AVAILABLE
G	BPI 017463	031777	BA SA M14	C R U	SPECIFIC GRAVITY FOUND LOW IN 5 CELLS OF RDS BTRY-	--"A". ADEQUATE CAPACITY AVAILABLE
G	BPI 018096A	042177	BA SA M14	C R U	RDS BATTERY B, CELL 27 FOUND TO HAVE LOW SPECIFIC -	--GRAVITY OF 1.191. FULL CAPACITY AVAIL
G	BPI 018096B	042777	BA SA M14	C U	SPECIFIC GRAVITY OF LD MARGINAL CELLS ADJUSTED DF-	--RDS BATTERY "A". FULL CAPACITY AVAILALE
G	BPI 018462B	061677	BA SA T1432	C V D	SPECIFIC GRAVITY OF CELL 27 OF RDS BATTERY B LOW	WATER ADDED THEN TESTED FOR SOON
G	BPI 019472B	092977	BA SA A1452	C R D	SPECIFIC GRAVITY OF CELL 12 OF RDS BATTERY "A" LOW	WATER ADDED, CHARGE INSUFFICIENT TO RIP
G	BPI 019542B	102077	BA SA A1432	C R D	SPECIFIC GRAVITY OF 3 CELLS OF RDS BATTERY "A", CELL 12 LOW	EQUALIZING CHARGE FOR 8 HOURS CORRECTED
G	BPI 020176	122277	BA SA A14	C R U	RDS BATTERY A, CELL 12 LO SPECIFIC GRAVITY READING	EXACT CAUSE UNKNOWN
G	BPI 022664	083178	BA SA A14	C R U	RDS C BTRY CELL 14 LOW SPECIFIC GRAVITY RDG	EFFECTIVE CELL REPLACED
G	BPI 027985	110179	BA SA A1420	C U	RDS BTRY "A" CELL 7 LOW SPECIFIC GRAVITY RDG	CELL DID NOT RESPOND ADD TO EQUALIZ CHRG
G	BPI 030237	012400	BA SA A1420	C U	RDS C BTRY CELLS 35,54 LOW SPECIFIC GRAVITY RDG	CELL DID NOT RESPOND 2% TO EQUALIZ CHRG
G	BPI 031176	050180	BA SA A1420	C U	RDS C BTRY CELLS 36,39,56 LOW SPECIFIC GRAVITY	VENDOR REC'DM INCRS IN FLOAT VOLTAGE LEVEL
G	BPI 031848	071080	BA SA A14	C U	RDS D BATTERY CELL 12 LOW SPECIFIC GRAVITY RDG	CELL DID NOT ADD RESPOND TO EQUALIZ CHRG
G	BPI 032297	040780	BA SA A14	C U	21 CELLS OF RDS "A" BATTERY LOW SPECIFIC GRAVITY	CELL TERMINALS INADQ. CLEANED BY MAINT PER
G	BPI 032656	091180	BA SA A1420	C U	RDS CH D BATTERY CELL 56 HAD LOW SG, WOULD NOT RES-	--FOND TO EQUALIZING CHARGE.
G	BPI 033544	121180	BA SA A1402	C D	RDS "A" RDS BTRY CELL #5 LOW SPECIFIC GRAVITY	CELL DIDN'T RESPOND ADD TO EQUALIZ CHRG
G	BPI 037338	010281	BA SA A1420	C R U	LO S.G. OF BTRY A2 CELL 1	HAD CELL IN BATTERY
G	BPI 038785	051581	BA SA A1420	C U	2 DIESEL FIRE PUMP 24V BATT CELLS A2-6, B2-1 LD 2 S.G.	CHARGER DUS DURING SURVEILLANCE
G	BPI 021433	053178	BA FP A1420	A U	B BTRY CAPACITY BELOW DESIGN	CELL 3-G, IN LO RND, PARTIAL ACID REPLED
G	BPI 031743*	062880	BA SP A14	A T	FOUND PILOT CELL IN CH A RDS POWER SUPPLY WITH A -	--HIGH ELEC LEVEL. POSSIBLY OVERFILLED
G	BPI 014211	012976	BA HN A14	B U		
G	BPI 038112	061581	BA SA A1402	A C D		

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE CAUSE

STATUS	PLANT	CONTROL NUMBER	EVENT DATE	COMP	REMARKS	FAILURE CODE	ACTIVITY TYPE	CLASS	FAIL #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
M	HNI	0146088	042576	BC	NN	D2122	N	U		VOLTG REG SPEKING TO 200 AMPS THEN SHUTTING OFF	FAULTY PHASING CRD IN CURRENT LIMITER CKT
M	IP3	036207	012481	BC	NN	B2123	N	U		OUTPUT FROM CHARGER #32 DISCOVERED DROPPING	VOLTAGE AND CURRENT CONTROLLER REPLACED
M	PP2	014599	041476	BC	NN	B2133	B	U		#12 BATTERY CHARGER FAILED DISABLED "B" DC POWER	VOLTAGE CNTRL CRD LOOSE IN ITS SOCKET
M	SA2	038319	072481	BC	NN	B2101	N	U	D	2C1 BATTERY CHARGER DISCOVERED TRIPPED. VOLTAGE -	-SETTING WAS INCORRECTLY SET
G	EN2	030651*	032580	BC	ST	A2122	G	U	2	EMER STATION BATT CHRGR 2G, 2J FAILED TO HOLD LOAD	VOLTG CNTRL & CURR LMT MODULES TUNED
G	PI1	033899	082180	BC	NN	B2113	N	U		"A" 125 VDC CONTROL BATT CHARGER INOPERABLE	VOLTAGE REGULATOR ELECTRONIC MODULES FPLC
G	QC2	018460	060977	BC	NN	E2101	N	U	D	BATTERY CHARGER SUPPLYING CURRENT TO BATTERY FOUN-	-D LOW. FLOATING POTENTIOMETER SET LOW
G	YI1	0162178	101376	BC	UP	B21	N	R	U	CNTRL BTRY CHARGING POWER SUPPLY FAILED	INOPERATIVE VOLTAGE REGULATOR CIRCUIT
C	PA1	016178	102076	BC	NN	E2201	N	D		DC BUS-2 VOLTG FELL, VOLTG ON ASSOC AC BUSES FELL	CURR LMT & OUTPUT BRKR SETTING ERRONEOUS
G	BR1	019389	102177	BC	NN	B2206	B	U		BATT CHRGR DC OUTPUT FUSE FAILED WHEN CHRGR BATT 2B-2	HI CURR/TEMP CAUSD SOLDERD LINKG SEPARATE
G	DR1	018553B	072977	BC	FP	B22	N	U		FUSE FOUND BLOWN IN DIESEL FIRE PUMP BATTERY CHARG-	-GR.
G	EN2	030711B	032780	BC	ST	A22	G	U		STATION BATT CHRGR 2C FAILED TO MAINTAIN LOAD	CURRENT LIMIT MODULE NEEDED ADJUSTMENT
G	CO1	022101A	062778	BC	NN	B2333	N	T		1A 250V BTRY CHRGR TIE BREAKER TRIPPED	PORR CNCTR CNTCTS IN CURRENT MODULE
G	QC2	018164	031777	BC	NN	C23	U	U		UNITS BATTERY CHARGER APPARENTLY INOPERABLE	FAULTY INDUCTIVE CURRENT CONTROL CIRCUIT
C	SL1	038775	091881	BC	NN	B24	A	R	U	1A BATTERY CHARGER SHUTDOWN ON HIGH VOLTAGE	HIGH VOLTAGE DEVICE FOUND DEFECTIVE
M	JF1	032504	082580	BC	SW	B24	N	S	U	SW B DC DISTRIBUTION SYS INOP NO OUTPUT FROM BATT-	-CHRGR 4. HV S/D RELAY ACTUATED
M	SA2	038327	081281	BC	NN	B24	N	U		2B1 BATTERY CHARGER WOULD NOT PICK UP 28 VDC LOAD	HIGH VOLTAGE CUT-OUT ACTUATED
M	RV1	037757	061581	BC	NN	B2506	N	R	D	#2 BATTERY CHARGER OUTPUT BREAKER FAILED OPEN	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
M	RV1	038347	080581	BC	NN	B2506	N	R	D	#2 BATTERY CHARGER OUTPUT BREAKER TRIPPED OPEN	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
M	IP3	014709	051076	BC	NN	B2630	A	U		BTRY CHRGR TROUBLE ALARMED CHARGER FAN HAD TRPD	AC FAN MTR INOP EXPOSED WIRE BLEW A FUSE
M	RV1	021043	032078	BC	NN	E2713	N	U		DECR #4 DC BUS VOLTAGE DUE TO A FAULTY BTRY CHRGR	FAILD COLLECTR RESISTR IN CHRGR CNTRL CKT
G	DC1	018293B	062877	BC	SY	B2713	U	U		BATTERY CHARGER FOR SWITCHING STATION BATTERY FOU-	-ND ODS AFTER 11 DAYS
M	HNI	014608A	042576	BC	NN	D2833	N	U		BTRY CHARGER A WENT INTO OVERCHARGE	FAULTY CNTCT ON CHARGER CONTROL TIMER
M	PP1	033222	110580	BC	NN	A2911	A	U		#12 BTRY CHRGR FAILED TO PROVIDE NORMAL OUTPUT	FIRING CARD B NOT PROVIDING PULSE TO SCR
G	RP1	015248A	063076	BC	ST	B29	N	U		STATION BATTERY CHARGER FAILED	DEFECTIVE SILICON RECTIFIERS
G	CO1	037646	090581	BC	ST	G29	B	U		HIGH RIPPLE FROM BATTERY CHARGER WHICH FAILED INV-	-ERTER 1A. FAILED SCR
G	EN2	030711A	032780	BC	ST	A29	G	U	2	STATION BATT CHRGR 2A, 2B FAILED TO MAINTAIN LOADS	SILICON CNTRL RECTIFIERS NEED LOAD BALANC
B	CR3	038100	071481	BA	ST	B3002	N	C	D	STATION BATTERY SHORTED DURING MAINTENANCE	PERSONNEL ERROR. CAUSED REACTOR TRIP
M	SE1	032338	080780	BA	DB	B30	N	U		D/G BTRY 1B-B CELL 51 SHORTED AND FAILED	NO CAUSE GIVEN
G	FN2	033891	081180	BA	ST	B30	M	U		DC BATT GROUND ON 2B STATION SERVICE BATTERY	NO CAUSE GIVEN
B	DE3	022183	072778	BA	NN	B33	B	U		SMOKE FROM 1 TERMINAL OF 16C BATTERY 30B	TERMINAL DEFCTV/CNNCTNS FOUND DEFECTIVE
M	RV1	038825	091081	BC	ST	B33	N	U		#4 STATION BATTERY CHARGER TAKEN OUT OF SERVICE	BAD ELECTRICAL CONNECTION IN OUTPUT

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY FAILURE CAUSE

SYSTEM	CONTROL NUMBER	EVENT DATE	STATUS	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION	
M	039106	101981	BA ST	A3308 M T	CELL TO CELL RESISTANCE IN 3 CELLS FOUND HIGH	CORROSION OF TERMINAL CONNECTIONS
M	021898	071678	BA ST	B3311 N D	PLASTIC TOP OF 2 STATH "A" BATT CELLS ON FIRE	RESISTING HEATG OF STRAP-CELL TERMINAL
M	030834	091881	BA FP	B33 N U	BATTERY CABLE CLAMP FOUND ARCING AND CRACKED	CLAMP WAS REPLACED ON #2 FIRE PUMP BTRY
G	015394	070976	BA NN	B3302 M U D	NEUTRON MONITORING BATTERY 2A MADE INOPERABLE	CNACTR BROKEN OFF A CELL POST PERS ERROR
G	025671	041979	BA SP	B3302 N C D	BROKEN TERMINAL DISCOVERED ON S7D BOARD "D" BTRY	PERSONNEL ERROR, ALSO AFFECTED UNIT 1
G	015444	081276	BA DB	B33 N T	EMERGENCY DIESEL GENERATOR DID NOT START DUE TO L-	-DENSE BATTERY CONNECTION,
G	017704	033077	BA UP	B3304 M C D	4 NU OUTPUT FROM ALL UPS BATTERY BANKS	CONNECTORS NOT TIGHTENED DURING INSTAL
G	019025A	082977	BA FP	B3302 M D	DIESEL FIRE PUMP "A" BATTERY FOUND WITH NO OUTPUT	CONNECTORS NOT TIGHTENED
G	025637A	032579	BA NN	A3308 B R T	BATTERY 1B2 VOLTAGE FELL TO 102.5V THEN ROSE TO -	-110V, CORRODED AND LOOSE BTRY CONNECT
G	025637B	032779	BA NN	A3308 B R T	BTRY 1B1 VOLTAGE FELL TO 96.8V THEN ROSE TO 118V	CORRODED AND LOOSE BTRY CONNECTORS
G	022101B	052778	BC NN	B3304 M U D	1A 250V BTRY CHRGR INPUT BREAKER TRIPPED	LOOSE CNCTIN AT CHRGR INPUT BRKR PHASE A
M	020738A	020178	BA NN	A34 N U	1C 125V BATTERY VOLTAGE LOW	1C1,1C2 BATT CHARGER D.C. BRKKS TRPD
M	038936A	100181	BA FP	B34 A D	SMOKE DETECTOR BATTERY FAILED	CHARGER NOT CHARGING BATTERY
M	033530B	121180	BA NN	T34 N U T	4B 125 VDC BATT DOS,TECH SPEC EXCEEDED	PROBLEM W/ ASSOCIATED BTRY CHARGER
G	018553A	072977	BA FP	B3413 M C D	2 DIESEL FIRE PUMP BATTERIES FAILED TO START DIESEL	FAILED FUSE FROM BATTERY CHARGER CIRCUIT
G	016265A	101876	BA NN	A34 A D	BATTERY IN A DEGRADED CONDITION	CHARGER SUBJECTED BTRY TO "DEEP CYCLING"
G	166730A	061591	BA NN	A3401 A D	250 VDC BATTERY INADVERTENTLY DISCHARGED	PERS DISCONNECTED TEMP BATTERY CHARGE
G	018293A	062877	BA SY	B34 U C D	ONE OF TWO SWITCHING STATION BATTERIES FOUND DMS -	-FOR 11 DAYS, BATTERY CHARGER FAILED
G	016274	101376	BA UP	A34 N R U	UPS-1B CNTRL PWR BTRY VOLTAGE W/S LOW	CNTRL BATT CHRNGNG POWER SUPPLY FAILED
G	018407	031877	BA UP	A3413 N R D	UPS-1B ALARMED DUE TO LOW VOLTAGE; CAUSED SCRAM	CAPACITOR FAILED IN CHARGING POWER SUPPLY

APPENDIX H
ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS
CAUSED BY HUMAN FACTORS

CODES USED IN LER ONE-LINE DESCRIPTIONS

NSSS VENDOR		FAILURE CAUSE		TYPE EVENT	
CODE	DESCRIPTION	CODE	DESCRIPTION	CODE	DESCRIPTION
B	BABCOCK & WILCOX	00	UNKNOWN	B	RECURRING COMMON CAUSE
C	COMBUSTION ENGINEERING	01	PERSONNEL OPERATION	C	COMMON CAUSE
M	WESTINGHOUSE	02	PERSONNEL MAINTENANCE	R	RECURRING
G	GENERAL ELECTRIC	03	PERSONNEL TESTING	S	COMMAND FAULT
-----		04	DESIGN/FABRICATION/CONSTRUCTION/QUALITY CONTROL	T	RECURRING COMMAND FAULT
EVENT CLASSIFICATION		05	DEFECTIVE PROCEDURES	J	COMMON CAUSE COMMAND FAULT
-----		06	EXTREME ENVIRONMENT	V	RECURRING COMMON CAUSE COMMAND FAULT
CODE	DESCRIPTION	08	CORROSION	BLANK	RANDOM
D	FREQUENCY	10	NORMAL WEAR/NATURAL END OF LIFE	-----	
T	AGE	11	ELECTRICAL MALFUNCTION	ACTIVITY RESULTING IN DISCOVERY	
U	UNKNOWN	12	MECHANICAL MALFUNCTION	-----	
-----		13	PIECE PART FAILURE	CODE	DESCRIPTION
COMPONENT		14	LOW SPECIFIC GRAVITY	A	TESTING (UNSPECIFIED)
-----		15	STRATIFICATION	B	NORMAL LOAD TESTING
BA	BATTERY	16	HIGH ELECTROLYTE SOLUTION LEVEL	C	MONTHLY TESTING
BC	BATTERY CHARGER	17	LOW ELECTROLYTE SOLUTION LEVEL	D	WEEKLY TESTING
-----		18	INSUFFICIENT CHARGE	E	QUARTERLY TESTING
		19	DEFECTIVE/WEAK CELLS	F	REFUELING TESTING
		20	VOLTAGE REGULATOR MALFUNCTION	G	18 MONTH TESTING
		21	CURRENT LIMITER MALFUNCTION	H	3 YEAR TESTING
		22	CURRENT CONTROLLER MALFUNCTION	M	MAINTENANCE
		23	VOLTAGE LIMITER MALFUNCTION	N	NORMAL PLANT OPERATION
		24	THERMAL OVERLOAD PROTECTION	R	RECORDS REVIEW
		25	COOLING FAN/VENTILATION MALFUNCTION	U	UNKNOWN
		26	CHARGE CONTROL MALFUNCTION	-----	
		27	CHARGE CONTROL TIMER MALFUNCTION	FLAGGING FIELD	
		28	RECTIFIER PROBLEM	CODE	DESCRIPTION
		29	SHORT CIRCUIT	A	FAILED COMPONENT CAUSED AN ACCIDENT
		30	ELECTROLYTE DILUTION	B	COMPONENT FAILED TO MITIGATE AN ACCIDENT
		31	FAULTY CABLE/CONNECTORS	C	SAFETY SIGNIFICANT
		34	CHARGER MALFUNCTION	D	FAIL # NOT KNOWN
-----		FAILURE MODE		E	CELL # NOT KNOWN
		-----		F	FAIL # AND CELL # NOT KNOWN
		CODE	DESCRIPTION	N	FROM NSIC DATA BASE
		A	REDUCED CAPABILITY	-----	
		B	NO OUTPUT		
		C	UNKNOWN/UNSPECIFIED/OTHER		
		D	HIGH CURRENT/VOLTAGE OUTPUT		
		E	LOW OUTPUT VOLTAGE		
		G	HIGH AC RIPPLE ON DC OUTPUT		
		H	MAINTENANCE REPLACEMENT		
		T	TEST NOT PERFORMED		

SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
AM	- AREA MONITOR SYSTEM
DB	- EMERGENCY DIESEL GENERATOR
ES	- ENGINEERED SAFETY FEATURE
FP	- FIRE PROTECTION SYSTEM
FW	- FEEDWATER SYSTEM
NM	- NEUTRON MONITORING BATTERY
NN	- UNKNOWN/UNSPECIFIED/OTHER
SA	- AUTOMATIC (REACTOR) DEPRESSURIZATION (ADS)
SP	- SPECIAL USE BATTERIES
ST	- STATION BATTERIES/CHARGERS
SW	- SERVICE WATER BUILDING BATTERIES/CHARGERS
SY	- SWITCHYARD BATTERIES/CHARGERS
UP	- UNINTERRUPTIBLE POWER SYSTEM (UPS)

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS CAUSED BY HUMAN FACTORS

W	M	C	CONTROL NUMBER	EVENT DATE	LOCATION	STATUS	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
B	CP3	0171664	011277	BA NN T03	R	U	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B	CP3	0171668	020277	BA NN T03	R	U	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B	CP3	017166C	020977	BA NN T03	R	U	INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B	CP3	021165	040578	BA NN T02	R	V	WRONG BTRY CELLS MONITORED FOR WEEKLY BATT SURV	PERSONNEL NOT FOLLOWING PROCEDURES
B	CP3	038100	071481	BA ST B3002	N	C	STATION BATTERY SHORTED DURING MAINTENANCE	PERSONNEL ERROR. CAUSED REACTOR TRIP
B	DB1	022362	090578	BA ST T02	R	U	STATION BATTERIES W/4LY SURV TEST NOT DONE ON TIME	MISUNDERSTANDING BTRM PERSONNEL
B	DB3	015532	081876	BA NN T05	R	U	125-VDC INSTR & CNTRL BATTERIES NOT LOAD TESTED	DFCTV PRUC: WRONG DATA IN SURV PRINTOUT
C	AR2	026489	052279	BA ST T03	R	U	SURVEILLANCE NOT PERFORMED ON STATION BATTERIES	PERSONNEL OVERSIGHT
C	CC2	017344	021777	BA NN B01	N	S	#11 125 VDC BATTERY INADVERTENTLY TAKEN OUT OF SE-	--RVICE. SUPERVISOR GAVE PERMISSION
C	PA1	016178	102076	BC NN F2201	N	D	DC BUS-2 VOLTG FELL/DVLTG ON ASSOC AC BUSES YEL'	CUPR LMR & OUTPUT BRKR SETTING ERRONEOUS
C	PA1	025917	040479	BA ST B2005	A	C	2 CELLS IN STATION BATTERY #2 BURST WHILE TAKING --	--VOLTAGE READINGS. FULL CAPACITY AVAIL
C	PA1	036000*	010681	BA ST B02	U	U	2 OUTPUT BREAKER FOR BOTH STATION BATTERIES WEPE OP-	--EMED FOR 1 HOUR. PERSONNEL ERROR
C	S11	037962	062481	BC NN T02	R	U	SURVEILLANCE REQUIREMENTS NOT MET ON "AB" BATTERY-	--CHARGER. MISINTERPRETATION OF TECH SPEC
M	RV1	0171194	020477	BA ST T03	R	U	SURVEILLANCE TEST NOT PERFORMED ON #3 & #4 STATION-	--N BATTERIES. PERSONNEL ERROR
M	BV1	0171198	020477	BC ST T03	R	U	SURVEILLANCE TEST NOT PERFORMED ON CHARGERS ASSOC-	--IATED WITH #3 & #4 STATION BTRY. PERSON
M	DC1	025643	032379	BC NN D01	M	U	125 VDC EQUALIZING CHARGE TOO HIGH, FAILED INVERT-	--EP, CAUSED SCRAM AND ST. NO CAUSE
M	DC2	039127	101981	BA NN T05	R	U	SURVEILLANCE NOT PERFORMED ON "M" TRAIN BATTERY	PROCEDURE LACKED SIGNOFF
M	JF1	027181	090679	BA NN T03	R	U	QUARTERLY AUXILIARY BUILDING BATTERY VERIFICATION-	--NOT PERFORMED ON TIME. PERSONNEL
M	JF1	032687	091180	BA SW A1404	A	D	SW BLDG "M" BATT SYS LO BATT CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN
M	JF1	033007	102180	BA SW A1404	A	D	SW "M" BTRY SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN
M	JF1	033163	102890	BA SW A1404	A	D	SW BLDG "M" BATT SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM PROX/ACID RES/POST SEAL DESIGN
M	NA1	026565	062879	BA DB T05	R	U	7 DAY SURVEILLANCE OF EMERGENCY DIESEL GENERATOR --	--BATTERIES EXCEEDED INTERVAL. PROCEDURAL
M	NA1	026656	073179	BA DB T05	R	U	DIESEL GENERATOR BATTERIES SURVEILLANCE NOT DONE	TIME LAG IN IMPLEMENTING NEW PROCEDURES
M	NA1	036491A	022881	BA ST T02	R	U	18 MONTH SURVEILLANCE ON D.C. DISTRIBUTION SERVIC-	--E SYSTEM NOT DONE. PERSONNEL OVERSIGHT
M	NA1	036491B	022881	BC ST T02	R	U	18 MONTH SURVEILLANCE ON D.C. DISTRIBUTION SERVIC-	--N SYSTEM NOT DONE. PERSONNEL OVERSIGHT
M	NA2	036417	022081	BA DB T05	R	U	DATA FROM TWO TESTS ON 24 DIESEL BATTERY FOUND NO-	--T USABLE. NOT COMPARED WITH INITIAL CON
M	PR1	026268	033179	BA FP T05	R	U	DIESEL DRIVEN WEEKLY BATTERY INSPECTION NOT DONE	PROCEDURES WERE DEFECTIVE
M	PR1	030917	033180	BA ST T02	R	U	INDIVIDUAL FLOAT CELL VOLT MEAS NOT DONE IN STATI-	--ON BATTERY TEST. PERSONNEL OVERSIGHT
M	P02	015515	071076	BA NN B02	M	D	BATTERY B LEADS WERE REMOVED RENDERING BATT INOP	PEPS FAILED TO COMPLY W/ T.S. 3.7
M	SA1	032162	072180	BA FP T02	R	U	92 DAY & 18 MON SURV NOT DONE ON 24 V STARTG BATT	ELECTRICIAN NOT COMPLETING JOB
M	SA2	038319	072481	BC NN B2101	N	U	2CC1 BATTERY CHARGER DISCOVERED TRIPPED. VOLTAGE --	--SETTING WAS INCORRECTLY SET
M	SF1	0323424	081280	BA DB B05	U	D	076 BTRY 18-B CELLS 49+50-51 DISCHARGED	INADEQUATE PROCEDURE

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS CAUSED BY HUMAN FACTORS

PLANT	CONTROL NUMBER	EVENT DATE	CONTROL	DESCRIPTION	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
M	5F1	0323428	081380	BA DB P05	U 0	D/G BTRY 18-B CELLS 49,50,51 DISCHARGED INADEQUATE PROCEDURE
M	T91	014563	032476	BA ES T05	R U D	ESF DC PWR SUPPLIES SURV REQ PERFORMD AT WRNG FREQ PROCEDURE DID NOT USE FREQ REQ BY T.S.
M	T91	020885	031778	BA NN T02	R U D	125 VDC ELECTRICAL SYS OP NOT VERIFIED WK OF 7-26 MAINT PERS FAILED TO INSURE SURV COMPLETED PERSONNEL
M	T91	0252114	011979	BA NN T03	R U D	125 VDC ELECTRICAL SYSTEM NOT VERIFIED PERSONNEL
M	T91	0252118	011979	BC NN T03	R U D	125 VDC ELECTRICAL SYSTEM NOT VERIFIED PERSONNEL
M	T03	022061A	122277	BA ST T01	U U D	EQUALIZING CHARGES ON STATION BATTERIES NOT PERFORMED. PERSONNEL ERROR, FULL CAPACITY AVAIL
M	T03	022061B	122977	BA ST T01	U U D	EQUALIZING CHARGES ON STATION BATTERIES NOT PERFORMED. PERSONNEL ERROR, FULL CAPACITY AVAIL
M	Y91	019476B	101477	BC NN T01	N U D	NO. 1 BATTERY CHARGER CROSS TIED TO NO. 2 BATTERY OVERSIGHT CAUSE LCO STATED IN TECH SPEC
M	Z11	171128A	121281	BA NN B01	M U D	UNIT 2 212 BATTERY TAKEN D05 ERRONEOUSLY LICENSED OPERATOR ERROR
M	Z11	171128B	121281	BC NN B01	M U D	UNIT 2 212 CHARGER TAKEN D05 ERRONEOUSLY LICENSED OPERATOR ERROR
M	Z11	172130	121581	BA NN C05	U U D	EQUALIZING CHARGE NOT PLACED ON BATTERY 112 PROCEDURE NOT CLEAR ON COMMUNICATIONS
G	R2	015394	070976	BA NN B3302	M U D	NEUTRON MONITORING BATTERY 2A MADE INOPERABLE C/NCTR BROKEN OFF A CELL POST PERS ERROR
G	R2	025671	041979	BA SP B3302	N C D	BROKEN TERMINAL DISCOVERED ON STD BOARD "D" BTRY PERSONNEL ERROR. ALSO AFFECTED UNIT 1
G	R1	016073A	100476	BA SA A1405	A D	R05 0 BTRY PILOT & 3 OTHER CELLS LO SPEC GRAVITY INCOMPLETE ELECTROLYTE MIXING
G	R1	017704*	033077	BA UP B3304	N C D	4 NO OUTPUT FROM ALL UPS BATTERY BANKS CONNECTORS NOT TIGHTENED DURING INSTAL
G	R1	019025A	082977	BA FP B3302	N D	DIESEL FIRE PUMP "A" BATTERY FOUND WITH NO OUTPUT CONNECTORS NOT TIGHTENED
G	R1	021519	022578	BA FP A1705	D D	FIRE PUMP DIESEL STARTG BTRY "A" CELLS 2,4,6 LO-- ELCTROLYTE SOLN. INADQ MAINTENANCE PROC
G	R1	033544	121180	BA SA A1402	C D	21 CELLS OF R05 "A" BATTERY LOW SPECIFIC GRAVITY CELL TERMINALS INADQ CLEANED BY MAINT PER
G	R1	033637	122380	BA NN T02	R U D	DC BATTERY MONTHLY TESTS OVERDUE INADQ ADMIN CONTROLS & PERSONNEL ERROR
G	R1	038112	081581	BA SA A1602	A C D	FOUND PILOT CELL IN CH A R05 POWER SUPPLY WITH A -- HIGH ELEC LEVEL. POSSIBLY OVERFILLED
G	R2	014651	021276	BA NN T05	R U D	MON. INSTEAD OF QUARTERLY BATTERY P.T. PERFORMD WRONG P.T. SCHEDULED BY MISTAKE
G	C01	022101B	062778	BC NN B3304	N U D	1A 250V BTRY CHRGR INPUT BREAKER TRIPPED LOOSE CNNECTN AT CHRGR INPUT BRKR PHASE A
G	C01	037936	022881	BA ST T03	R U D	5G TESTS FOR 125V 1AEB AND 250V 1B NOT PERFORMED -- PROPERLY. PERSONNEL USED WRONG HYDRM
G	D01	030982	041780	BA NN T02	R U D	WKLY BATT SURV DOCUMENTATION NOT COMPLETED PERSONNEL ERROR--NONLIC. OPERATIONS PERS
G	R2	039116	102181	BA NN T01	R U D	QUARTERLY STORAGE BATTERY SURVEILLANCE DONE 3 DAY-- 5 LATE. OVERSIGHT BY OPERATING SHIF1
G	D03	025951	042479	BA NN B01	M U D	UNIT 2'S BATTERY NOT RETURNED TO NORMAL LINEUP BREAKER COULD HAVE BEEN SHUT AT ANY TIME
G	R3	036569	030381	BA NN T01	R U D	WEEKLY STORAGE BATTERY SURVEILLANCE DONE 4 DAYS L--ATE. OVERSIGHT BY OPERATING SHIF1
G	EN1	021475*	060478	BC ST H1304	M D	2 HEAT-SENSITIVE XSTR ON BATT CHRGR FIRING MODUL CRD SHOULD BE A NON-HEAT-SENSITIVE TRANSISTOR
G	EN1	021719	062778	BA DB T02	R U D	WKLY PILOT CELL SURV OF 1C D/G BTRY NOT COMPLT-- ED ON TIME. PERSONNEL OVERSIGHT
G	EN1	027782	112679	BA NN T03	R U D	CELL SURVEILLANCE REQUIREMENT NOT PERFORMED PERSONNEL OVERSIGHT
G	EN2	022208	081678	BA NN T02	R U D	WKLY PILOT CELL SURV OF PLANT BATT NOT COMPLETED-- ON TIME. NOTICES ROUTED TO ABSENT PERS
G	EN2	026657	071879	BA NN T03	R V D	CELL SURVEILLANCE REQUIREMENT NOT PERFORMED PERSONNEL OVERSIGHT

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS CAUSED BY HUMAN FACTORS

STATION	CONTROL NUMBER	EVENT DATE	SYMBOL	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G EN2	036943A	040781	BA ST A1602	2 ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF ST	-BTRYS 2R42-5001A&B. PERSONNEL ERROR
G EN2	036943B	040781	BA ST A1702	2 ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF ST	-BTRYS 2R42-5001A&B. PERSONNEL ERROR
G EN2	036943C	040781	BA DR A1602	ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF DIE	-SEL GENERATOR BATTERY. PERSONNEL ERROR
G EN2	036943D	040781	BA DR A1702	ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF DIE	-E1 GENERATOR BATTERY. PERSONNEL ERROR
G M11	014478	040776	BA SY T01	SWITCHYARD BTRY SURVEILLANCE NOT PERFORMED W/IN	REQ TIME PERIOD. PERSONNEL ERROR
G M01	166730A	061581	BA NN A3401	250 VDC BATTERY INADVERTENTLY DISCHARGED	PEPS DISCONNECTED TEMP BATTERY CHARGE
G M01	166730B	061581	BC NN R01	TEMPORARY BATTERY CHARGER TAKEN OUT OF SERVICE	PERSONNEL ERROR-CAUSED BTRY TO DISCHARGE
G DC1	021497A	052478	BA DB T01	D/G BTRY LOAD TESTING NOT PERFORMED IN TIME	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	021497B	052478	BA ST T01	STATION BTRY LOAD TESTING NOT PERFORMED IN TIME	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	023298A	121378	BA DB T01	D/G BTRY NOT TESTED/MONITORED W/IN TIME INTERVAL	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	023298B	121378	BA ST T01	STATION BTRY NOT TEST/MONITOR W/IN TIME INTERVAL	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G DC1	030599A	022880	BA ST T02	MAIN STATION BTRY SURV TEST NOT PERFORMED	PLANT PERS FAILED TO ADHERE TO SURV SCHEDULE
G DC1	030599B	022880	BA DB T02	DIESEL GENERATOR BTRY SURV TEST NOT PERFORMED	PLANT PERS FAILED TO ADHERE TO SURV SCHEDULE
G DC1	038737	091181	BA NN T02	BATTERY SURVEILLANCE PROCEDURES FOUND NOT TO FULL	-Y COMPLY WITH NEW REQUIREMENTS.
G DC2	018460	060977	BC MH E2101	BATTERY CHARGER SUPPLYING CURRENT TO BATTERY FOUR	-D LOW. FLOATING POTENTIOMETER SET LOW

APPENDIX I
ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS
SORTED BY ACTIVITY RESULTING IN DISCOVERY

SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
AM	- AREA MONITOR SYSTEM
DB	- EMERGENCY DIESEL GENERATOR
ES	- ENGINEERED SAFETY FEATURE
FP	- FIRE PROTECTION SYSTEM
FW	- FEEDWATER SYSTEM
NM	- NEUTRON MONITORING BATTERY
NN	- UNKNOWN/UNSPECIFIED/OTHER
SA	- AUTOMATIC (REACTOR) DEPRESSURIZATION (ADS)
SP	- SPECIAL USE BATTERIES
ST	- STATION BATTERIES/CHARGERS
SW	- SERVICE WATER BUILDING BATTERIES/CHARGERS
SY	- SWITCHYARD BATTERIES/CHARGERS
UP	- UNINTERRUPTIBLE POWER SYSTEM (UPS)

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY ACTIVITY RESULTING IN DISCOVERY

N S S	P L A N T	CONTROL NUMBER	EVENT DATE	C O M P	S Y S T E M	F A I L U R E	A C T I V I T Y	T Y P E	C L A S S	F A I L #	FAILURE MODE	FAILURE CAUSE
											DESCRIPTION	DESCRIPTION
C	CC1	021533	050378	BA	NN	A00	A	U			125 VDC BTRY 22 CELL 54 ICV BELOW MIN VOLTAGE	CAUSE UNKNOWN
C	CC1	037262	050681	BA	NN	M20	A	U			VOLT OF CELL 18 OF 125 VDC BATTERY 12 FOUND .08V -	-BELOW MINIMUM. FULL CAPACITY AVAILABLE
C	M12	026979	080379	SA	NN	M20	A	U			VARIOUS CELLS REPLACED IN 2018 BTRY (4 CELLS)	REDUCTION IN CELL VOLT. FULL CAPACITY
C	PA1	025917	040479	BA	ST	B2005	A	C	D		2 CELLS IN STATION BATTERY #2 BURST WHILE TAKING -	-VOLTAGE READINGS. FULL CAPACITY AVAIL
C	SL1	038775	091881	BC	NN	B24	A	R	U		1A BATTERY CHARGER SHUTDOWN ON HIGH VOLTAGE	HIGH VOLTAGE DEVICE FOUND DEFECTIVE
W	BV1	016357	102476	BA	NN	M00	A	U			VOLTAGE DECREASED IN CELL 48 BY MORE THAN 0.05V	UNKNOWN. CELL 48 FROM BTRY 3, 1650 A.H.
W	BV1	028147	092179	BA	NN	M2010	A	T			CELL #6 OF BATTERY NO. 1 COULD NOT HOLD ORIGINAL -	-VOLTAGE. FULL BATTERY CAPACITY AVAIL.
W	DC2	021633	060778	BA	NN	A14	A	U			CD PLANT BTRY CELL 89 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W	DC2	021632	061578	BA	NN	A14	A	U			AB PLANT BTRY CELL 35 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W	IP3	014709	051076	BC	NN	B2630	A	U			BTRY CHRGR TROUBLE ALARMED CHARGER FAN HAD TRPD	AC FAN MTR INOP EXPOSED WIRE BLEW A FLSE
W	IP3	015138	060876	BC	NN	B13	A	S	U		# 31 BTRY CHRGR AC BRKR TRIPD BATT CHRGR INOP	PRESSURE SENSOR FAILED TRIPPING BREAKER
W	JF1	032332A	081280	BA	SW	A14	A	R	U		SW BLDG B BTRY SYS LOW SPECIFIC GRAVITY	BATT PLACED ON EQUALIZE & S.G. ACCEPTABLE
W	JF1	032332B	082580	BA	SW	A14	A	R	U		SW BLDG B BTRY SYS LOW SPECIFIC GRAVITY	NO EXTERNAL CAUSE FOR LOW SPECIFIC GRAV
W	JF1	032687	091180	BA	SW	A1404	A	D			SW BLDG "AM" BATT SYS LO BATT CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN
W	JF1	033007	102180	BA	SW	A1404	A	D			SW "AM" BTRY SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN
W	JF1	033163	102880	BA	SW	A1404	A	D			SW BLDG "AM" BATT SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM PROX/ACID RES/POST SEAL DESIGN
W	HA1	171672	120181	BA	DB	A1410	A	T			1J EMERGENCY D/G INOP CELL S.G. BELOW 1.2	D/G BATTERY NEAR END OF USEFUL LIFE
W	PR1	033222	110580	BC	NN	A2911	A	U			#12 BTRY CHRGR FAILED TO PROVIDE NORMAL OUTPUT	FIPING CARD B NOT PROVIDING PULSE TO SCH
W	SU2	038936A	100181	BA	FP	B34	A	D			SMOKE DETECTOR BATTERY FAILED	CHARGER NOT CHARGING BATTERY
W	SU2	038936B	100181	BC	FP	B00	A	U			BATTERY CHARGER FOR SMOKE DETECTOR BATTERY FAILED	NO CAUSE GIVEN
W	TU3	039363	111281	BA	NN	B20	A	R	U		"3A" 125 VDC FAILED TO HOLD A CHARGE	BEING EVALUATED W/ MANUFACTURER
G	BP1	016073B	100376	BA	SA	A17	A	U			RDS D BTRY PILOT & 3 OTHER CELLS LO ELECTROLYTE -	-LEVEL. UNKNOWN CAUSE
G	BP1	016073A	100476	BA	SA	A1405	A	D			RDS D BTRY PILOT & 3 OTHER CELLS LO SPEC GRAVITY	INCOMPLETE ELECTROLYTE MIXING
G	BP1	017024*	010477	BA	SA	M14	A	R	U	2	B CELLS SPECIFIC GRAVITY FOUND BELOW 1.2. EVALUA-	-TION REVEALED ADEQUATE CAPACITY
G	BP1	038112	081581	BA	SA	A1602	A	C	D		FOUND PILOT CELL IN CH A RDS POWER SUPPLY WITH A -	-HIGH ELEC LEVEL. POSSIBLY OVERFILLED
G	DR3	016265A	101876	BA	NN	A34	A	D			BATTERY IN A DEGRADED CONDITION	CHARGER SUBJECTED BTRY TO "DEEP CYCLING"
G	DR3	016265B	101876	BC	NN	C00	A	U			CHARGER SUBJECTED BTRY TO "DEEP CYCLING"	UNKNOWN CAUSE
G	FP1	021433	053178	BA	FP	A1420	A	U			LO S.G. OF BTRY A2 CELL 1	BAD CELL IN BATTERY
G	FP1	031743*	062880	BA	FP	A14	A	T	2		DIESEL FIRE PUMP 24V BATT CELLS A2-6, B2-1 LOW S.G.	CHARGER UDS DURING SURVEILLANCE
G	MD1	166730A	061581	BA	NN	A340E	A	D			250 VDC BATTERY INADVERTENTLY DISCHARGED	PERS DISCONNECTED TEMP BATTERY CHARGER
G	MD1	166730B	061581	BC	NN	B01	A	U	D		TEMPORARY BATTERY CHARGER TAKEN OUT OF SERVICE	PERSONNEL ERROR, CAUSED BTRY TO DISCHARGE
B	DE3	022183	072778	BA	NN	B33	B	U			SMOKE FROM 1 TERMINAL OF I&C BATTERY 3CB	TERMINAL DEFCTV/CNNCTNS FOUND DEFECTIVE

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY ACTIVITY RESULTING IN DISCOVERY

UNION	PLANT	CONTROL NUMBER	EVENT DATE	COMP	SYSTEM	FAILURE ORDER	ACTIVITY TYPE	CLASS	FAILURE #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
B	T12	0230849	111278	BC	NN	B13	B	U	2	CHGRS 2-2A/B FUSE BLEW NO CHGR FOR BANK 2-258	DEFECTIVE GATING FILTER MODULES
M	BV1	022136	080478	BC	ST	B00	B	U		#4 STATION BTTRY CHGR OUTPUT BRKR TRIPPED	IMPROPR OP OF CKTBRK.CAUSE OF TRP UNKNOWN
M	PR2	014599	041476	BC	NN	B2133	B	U		#12 BATTERY CHARGER FAILED DISABLED "B" DC POWER	VOLTAGE CNTRL CRD LOOSE IN ITS SOCKET
G	BR1	019389	102177	BC	NN	B2206	B	U		BATT CHGR DC OUTPT FUSE FAILED WHEN CHRG BATT 2B-2	HI CURR/TEMP CAUSD SOLDERD LINKG SEPARATE
G	BR1	025637A	032579	BA	NN	A3308	B	R	T	BATTERY 1B2 VOLTAGE FELL TO 102.5V THEN ROSE TO -	-118V. CORRUDED AND LOOSE BTTRY CONNECT
G	BR1	025637B	032779	BA	NN	A3308	B	R	T	BTTRY 1B1 VOLTAGE FELL TO 96.8V THEN ROSE TO 118V	CORRUDED AND LOOSE BTTRY CONNECTORS
G	CD1	037646	050581	BC	ST	G29	B	U		HIGH RIPPLE FROM BATTERY CHARGER WHICH FAILED INV-	-ENTER IA. FAILED SCR
G	PR3	014211	012976	BA	NN	A14	B	U		B BTTRY CAPACITY BELOW DESIGN	CELL S.G. IN LO RNG, PARTIAL ACID REPLCD
G	BP1	015326A	072276	BA	SA	A17	C	U		RDS BATTERY D PILOT CELL LOW ELECTROLYTE LEVEL	EXACT CAUSE UNKNOWN
G	BP1	015326B	072276	BA	SA	A1432	C	D		RDS BATTERY D PILOT CELL HAD LOW SPECIFIC GRAVITY	ADDITION OF WATER POSSIBLE CAUSE
G	BP1	015327A	072876	BA	SA	A17	C	U		RDS BTTRY C PILOT CELL LOW ELECTROLYTE LEVEL	UNKNOWN CAUSE
G	BP1	015327B	072976	BA	SA	T14	C	U	D	RDS BTTRY C PILOT CELL RDG LO SPECIFIC GRAVITY	DECTV PROC SPECIFIC GRAVITY READ TOO SOON
G	BP1	016459	110476	BA	SA	A14	C	U		RDS B PILOT CELL LOW SPECIFIC GRAVITY	UNKNOWN CAUSE
G	BP1	017464	027477	BA	SA	M14	C	R	U	RDS BATTERY B HAD ONE CELL BELOW MINIMUM SPECIFIC-	-GRAVITY. ADEQUATE CAPACITY AVAILABLE
G	BP1	017463	031777	BA	SA	M14	C	R	U	SPECIFIC GRAVITY FOUND LOW IN 5 CELLS OF RDS BTTRY-	"A". ADEQUATE CAPACITY AVAILABLE
G	BP1	018096A	042177	BA	SA	M14	C	R	U	RDS BATTERY B, CELL 27 FOUND TO HAVE LOW SPECIFIC -	-GRAVITY OF 1.191. FULL CAPACITY AVAIL
G	BP1	018096B	042777	BA	SA	M14	C	U		SPECIFIC GRAVITY OF LO MARGINAL CELLS ADJUSTED OF-	-RDS BATTERY B. FULL CAPACITY AVAILABL
G	BP1	018462B	061677	BA	SA	T1432	C	V	D	SPECIFIC GRAVITY OF CELL 27 OF RDS BATTERY B LOW	WATER ADDED THEN TESTED TOO SOON
G	BP1	019472B	092977	BA	SA	A1432	C	R	D	SPECIFIC GRAVITY OF CELL 12 OF RDS BATTERY "A" LOW	WATER ADDED, CHARGE INSUFFICIENT TO MIX
G	BP1	019542B	102077	BA	SA	A1432	C	R	D	SPECIFIC GRAVITY OF 3 CELLS OF RDS BATTERY "D" LOW	WATER ADDED, MIXING WAS INADEQUATE
G	BP1	020176	122277	BA	SA	A14	C	R	U	SPECIFIC GRAVITY ON RDS BATTERY "A", CELL 12 LOW	EQUALIZING CHARGE FOR 8 HOURS CORRECTED
G	BP1	022664	083178	BA	SA	A14	C	R	U	RDS BATTERY A, CELL 12 LO SPECIFIC GRAVITY READING	EXACT CAUSE UNKNOWN
G	BP1	027985	110179	BA	SA	A1420	C	U		SPECIFIC GRAVITY OF CELL 48 OF RDS BATTERY C LOW	CELL REPLACED, WOULD NOT TAKE EQUAL CHARGE
G	BP1	030237	012480	BA	SA	A1420	C	U		RDS C BTTRY CELL 14 LOW SPECIFIC GRAVITY RDG	DEFECTIVE CELL REPLACED
G	BP1	031176	050180	BA	SA	A1420	C	U		RDS BTTRY "A" CELL 2 LOW SPECIFIC GRAVITY RDG	CELL DID NOT RESPOND ADQ TO EQUALIZG CHRG
G	BP1	031848	071080	BA	SA	A1420	C	U		RDS C BTTRY CELLS 35, 54 LOW SPECIFIC GRAVITY RDG	CELL DID NOT RESPOND ADQ TO EQUALIZG CHRG
G	BP1	032297	080780	BA	SA	A14	C	U		RDS C BTTRY CELLS 39, 39, 56 LOW SPECIFIC GRAVITY	VENDOR RECOM INCRS IN FLOAT VOLTAGE LEVEL
G	BP1	032656	091180	BA	SA	A1420	C	U		RDS D BATTERY CELL 12 LOW SPECIFIC GRAVITY RDG	CELL DID NOT ADQ RESPOND TO EQUALIZG CHRG
G	BP1	033544	121180	BA	SA	A1402	C	D		21 CELLS OF RDS "A" BATTERY LOW SPECIFIC GRAVITY	CELL TERMINALS INADQ CLEANED BY MAINT PER
G	BP1	037338	010281	BA	SA	A1420	C	R	U	RDS CH D BATTERY CELL 56 HAD LOW SG, WOULD NOT RES-	-POND TO EQUALIZING CHARGE.
G	BP1	038592	083181	BA	ST	A2014	C	C	D	LOW SG IN CELL 43 OF ST BTTRY, CELL FOUND CRACKED.-	-THIS LEAD TO DILUTION, CRACKED WHEN MEVED
G	BP1	039785	091581	BA	SA	A1420	C	U		"A" RDS BTTRY CELL #5 LOW SPECIFIC GRAVITY	CELL DIDN'T RESPOND ADQ TO EQUALIZG CHRG

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY ACTIVITY RESULTING IN DISCOVERY

PLANT	CONTROL NUMBER	EVENT DATE	COMP	SYSTEM	FAILURE CODE	ACTIVITY TYPE	CLASS	FAILURE #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
B DB1	025397	020879	BA FP	A17	D	U			ELECTROLYTE LEVEL IN 4 CELLS FOUND LOW IN DSL ENG STA-	-RTING BTRY. DIESEL STILL STARTED
G BP1	016305A	102176	BA SA	A14	D	U			RDS "A" BTRY PILOT CELL 55 LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G BP1	016305B	112176	BA SA	A14	D	U			RDS "A" BTRY PILOT CELL 55 LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G BP1	016584	120276	BA SA	A14	D	U			RDS B BTRY PILOT CELL 27 LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G BP1	017023	120976	BA SA	A14	D	U			RDS B ONE CELL LOW SPECIFIC GRAVITY	UNKNOWN CAUSE VENDOR INVESTIGATING
G BP1	021307	050478	BA FP	A17	D	U			FIRE PUMP DIESEL STARTG BTRY "A" CELLS 1,3,5 LOW	ELECTROLYTE SOLN. EXACT CAUSE UNKNOWN
G BP1	021519	052578	BA FP	A1705	D	D			FIRE PUMP DIESEL STARTG BTRY "A" CELLS 2,4,6 LOW	ELECTROLYTE SOLN. INADQ MAINTENANCE FROM
G BP1	032023	071880	BA SA	A20	D	U			RDS C BTRY PILOT CELL UNIT-9 INTERNAL RESISTANCE	-INCRS. CAUSE UNKNOWN
B DB1	020448	011978	BA ST	A1415	E	U			1H BTRY CELL 32 ELECTROLYTE S.G. DECRS .003 DOT	ELEC. STRAT. DUE TO LOW BTRY LOADING
M BV1	039154	101781	BA NN	M20	E	R	U		2 OF 60 CELLS VOLTAGE FOUND DROPPED BY .05 VDC	NO CAUSE GIVEN, BATTERY HAD FULL CAPACITY
M JF1	021235A	041878	BA SW	B00	E	U			2 CELLS IN SW BLDG "A" BATT BANK 1 FAILED T.S. REQ	CAUSE COULD NOT BE DETERMINED
M JF1	021235B	041878	BA SW	B00	E	U			2 CELLS IN SW BLDG B BATT BANK 2 FAILED T.S. REQ	CAUSE COULD NOT BE DETERMINED
M NA2	036466*	021881	BA DB	M14	E	U			2 BATTERIES FOR 2J & 2H DIESEL GENERATORS FAILED SUR-	-VEILLANCE TEST. 4 CELLS REPLACED
M YR1	019861	120577	BA ST	A20	E	U			CELL VOLTAGE ON CELL 18 OF BANK 1 FOUND LOW	NO CAUSE FOUND, CELL REPLACED
G DR3	020853	032878	BA NN	A10	F	K	T		24/48 V BTRY FAILED THE REFUELING OUTAGE DISCHRG-	-TEST. 4 CELLS REPLCD NAT'L END OF LIFE
G EN2	030651*	032580	BC ST	A2122	G	U			2 EMER STATION BATT CHRGR 2G, 2J FAILED TO HOLD LOAD	VOLTG CNTRL & CURR LMT MODULES TUNED
G EN2	030711A	032780	BC ST	A29	G	U			2 STATION BATT CHRGR 2A, 2B FAILED TO MAINTAIN LOADS	SILICON CNTRL RECTIFIERS NEED LOAD BALANC
G EN2	030711B	032780	BC ST	A22	G	U			STATION BATT CHRGR 2C FAILED TO MAINTAIN LOAD	CURRENT LIMIT MODULE NEEDED ADJUSTMENT
M MG1	039186	101981	BA ST	A3308	M	T			CELL TO CELL RESISTANCE IN 3 CELLS FOUND HIGH	CORROSION OF TERMINAL CONNECTIONS
M RO2	015515	071076	BA NN	B02	M	D			BATTERY B LEADS WERE REMOVED RENDERING BATT INOP	PERS FAILED TO COMPLY W/ T.S. 3.7
M Z11	171128A	121281	BA NN	B01	M	U	D		UNIT 2 212 BATTERY TAKEN OOS ERRONEOUSLY	LICENSED OPERATOR ERROR
M Z11	171128B	121281	BC NN	B01	M	U	D		UNIT 2 212 CHARGER TAKEN OOS ERRONEOUSLY	LICENSED OPERATOR ERROR
G BF2	015394	070976	BA NN	B1302	M	U	D		NEUTRON MONITORING BATTERY 2A MADE INOPERABLE	CHNCTR BROKEN OFF A CELL POST PERS ERROR
G EN1	021475*	060478	BC ST	M1304	M	D		2	HEAT-SENSITIVE XSTR ON BATT CHRGR FIRING MODULE CRD	SHOULD BE A NON-HEAT-SENSITIVE TRANSISTOR
G EN2	033891	081180	BA ST	B30	M	U			DC BATT GROUND ON 2B STATION SERVICE BATTERY	NO CAUSE GIVEN
B CR3	038100	071481	BA ST	B3002	N	C	D		STATION BATTERY SHORTED DURING MAINTENANCE	PERSONNEL ERROR, CAUSED REACTOR TRIP
B DB1	021587	042778	BA FP	A17	N	U			4 CELLS OF ENGINE BTRY W/ ELECTROLYTE BELOW PLATE	ELEC. ADDED BROUGHT CELLS UP TO NORMAL
C AR2	026904	080979	BC NN	B1306	H	C	D		BATTERY CHARGER 2D31 FAILED. DC OUTPUT LAMP SOCK-	-ET BURNED UP DUE TO HIGH HEAT, VOLT, DLST
C AR2	027808	121179	BC NN	H21	N	S	D		BATTERY CHARGER 2D32 AC BREAKER TRIPPED	CURRENT SURGED WHEN SHIFTING TO FLOAT
C AR2	039245*	110581	BC NN	B00	N	U		2	OUTPUT BREAKER OF BATTERY CHARGER 2D34 TRIPPED OP-	-FN TWICE. NO CAUSE COULD BE FOUND
C CC2	017344	021777	BA NN	R01	N	S	D		#11 125 VDC BATTERY INADVERTENTLY TAKEN OUT OF SE-	-RVICE. SUPERVISOR GAVE PERMISSION
C PA1	016178	102076	BC NN	E2201	N	D			DC BUS-2 VOLTG FELL, VOLTG ON ASSOC AC BUSES FELL	CURR LMT & OUTPUT BRKR SETTING ERRONEOUS

125

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY ACTIVITY RESULTING IN DISCOVERY

PLANT	CONTROL NUMBER	EVENT DATE	COMP	SYSTEM	FAILURE CODE	ACTIVITY TYPE	CLASS #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
C SL1	020069	121677	BC	NN	B00	N	D	OUTPUT LOST FROM "AB" BATTERY CHARGER	POWER SUPPLY BKR TRIPPED FOR NO REASON
M BV1	021043	032078	BC	NN	E2713	N	U	DECR #4 DC BUS VOLTAGE DUE TO A FAULTY BTRY CHRGR	FAILD COLLECTR RESISTR IN CHRGR CNTRL CKT
M BV1	037757	061581	BC	NN	B2506	N	R D	#2 BATTERY CHARGER OUTPUT BREAKER FAILED OPEN	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
M BV1	038347	080581	BC	NN	B2506	N	R D	#2 BATTERY CHARGER OUTPUT BREAKER TRIPPED OPEN	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
M BV1	038825	091081	BC	ST	B33	N	U	#4 STATION BATTERY CHARGER TAKEN OUT OF SERVICE	BAD ELECTRICAL CONNECTION IN OUTPUT
M DC1	025643	032379	BC	NN	D01	N	U D	125 VDC EQUALIZING CHARGE TOO HIGH, FAILED INVERT-	-EP, CAUSED SCRAM AND SI. NO CAUSE
M HN1	014608A	042576	BC	NN	D2833	N	U	BTRY CHARGER A WENT INTO OVERCHARGE	FAULTY CNTCT ON CHARGER CONTROL TIMER
M HN1	014608B	042576	BC	NN	D2122	N	U	VOLTG REG SPIKING TO 200 AMPS THEN SHUTTING OFF	FAULTY PHASING CRD IN CURRENT LIMITER CKT
M IP3	036207	012481	BC	NN	B2123	N	U	OUTPUT FROM CHARGER #32 DISCOVERED DROPPING	VOLTAGE AND CURRENT CONTROLLER REPLACED
M IP3	038257	070681	BC	NN	B13	N	S U	BATTERY CHARGER #32 DISCOVERED TRIPPED	FAILED OP AIR FLOW SENSOR SWITCH
M JF1	032504	082580	BC	SW	B24	N	S U	SW B DC DISTRIBUTION SYS INOP NO OUTPUT FROM BATT-	-CHRGR 4. HV S/D RELAY ACTUATED
M RQ2	021898	071678	BA	ST	B311	N	D	PLASTIC TOP OF 2 STATN "A" BATT CELLS ON FIRE	RESISTNC HEATG OF STRAP-CELL TERMINAL
M SA1	020738A	020178	BA	NN	A34	N	U	1C 125V BATTERY VOLTAGE LOW	1C1,1C2 BATT CHARGER D.C. BRKRS TRPD
M SA1	020738B	020178	BC	NN	B00	N	U	2 1C1,1C2 BATT CHARGER D.C. BRKRS TRIPPED	UNKNOWN CAUSE
M SA1	038834	091881	BA	FP	B33	N	U	BATTERY CABLE CLAMP FOUND ARCING AND CRACKED	CLAMP WAS REPLACED ON #2 FIRE PUMP BTRY
M SA2	038319	072481	BC	NN	B2101	N	U D	2C1 BATTERY CHARGER DISCOVERED TRIPPED. VOLTAGE -	-SETTING WAS INCORRECTLY SET
M SA2	038327	081281	BC	NN	B24	N	U	2B1 BATTERY CHARGER WOULD NOT PICK UP 28 VDC LOAD	HIGH VOLTAGE CUT-OUT ACTUATED
M SA2	038683	090681	BA	AM	B00	N	U	RAD MONITOR 2R12A BATTERY PACK FAILED	NO CAUSE GIVEN
M SF1	032338	080780	BA	DB	B30	N	U	D/G BTRY 1B-B CELL 51 SHORTED AND FAILED	NO CAUSE GIVEN
M SU2	169141	081981	BC	FP	B13	N	U	SMOKE DET SYS INOP BTRY CHRGR LOST POWER	FAULTY POWER SUPPLY CARD IN CHARGER
M TR1	032622	090380	BA	FW	B20	N	U	DIESEL-DRIVEN AFWP FAILED TO START FROM MANUAL SIG	FAILED STARTING BATTERY
M TU3	033530A	121180	BC	NN	C00	N	U	PROBLEMS WITH 4B 125 VDC BATTERY CHARGER	NO CAUSE GIVEN
M TU3	033530B	121180	BA	NN	T34	N	U T	4B 125 VDC BATT 00S,TECH SPEC EXCEEDED	PROBLEM W/ ASSOCIATED BTRY CHARGER
M YR1	019476A	101477	BC	NN	R1210	N	R T	NO. 2 BATTERY CHARGER TAKEN OUT OF SERVICE	FAILED BEARING
M YR1	019476B	101477	BC	NN	T01	N	U D	NO. 1 BATTERY CHARGER CROSS TIED TO NO. 2 BATTERY	OVERSIGHT CAUSE LCU STATED IN TECH SPEC
M YR1	019640	110577	BC	NN	B1210	N	R T	NO. 1 BATTERY CHARGER TAKEN OUT OF SERVICE	FAILED BEARING DUE TO NORMAL WEAR
G BF2	025671	041979	BA	SP	B3302	N	C D	BROKEN TERMINAL DISCOVERED ON S/D BOARD "D" BTRY	PERSONNEL ERROR. ALSO AFFECTED UNIT J
G BP1	015248A	063076	BC	ST	B29	N	U	STATION BATTERY CHARGER FAILED	DEFECTIVE SILICON RECTIFIERS
G BP1	015248B	063076	BA	ST	A18	N	D	LOAD ON BTRY REDUCED VOLTAGE & SPECIFIC GRAVITY	STATION BATTERY CHARGER HAD FAILED
G BP1	015444	081276	BA	DB	B33	N	T	EMERGENCY DIESEL GENERATOR DID NOT START DUE TO L-	-NOSE BATTERY CONNECTION.
G BP1	017704*	033077	BA	UP	B3304	N	C D	4 NO OUTPUT FROM ALL UPS BATTERY BANKS	CONNECTORS NOT TIGHTENED DURING INSTAL
G BP1	019025A	082977	BA	FP	B3302	N	D	DIESEL FIRE PUMP "A" BATTERY FOUND WITH NO OUTPUT	CONNECTORS NOT TIGHTENED

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY ACTIVITY RESULTING IN DISCOVERY

N S S	P L A N T	CONTRL NUMBER	EVENT DATE	C O M P	S Y S T E M	F A I L U R E R E F	A C T I V I T Y	T Y P E	F A I L C L A S S	F A I L M O D E	FAILURE MODE	FAILURE CAUSE
											DESCRIPTION	DESCRIPTION
G	BP1	0190258	082977	BA	FP	800	N	U			DIESEL FIRE PUMP "B" BATTERY FOUND FAILED WITH NO-OUTPUT. DISCHR WITH NO APPARENT CAUSE	
G	CD1	022101A	062778	BC	NN	82333	N	T			1A 250V BTRY CHRGR TIE BREAKER TRIPPED	POOR CNNECT CNCTS IN CURRENT MODULE
G	CD1	022101B	062778	BC	NN	83304	N	U	D		1A 250V BTRY CHRGR INPUT BREAKER TRIPPED	LOOSE CNNECTN AT CHRGR INPUT BRKR PHASE A
G	DA1	171665	120881	BC	NN	800	N	U			BATTERY CHARGER OUTPUT INCORRECT	UNKNOWN
G	DR1	018553A	072977	BA	FP	83413	N	C	D	2	DIESEL FIRE PUMP BATTERIES FAILED TO START DIESEL	FAILED FUSE FROM BATTERY CHARGER CIRCUIT
G	DR1	018553B	072977	BC	FP	822	N	U			FUSE FOUND BLOWN IN DIESEL FIRE PUMP BATTERY CHARGER.	
G	DR3	025951	042479	BA	NM	801	N	U	D		UNIT 2'S BATTERY NOT RETURNED TO NORMAL LINEUP	BREAKER COULD HAVE BEEN SHUT AT ANY TIME
G	EN2	032981A	032381	BA	AM	81834	N	D			POST TREATMENT MON 2011-K615A BATTERY DRAINED	BATTERY CHARGER 2AB 24/48 VDC FAILED
G	EN2	032981B	032381	BC	NN	800	N	U			24/48 VDC BATTERY CHARGER FOUND NOT CHARGING	NO CAUSE GIVEN
G	EN2	036943A	040781	BA	ST	A1602	N	C	D	2	ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF ST -	-BTRYS 2R42-5001A6B. PERSONNEL ERROR
G	EN2	036943B	040781	BA	ST	A1702	N	C	D	2	ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF ST B-	-TRYS 2R42-5001A6B. PERSONNEL ERROR
G	EN2	036943C	040781	BA	DB	A1602	N	C	D		ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF DIE-	-SEL GENERATOR BATTERY. PERSONNEL ERFOR
G	EN2	036943D	040781	BA	DB	A1702	N	C	D		ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF DIES-	-EL GENERATOR BATTERY. PERSONNEL ERRIE
G	FP1	026922	090479	BA	ST	A20	N	U			LEAKING CELL NOTED IN BATTERY "B". BATTERY TEMPOR-	-ARILY INOP WHILE CELL JUMPERED
G	FP1	033280	111780	BA	ST	A10	N	T			STATION BTRY B MADE INOP TO JUMP A CELL	CELL #8 POOR PERFORMANCE DUE TO AGE
G	FP1	171811	123081	BA	NM	818	N	D	2		LOW VOLTAGE FROM DIVISION I 24 VDC BATTERIES, CAUS	-ED EPRATIC READINGS ON LRM & SPM INST
G	DC1	021497A	052478	BA	DB	101	N	U	D		D/G BTRY LOAD TESTING NOT PERFORMED IN TIME	FATLD TO ADHERE TO SURVEILLANCE SCHEDULE
G	DC1	021497B	052478	BA	ST	101	N	U	D		STATION BTRY LOAD TESTING NOT PERFORMED IN TIME	FATLD TO ADHERE TO SURVEILLANCE SCHEDULE
G	PI1	027950B	122479	BC	SY	800	N	R	U		SWITCHYARD 125 VDC BACKUP BATTERY CHARGER FAILED	NO CAUSE GIVEN
G	PI1	033899	082180	BC	NN	82113	N	U			"A" 125 VDC CONTROL BATT CHARGER INOPERABLE	VOLTAGE REGULATOR ELECTRONIC MODULES FPLC
G	QC2	018460	060977	BC	NN	E2101	N	U	D		BATTERY CHARGER SUPPLYING CURRENT TO BATTERY FOUN-	-D LOW. FLOATING POTENTIOMETER SET LEM
G	VY1	016217A	101376	BA	UP	A34	N	R	U		UPS-1B CNTRL PWR BTRY VOLTAGE WAS LOW	CNTRL BATT CHRNGG POWER SUPPLY FAILED
G	VY1	016217B	101376	BC	UP	B21	N	R	U		CNTRL BTRY CHARGING POWER SUPPLY FAILED	INOPERATIVE VOLTAGE REGULATOR CIRCUIT
G	VY1	018407A	031877	BA	UP	A3413	N	R	D		UPS-1B ALARMED DUE TO LOW VOLTAGE, CAUSED SCRAM	CAPACITOR FAILED IN CHARGING POWER SUPPLY
G	VY1	018407B	031877	BC	UP	B13	N	T			UPS-1B CONTROL CHARGING POWER SUPPLY FAILED	FAILED CAPACITOR IN ON/OFF CIRCUITRY
G	VY1	021749	061978	BC	NN	806	N	S	D		AC INPUT BRKR TO CAL BATT CHRGR TRPO OPEN	SPURIOUS TRP OF AC BRKR IN AN ELEC STERN
G	VY1	025519	031779	BC	UP	800	N	U			CONTROL CHARGING POWER SUPPLY FAILED	NO CAUSE GIVEN. CAUSED BATTERIES DISCHR
B	CR3	017166A	011277	BA	NN	103	R	U	D		INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B	CR3	017166B	020277	BA	NN	103	R	U	D		INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B	CR3	017166C	020477	BA	NN	103	R	U	D		INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B	CR3	021165	040578	BA	NN	102	R	V	D		WRONG BTRY CELLS MONITORED FOR WEEKLY BATT SURV	PERSONNEL NOT FOLLOWING PROCEDURES
B	DB1	022362	090578	BA	ST	102	R	U	D		STATION BATTERIES WKLY SURV TEST NOT DONE ON TIME	MISUNDERSTANDING BTWN PERSONNEL

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY ACTIVITY RESULTING IN DISCOVERY

NO	TYPE	CONTROL NUMBER	EVENT DATE	COMPL	STATUS	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
B	DE3	015932	081876	BA NN 105	R U D	125-VDC INSTR & CNTRL BATTERIES NOT LOAD TESTED	DFTV PROCY WRONG DATA IN SURV PRINTOUT
C	AR2	026489	052279	BA ST 103	R U D	SURVEILLANCE NOT PERFORMED ON STATION BATTERIES	PERSONNEL OVERSIGHT
C	SL1	037962	062481	BC NN 102	R U D	SURVEILLANCE REQUIREMENTS NOT MET ON #AB# BATTERY-	--CHARGER, MISINTERPRETATION O. TECH SPEC
M	BV1	017119A	020477	BA ST 103	R U D	SURVEILLANCE TEST NOT PERFORMED ON #3 & #4 STATIO-	--N BATTERIES, PERSONNEL ERROR
M	BV1	017119B	020477	BC ST 103	R U D	SURVEILLANCE TEST NOT PERFORMED ON CHARGERS ASSOC-	--TATED WITH #3 & #4 STATION BTRY, PERSON
M	DC2	039127	101981	BA NN 105	R U D	SURVEILLANCE NOT PERFORMED ON #M# TRAIN BATTERY	PROCEDURE LACKED SIGNOFF
M	JF1	027181	090679	BA NN 103	R U D	QUARTERLY AUXILIARY BUILDING BATTERY VERIFICATION-	--NOT PERFORMED ON TIME, PERSONNEL
M	NA1	026905	062879	BA DB 105	R U D	7 DAY SURVEILLANCE OF EMERGENCY DIESEL GENERATOR -	--BATTERIES EXCEEDED INTERVAL, PROCEDURAL
M	NA1	026656	073179	BA DB 105	R U D	DIESEL GENERATOR BATTERIES SURVEILLANCE NOT DONE	TIME LAG IN IMPLEMENTING NEW PROCEDURES
M	NA1	036491A	022891	BA ST 102	R U D	18 MONTH SURVEILLANCE ON D-C. DISTRIBUTION SERVIC-	--E SYSTEM NOT DONE, PERSONNEL OVERSIGHT
M	NA1	036491B	022891	BC ST 102	R U D	18 MONTH SURVEILLANCE ON D-C. DISTRIBUTION SERVIC-	--B SYSTEM NOT DONE, PERSONNEL OVERSIGHT
M	NA2	036417	022081	BA DB 105	R U D	DATA FROM TWO TESTS ON 2J DIESEL BATTERY FOUND NO-	--T USABLE, NOT COMPARED WITH INITIAL CON
M	PR1	026268	053179	BA FP 105	R U D	DIESEL DRIVEN WEEKLY BATTERY INSPECTION NOT DONE	PROCEDURES WERE DEFECTIVE
M	PR1	030917	033180	BA ST 102	R U D	INDIVIDUAL FLOAT CELL VOLT MEAS NOT DONE IN STATI-	--ON BATTERY TEST, PERSONNEL OVERSIGHT
M	SAL	032162	072180	BA FP 102	R U D	92 DAY & 18 MON SURV NOT DONE ON 24 V STARTG BATT	ELECTRICIAN NOT COMPLETING JOB
M	TR1	014563	032476	BA ES 105	R U D	ESF DC PWR SUPPLIES SURV REQ PERFORMED AT WRNG FREQ	PROCEDURE DID NOT USE FREQ REQ BY T.S.
M	TR1	020885	031778	BA NN 102	R U D	125 VDC ELECTRICAL SYS OP NOT VERIFIED WK OF 2-26	MAINT PERS FAILED TO INSURE SURV COMPLETED
M	TR1	025211A	011979	BA NN 103	R U D	125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL
M	TR1	025211B	011979	RC NN 103	R U D	125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL
G	RPI	031637	122380	BA NN 102	R U D	DC BATTERY MONTHLY TESTS OVERDUE	INADQ ADMIN CONTROLS & PERSONNEL ERROR
G	BR2	014651	021276	BA NN 105	R U D	MONTHLY INSTEAD OF QUARTERLY BATTERY P.T. PERFORMD	WRONG P.T. SCHEDULED BY MISTAKE
G	CO1	037938	052881	BA ST 103	R U D	SG TESTS FOR 125V 1A&B AND 250V 1B NOT PERFORMED -	--PROPERLY, PERSONNEL USED WRONG HYDRFCM
G	DA1	030982	041780	BA NN 102	R U D	WKLY BATT SURV DOCUMENTATION NOT COMPLETED	PERSONNEL ERROR-NONLIC. OPERATIONS PERS
G	DR2	039116	102181	BA NN 101	R U D	QUARTERLY STORAGE BATTERY SURVEILLANCE DONE 3 DAY-	--S LATE, OVERSIGHT BY OPERATING SHIFT
G	DR3	036569	030381	BA NN 101	R U D	WEEKLY STORAGE BATTERY SURVEILLANCE DONE 4 DAYS L-	--ATE, OVERSIGHT BY OPERATING SHIFT
G	EN1	021719	062778	BA DB 102	R U D	WKLY PILOT CELL SURV OF 1C D/G BTRY NOT COMPLET--	--ED ON TIME, PERSONNEL OVERSIGHT
G	EN1	027782	112679	BA NN 103	R U D	CELL SURVEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT
G	EN2	022208	081678	BA NN 102	R U D	WKLY PILOT CELL SURV OF PLANT BATT NOT COMPLETED--	ON TIME, NOTICES ROUTED TO ABSENT PERS
G	EN2	026657	071879	BA NN 103	R U D	CELL SURVEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT
G	M11	014478	040776	BA SY 101	R U D	SWITCHARD BTRY SURVEILLANCE NOT PERFORMED W/IN--	REQ TIME PERIOD, PERSONNEL ERROR
G	OCL	023298A	121378	BA DB 101	R U D	D/G BTRY NOT TESTED/MONITORED W/IN TIME INTERVAL	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE
G	OCL	023298B	121378	BA ST 101	R U D	STATION BTRY NOT TEST/MONITOR W/IN TIME INTERVAL	FAILED TO ADHERE TO SURVEILLANCE SCHEDULE

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS SORTED BY ACTIVITY RESULTING IN DISCOVERY

PLANT	CONTROL NUMBER	EVENT DATE	SYSTEM	STATUS	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G DC1	030599A	022880	BA ST 102	R U D	MAIN STATION BTRY SURV TEST NOT PERFORMED	PLANT PERS FAILED TO ADHERE TO SURV SCHEDULE
G DC1	030599B	022880	BA DB 102	R U D	DIESEL GENERATOR BTRY SURV TEST NOT PERFORMED	PLANT PERS FAILED TO ADHERE TO SURV SCHEDULE
G DC1	038737	091161	BA NN 102	R U D	BATTERY SURVEILLANCE PROCEDURES FOUND NOT TO FULLY COMPLY WITH NEW REQUIREMENTS.	
C PA1	036600*	010681	RA ST 802	U U D	2 OUTPUT BREAKER FOR BOTH STATION BATTERIES WERE OPENED FOR 1 HOUR. PERSONNEL ERROR	
W SE1	032342A	081280	BA DB 805	U D	D/G BTRY 1B-B CELLS 49,50,51 DISCHARGED	INADEQUATE PROCEDURE
W SE1	032342B	081380	BA DB 805	U D	D/G BTRY 1B-B CELLS 49,50,51 DISCHARGED	INADEQUATE PROCEDURE
W SU2	038470	090681	BA FP 800	U U	SOME DETECTOR BATTERY FOUND NOT TO TAKE A CHARGE	NO CAUSE GIVEN
W TU3	022061A	122277	BA ST 101	U U D	EQUALIZING CHARGES ON STATION BATTERIES NOT PERFORMED	--RMED. PERSONNEL ERROR, FULL CAPACITY AVAILABLE
W TU3	022061B	122977	BA ST 101	U U D	EQUALIZING CHARGES ON STATION BATTERIES NOT PERFORMED	--RMED. PERSONNEL ERROR, FULL CAPACITY AVAILABLE
W Z11	172130	121581	BA NN C05	U U D	EQUALIZING CHARGE NOT PLACED ON BATTERY 112	PROCEDURE NOT CLEAR ON COMMUNICATIONS
G 8F1	038085	072281	BA NN A20	U U	250 VOLT MAIN BATTERY TAKEN ODS TO BYPASS A CRACK	--ED CELL.
G 8P1	018462A	061677	BA SA A17	U R U	WATER ADDED TO CELL 27 OF RDS BATTERY "B"	NO CAUSE GIVEN FOR LOW WATER LEVEL
G 8P1	019472A	092977	BA SA A17	U R U	WATER ADDED TO CELL 12 OF RDS BATTERY "A"	NO CAUSE GIVEN FOR LOW WATER LEVEL
G 8P1	019442A	100877	BA SA A17	U R U	WATER ADDED TO 3 CELLS OF RDS BATTERY "D"	NO CAUSE GIVEN FOR LOW WATER LEVEL
G 8P1	019457	102077	BA ST A20	U U	STATION BATTERY "B" FOUND TO HAVE CRACKED CELL	NO CAUSE KNOWN FOR CRACKED CELL #228
G DC1	018293A	062877	BA SY B34	U C D	ONE OF TWO SWITCHING STATION BATTERIES FOUND ODS	--FOR 11 DAYS. BATTERY CHARGER FAILED
G DC1	018293B	062877	BC SY B2713	U U	BATTERY CHARGER FOR SWITCHING STATION BATTERY FOUR	--NO ODS AFTER 11 DAYS
G P11	027950A	122379	BC SY H00	U R U	SWITCHYARD 125 VDC BATTERY CHARGER FAILED	NO CAUSE GIVEN
G DC1	019222	092477	BA NN P2010	U T	BATTERY SYSTEM TAKEN OUT OF SERVICE	REPLACED 12 WEAK CELLS, NORMAL END OF LIFE
G QC2	018164	031777	BC NN C23	U U	UNITS BATTERY CHARGER APPARENTLY INOPERABLE	FAULTY INDUCTIVE CURRENT CONTROL CIRCUIT

APPENDIX J
ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS
FOUND IN NUREG-0666

CODES USED IN LER ONE-LINE DESCRIPTIONS

NSSS VENDOR
 CODE DESCRIPTION
 B - BABCOCK & WILCOX
 C - COMBUSTION ENGINEERING
 M - WESTINGHOUSE
 G - GENERAL ELECTRIC

EVENT CLASSIFICATION

CODE DESCRIPTION
 D - FREQUENCY
 T - AGE
 U - UNKNOWN

COMPONENT

CODE DESCRIPTION
 BA - BATTERY
 BC - BATTERY CHARGER

FAILURE CAUSE
 CODE DESCRIPTION
 00 - UNKNOWN
 01 - PERSONNEL OPERATION
 02 - PERSONNEL MAINTENANCE
 03 - PERSONNEL TESTING
 04 - DESIGN/FABRICATION/CONSTRUCTION/QUALITY CONTROL
 05 - DEFECTIVE PROCEDURES
 06 - EXTREME ENVIRONMENT
 08 - CORROSION
 10 - NORMAL WEAR/NATURAL END OF LIFE
 11 - ELECTRICAL MALFUNCTION
 12 - MECHANICAL MALFUNCTION
 13 - PIECE PART FAILURE
 14 - LOW SPECIFIC GRAVITY
 15 - STRATIFICATION
 16 - HIGH ELECTROLYTE SOLUTION LEVEL
 17 - LOW ELECTROLYTE SOLUTION LEVEL
 18 - INSUFFICIENT CHARGE
 19 - DEFECTIVE/WEAK CELLS
 20 - VOLTAGE REGULATOR MALFUNCTION
 21 - CURRENT LIMITER MALFUNCTION
 22 - CURRENT CONTROLLER MALFUNCTION
 23 - VOLTAGE LIMITER MALFUNCTION
 24 - THERMAL OVERLOAD PROTECTION
 25 - COOLING FAN/VENTILATION MALFUNCTION
 26 - CHARGE CONTROL MALFUNCTION
 27 - CHARGE CONTROL TIMER MALFUNCTION
 28 - RECTIFIER PROBLEM
 29 - SHORT CIRCUIT
 30 - ELECTROLYTE DILUTION
 31 - FAULTY CABLE/CONNECTORS
 32 - CHARGER MALFUNCTION

FAILURE MODE

CODE DESCRIPTION
 A - REDUCED CAPABILITY
 B - NO OUTPUT
 C - UNKNOWN/UNSPECIFIED/OTHER
 D - HIGH CURRENT/VOLTAGE OUTPUT
 E - LOW OUTPUT VOLTAGE
 F - HIGH AC RIPPLE ON DC OUTPUT
 M - MAINTENANCE REPLACEMENT
 T - TEST NOT PERFORMED

TYPE EVENT
 CODE DESCRIPTION
 B - RECURRING COMMON CAUSE
 C - COMMON CAUSE
 R - RECURRING
 S - COMMAND FAULT
 T - RECURRING COMMAND FAULT
 Y - COMMON CAUSE COMMAND FAULT
 V - RECURRING COMMON CAUSE COMMAND FAULT
 BLANK - RANDOM

ACTIVITY RESULTING IN DISCOVERY

CODE DESCRIPTION
 A - TESTING(UNSPECIFIED)
 B - NORMAL LOAD TESTING
 C - MONTHLY TESTING
 D - WEEKLY TESTING
 E - QUARTERLY TESTING
 F - REFUELING TESTING
 G - 18 MONTH TESTING
 H - 3 YEAR TESTING
 M - MAINTENANCE
 N - NORMAL PLANT OPERATION
 R - RECORDS REVIEW
 U - UNKNOWN

FLAGGING FIELD

CODE DESCRIPTION
 A - FAILED COMPONENT CAUSED AN ACCIDENT
 B - COMPONENT FAILED TO MITIGATE AN ACCIDENT
 C - SAFETY SIGNIFICANT
 D - FAIL # NOT KNOWN
 E - CELL # NOT KNOWN
 F - FAIL # AND CELL # NOT KNOWN
 N - FROM NSIC DATA BASE

SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
AM	- AREA MONITOR SYSTEM
DB	- EMERGENCY DIESEL GENERATOR
ES	- ENGINEERED SAFETY FEATURE
FP	- FIRE PROTECTION SYSTEM
FW	- FEEDWATER SYSTEM
NM	- NEUTRON MONITORING BATTERY
NN	- UNKNOWN/UNSPECIFIED/OTHER
SA	- AUTOMATIC (REACTOR) DEPRESSURIZATION (ADS)
SP	- SPECIAL USE BATTERIES
ST	- STATION BATTERIES/CHARGERS
SW	- SERVICE WATER BUILDING BATTERIES/CHARGERS
SY	- SWITCHYARD BATTERIES/CHARGERS
UP	- UNINTERRUPTIBLE POWER SYSTEM (UPS)

ONE-LINE DESCRIPTIONS OF BATTERY AND BATTERY CHARGER EVENTS FOUND IN MUREG-0666

SY	NO	CONTROL NUMBER	EVENT DATE	LOCATION	STATUS	DESCRIPTION	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
R	0E3	022183	072778	BA NN 833	B U	SMOKE FROM 1 TERMINAL OF 1CC BATTERY 3C8		TERMINAL DFTV/CNNCTNS FOUND DEFECTIVE
C	PA1	016178	102076	RC NN E2201	N D	DC BUS-2 VOLTG FELL/VOLTG ON ASSOC AC BUSES FELL		CUPR LMTR & OUTPUT BRKR SETTING ERRONEOUS
W	BV1	021043	032078	BC NN E2713	N U	DECR #4 DC BUS VOLTAGE DUE TO A FAULTY BTRY CHGR		FAILD COLLECTR RESISTR IN CHRGR CNTRL CKI
W	HN1	014608A	042576	BC NN D2833	N U	BTRY CHARGER A WENT INTO OVERCHARGE		FAULTY CMCT ON CHARGER CONTROL TIMER
W	TP3	014709	051076	BC NN B2630	A U	BTRY CHGR TROUBLE ALARMD CHARGER FAN HAD TRPD		AC FAN MTR INDP EXPOSED WERE BLEW A FLSE
W	IP3	015138	060876	BC NN 813	A S U	# 31 BTRY CHGR AC BRKR TRIPD BATT CHGR INOP		PRESSURE SFNSOR FAILED TRIPPING BREAKER
W	PR2	014599	041476	BC NN 82133	B U	#12 BATTERY CHARGER FAILED DISABLED "B" DC POWER		VOLTAGE CNTRL CPD LOOSE IN ITS SOCKET
W	YR1	019476A	101477	BC NN 81210	M R T	NO. 2 BATTERY CHARGER TAKEN OUT OF SERVICE		FAILED BEARING
G	BF2	015394	070976	BA NN B3302	M U D	NEUTRON MONITORING BATTERY 2A MADE INOPERABLE		CNNCTR BROKEN OFF A CELL POST PERS ERFOR
G	BP1	015248A	063076	BC ST 829	M U	STATION BATTERY CHARGER FAILED		DEFECTIVE SILICON RECTIFIERS
G	RP1	015444	081276	BA DB 833	M T	EMERGENCY DIESEL GENERATOR DID NOT START ONE TO L		--NOSE BATTERY CONNECTION.
G	BP1	017704*	033077	BA UP B3304	N C D	4 NO OUTPUT FROM ALL UPS BATTERY BANKS		CONNECTORS NOT TIGHTENED DURING INSTAL
G	BP1	019025A	082977	BA FP B3302	N D	DIESEL FIRE PUMP "A" BATTERY FOUND WITH NO OUTPUT		CONNECTORS NOT TIGHTENED
G	BR1	019389	107177	BC NN B2206	B U	BATT CHGR DC OUTPT FUSE FAILD WHEN CHRGR BATT 2A-2		HI CURR/TEMP CAUSD SOLDERD LINKG SEPARATE
G	CO1	022101A	062778	BC NN B2333	M T	1A 250V BTRY CHGR TIE BREAKER TRIPPED		POOR CNNCTR CNTCTS IN CURRENT MODULE
G	OR1	018553B	072977	BC FP B22	N U	FUSE FOUND BLOWN IN DIESEL FIRE PUMP BATTERY CHAR		--GER.
G	DR3	016265A	101876	BA NN A34	A D	BATTERY IN A DEGRADED CONDITION		CHARGER SUBJECTED BTRY TO "DEEP CYCLING"
G	DP3	016265R	101876	BC NN C00	A U	CHARGER SUBJECTED BTRY TO "DEEP CYCLING"		UNKNOWN CAUSE
G	OC1	018293R	062877	BC SY B2713	U U	BATTERY CHARGER FOR SWITCHING STATION BATTERY FOU		--ND OOS AFTER 11 DAYS
G	OC1	019222	092477	RA NN P2010	U T	BATTERY SYSTEM TAKEN OUT OF SERVICE		REPLACED 12 WEAK CELLS-NORMAL END OF LIFE
G	OC2	018164	031777	BC NN C23	U U	UNITS BATTERY CHARGER APPARENTLY INOPERABLE		FAULTY INDUCTIVE CURRENT CONTROL CIRCUIT
G	VY1	016217A	101376	RA UP A34	M R U	UPS-1B CNTRL PWR BTRY VOLTAGE WAS LOW		CNTRL BATT CHRNGNG POWER SUPPLY FAILED
G	VY1	016217B	101376	BC UP B21	M R U	CNTRL BTRY CHARGING POWER SUPPLY FAILED		INOPERATIVE VOLTAGE REGULATOR CIRCUIT

APPENDIX K
ADDITIONAL INFORMATION CONTAINED IN BATTERY AND BATTERY CHARGER
ONE-LINE DESCRIPTIONS

CODES USED IN LER ONE-LINE DESCRIPTIONS

NSSS VENDOR		FAILURE CAUSE		TYPE EVENT	
CODE	DESCRIPTION	CODE	DESCRIPTION	CODE	DESCRIPTION
B	BABCOCK & WILCOX	00	UNKNOWN	B	RECURRING COMMON CAUSE
C	COMBUSTION ENGINEERING	01	PERSONNEL OPERATION	U	COMMON CAUSE
M	METTINGHOUSE	02	PERSONNEL MAINTENANCE	U	RECURRING
G	GENERAL ELECTRIC	03	PERSONNEL TESTING	U	COMMAND FAULT
-----		04	DESIGN/FABRICATION/CONSTRUCTION/QUALITY CONTROL	U	RECURRING COMMAND FAULT
EVENT CLASSIFICATION		05	DEFECTIVE PROCEDURES	U	COMMON CAUSE COMMAND FAULT
-----		06	EXTREME ENVIRONMENT	U	RECURRING COMMON CAUSE COMMAND FAULT
CODE		08	CORROSION	BLANK	RANDOM
DESCRIPTION		10	NORMAL WEAR/NATURAL END OF LIFE	-----	
-----		11	ELECTRICAL MALFUNCTION	ACTIVITY RESULTING IN DISCOVERY	
CODE		12	MECHANICAL MALFUNCTION	-----	
DESCRIPTION		13	PIECE PART FAILURE	CODE	
-----		14	LOW SPECIFIC GRAVITY	DESCRIPTION	
D	FREQUENCY	15	STRATIFICATION	-----	
T	AGE	16	HIGH ELECTROLYTE SOLUTION LEVEL	A	TESTING (UNSPECIFIED)
U	UNKNOWN	17	LOW ELECTROLYTE SOLUTION LEVEL	B	NORMAL LOAD TESTING
-----		18	INSUFFICIENT CHARGE	C	MONTHLY TESTING
COMPONENT		20	DEFECTIVE/WEAK CELLS	D	WEEKLY TESTING
-----		21	VOLTAGE REGULATOR MALFUNCTION	E	QUARTERLY TESTING
CODE		22	CURRENT LIMITER MALFUNCTION	F	REFUELING TESTING
DESCRIPTION		23	CURRENT CONTROLLER MALFUNCTION	G	18 MONTH TESTING
-----		24	VOLTAGE LIMITER MALFUNCTION	H	3 YEAR TESTING
BA - BATTERY		25	THERMAL OVERLOAD PROTECTION	M	MAINTENANCE
BC - BATTERY CHARGER		26	COOLING FAN/VENTILATION MALFUNCTION	N	NORMAL PLANT OPERATION
		27	CHARGE CONTROL MALFUNCTION	R	RECORDS REVIEW
		28	CHARGE CONTROL TIMER MALFUNCTION	U	UNKNOWN
		29	RECTIFIER PROBLEM	-----	
		30	SHORT CIRCUIT	FLAGGING FIELD	
		32	ELECTROLYTE DILUTION	-----	
		33	FAULTY CABLE/CONNECTORS	CODE	
		34	CHARGER MALFUNCTION	DESCRIPTION	
		-----		-----	
		FAILURE MODE		-----	
		-----		CODE	
		DESCRIPTION		DESCRIPTION	
		-----		-----	
		A	REDUCED CAPABILITY	A	FAILED COMPONENT CAUSED AN ACCIDENT
		B	NO OUTPUT	B	COMPONENT FAILED TO MITIGATE AN ACCIDENT
		C	UNKNOWN/UNSPECIFIED/OTHER	C	SAFETY SIGNIFICANT
		D	HIGH CURRENT/VOLTAGE OUTPUT	D	CELL # NOT KNOWN
		E	LOW OUTPUT VOLTAGE	E	CELL # NOT KNOWN
		F	HIGH AC RIPPLE ON DC OUTPUT	F	FAIL # AND CELL # NOT KNOWN
		G	MAINTENANCE REPLACEMENT	N	FROM NSIC DATA BASE
		H	TEST NOT PERFORMED		
		T			

SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
AM	- AREA MONITOR SYSTEM
DB	- EMERGENCY DIESEL GENERATOR
ES	- ENGINEERED SAFETY FEATURE
FP	- FIRE PROTECTION SYSTEM
FW	- FEEDWATER SYSTEM
NM	- NEUTRON MONITORING BATTERY
NN	- UNKNOWN/UNSPECIFIED/OTHER
SA	- AUTOMATIC (REACTOR) DEPRESSURIZATION (ADS)
SP	- SPECIAL USE BATTERIES
ST	- STATION BATTERIES/CHARGERS
SW	- SERVICE WATER BUILDING BATTERIES/CHARGERS
SY	- SWITCHYARD BATTERIES/CHARGERS
UP	- UNINTERRUPTIBLE POWER SYSTEM (UPS)

 ADDITIONAL INFORMATION CONTAINED IN BATTERY AND BATTERY CHARGER ONE-LINE DESCRIPTIONS

EVENT #	PLANT	CONTROL NUMBER	EVENT DATE	COMP	MANUFACTURE NO	VOLTAGING	REPAIR	FLAGGING	CELL #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
B CR3	017166A	011277	BA					F		INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B CR3	017166B	020277	BA					F		INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B CR3	017166C	020977	BA					F		INCORRECT PILOT CELLS TESTED FOR 3A/B BATTERIES	IDENTIFICATION STICKERS NOT MOVED
B CR3	021165	040578	BA	E355				E		WRONG BTRY CELLS MONITORED FOR WEEKLY BATT SURV	PERSONNEL NOT FOLLOWING PROCEDURES
B CR3	C33100	071481	BA	C173	125			A	NA	STATION BATTERY SHORTED DURING MAINTENANCE	PERSONNEL ERROR. CAUSED REACTOR TRIP
B DB1	020443	011978	BA	G185	125					IN BTRY CELL 32 ELECTROLYTE S.G. DECRS .003 OUT	ELEC. STRAT. DUE TO LO BTRY LOADING
B DB1	021587	042778	BA	C742	024				4	4 CELLS OF ENGINE BTRY W/ ELECTROLYTE BELOW PLATE	ELEC. ADDED BROUGHT CELLS UP TO NORMAL
B DB1	022362	090578	BA					D	NA	STATION BATTERIES WKLY SURV TEST NOT DONE ON TIME	MISUNDERSTANDING BTWN PERSONNEL
B DB1	025397	020879	BA	C742					4	ELECTROL LEVEL IN 4 CELLS FOUND LO IN DSL ENG STA-	-RING BTRY. DIESEL STILL STARTED
B DE3	015532	081876	BA		125			D	NA	125-VDC INSTR & CNTRL BATTERIES NOT LOAD TESTED	DECTV PROC. WRONG DATA IN SURV PRINTOUT
B DE3	022183	072778	BA	E355	125					SMOKE FROM 1 TERMINAL OF I&C BATTERY 3CB	TERMINAL DECTV/CNNCTNS FOUND DEFECTIVE
B TI2	023084*	111278	BC	E355					NA	CHRGRS 2-2A/B FUSE BLEW NO CHRGR FOR BANK 2-2>B	DEFECTIVE GATING FILTER MODULES
C AR2	026489	052279	BA					D	NA	SURVEILLANCE NOT PERFORMED ON STATION BATTERIES	PERSONNEL OVERSIGHT
C AR2	026704	080979	BC	P319					NA	BATTERY CHARGER 2031 FAILED. DC OUTPUT LAMP SOCK-	-ET BURNED UP DUE TO HIGH HEAT+VOLT+DUST
C AR2	027809	121179	BC	P319				1	NA	BATTERY CHARGER 2032 AC BREAKER TRIPPED	CURRENT SURGED WHEN SHIFTING TO FLOAT
C AR2	039245*	110581	BC		125				NA	OUTPUT BREAKER OF BATTERY CHARGER 2034 TRIPPED OP-	-EN TWICE. NO CAUSE COULD BE FOUND
C CCI	021533	050378	BA	E355	125				125	VDC BTRY 22 CELL 54 ICV BELOW MIN VOLTAGE	CAUSE UNKNOWN
C CCI	037262	050581	BA	E355	125					VOLT OF CELL 18 OF 125 VDC BATTERY 12 FOUND .08V -	-BELOW MINIMUM. FULL CAPACITY AVAILABLE
C CC2	017344	021777	BA	E355	125			2	NA	#11 125 VDC BATTERY INADVERTENTLY TAKEN OUT OF SE-	-VICE. SUPERVISOR GAVE PERMISSION
C MI2	026979	080379	BA	C173				2	4	VARIOUS CELLS REPLACED IN 2018 BTRY (4 CELLS)	REDUCTION IN CELL VOLT. FULL CAPACITY
C PA1	016178	102076	BC	W120	125				NA	DC BUS-2 VOLTG FELL+VOLTG ON ASSOC AC BUSES FELL	CURR LMR & OUTPUT BRKR SETTING ERRONEOUS
C PA1	025917	040479	BA	G185				C	2	2 CELLS IN STATION BATTERY #2 BURST WHILE TAKING -	-VOLTAGE READINGS. FULL CAPACITY AVAIL
C PA1	036300*	010681	BA	W120					NA	OUTPUT BREAKER FOR BOTH STATION BATTERIES WERE OP-	-ENED FOR 1 HOUR. PERSONNEL ERROR
C SL1	020067	121677	BC	C173					NA	OUTPUT LOST FROM "AB" BATTERY CHARGER	POWER SUPPLY BKR TRIPPED FOR NO REASON
C SL1	037762	062481	BC						NA	SURVEILLANCE REQUIREMENTS NOT MET ON "AB" BATTERY-	-CHARGER. MISINTERPRETATION OF TECH SPEC
C SL1	038775	091881	BC	C173					NA	1A BATTERY CHARGER SHUTDOWN ON HIGH VOLTAGE	HIGH VOLTAGE DEVICE FOUND DEFECTIVE
M 3V1	016357	102476	BA	G185						VOLTAGE DECREASED IN CELL 48 BY MORE THAN 0.05V	UNKNOWN. CELL 48 FROM BTRY 3, 1000 A.H.
M 3V1	017117A	020477	BA	G185					NA	SURVEILLANCE TEST NOT PERFORMED ON #3 & #4 STATIO-	-N BATTERIES. PERSONNEL ERROR
M 3V1	017117B	020477	BC	G185					NA	SURVEILLANCE TEST NOT PERFORMED ON CHARGER, ASSOC-	-IATED WITH #3 & #4 STATION BTRY. PERSON
M 3V1	021243	032078	BC	L015	125			3	NA	DECK #4 DC BUS VOLTAGE DUE TO A FAULTY BTRY CHRGR	FAILD COLLECTR RESISTR IN CHRGR CNTRL CAT

 ADDITIONAL INFORMATION CONTAINED IN BATTERY AND BATTERY CHARGER ONE-LINE DESCRIPTIONS

UNION	PLANT	CONTROL NUMBER	EVENT DATE	CLMP	MANUFACTURER'S	VOLTAG REG	OUTPUT	FACILITY	FAILURE	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
W	BV1	022136	080478	BC	W120				NA	#4 STATION BTRY CHRGR OUTPUT BRKR TRIPPED	IMPRPR JP OF CKTBRK.CAUSE OF TRP UNKNOWN
W	BV1	028147	092179	BA	G195					CELL #6 OF BATTERY NO. 1 COULD NOT HOLD ORIGINAL -	-VOLTAGE. FULL BATTERY CAPACITY AVAIL.
W	BV1	037757	061581	BC		125			NA	#2 BATTERY CHARGER OUTPUT BREAKER FAILED OPEN	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
W	BV1	031347	080581	BC		125			NA	#2 BATTERY CHARGER OUTPUT BREAKER TRIPPED OPEN	EXCESSIVE HEAT CAUSED THERMAL OVERLOAD
W	BV1	038825	091081	BC				2	NA	#4 STATION BATTERY CHARGER TAKEN OUT OF SERVICE	BAD ELECTRICAL CONNECTION IN OUTPUT
W	BV1	039154	101781	BA	G195					2 2 OF 60 CELLS VOLTAGE FOUND DRIPPED BY .05 VDC	NO CAUSE GIVEN,BATTERY HAD FULL CAPACITY
W	DC1	025543	032379	BC		125		A	NA	125 VDC EQUALIZING CHARGE TOO HIGH, FAILED INVERT-	-ER, CAUSED SCRAM AND SI. NO CAUSE
W	DC2	021633	060778	BA	E355			1		CD PLANT BTRY CELL 89 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W	DC2	021632	051578	BA	E355			1		AB PLANT BTRY CELL 35 BELOW MIN SPECIFIC GRAVITY	EXACT CAUSE NOT DETERMINED
W	DC2	039127	131981	BA						SURVEILLANCE NOT PERFORMED ON "N" TRAIN BATTERY	PROCEDURE LACKED SIGNOFF
W	HN1	014603A	042576	BC	W120				NA	BTRY CHARGER A WENT INTO OVERCHARGE	FAULTY CNTCT ON CHARGER CONTROL TIMER
W	HN1	014603B	042576	BC	W120				NA	VOLTG REG SPIKING TO 200 AMPS THEN SHUTTING OFF	FAULTY PHASING CRD IN CURRENT LIMITER CRT
W	IP3	014709	051076	BC	W120				NA	BTRY CHRGR TROUBLE ALARMED CHARGER FAN HAD TRPD	AC FAN MTR INOP EXPOSED WIRE BLEW A FUSE
W	IP3	015139	060876	BC					NA	# 31 BTRY CHRGR AC BRKR TRIPD BATT CHKGR INOP	PRESSURE SENSOR FAILED TRIPPING BREAKER
W	IP3	036207	012481	BC	W120			1	NA	OUTPUT FROM CHARGER #32 DISCOVERED DRIPPING	VOLTAGE AND CURRENT CONTROLLER REPLACED
W	IP3	038257	070681	BC	F013				NA	BATTERY CHARGER #32 DISCOVERED TRIPPED	FAILED OP AIR FLOW SENSOR SWITCH
W	JF1	021235A	041878	BA	C173	125				2 2 CELLS IN SW BLDG "A" BATT BANK 1 FAILED T.S. REQ	CAUSE COULD NOT BE DETERMINED
W	JF1	021235B	041878	BA	C173	125		1		2 2 CELLS IN SW BLDG B BATT BANK 2 FAILED T.S. REQ	CAUSE COULD NOT BE DETERMINED
W	JF1	027181	090579	BA				D	NA	QUARTERLY AUXILIARY BUILDING BATTERY VERIFICATION-	-NOT PERFORMED ON TIME. PERSONNEL
W	JF1	032332A	061280	BA	E355			2		3 SW BLDG B BTRY SYS LOW SPECIFIC GRAVITY	BATT PLACED ON EQUALIZE & S.G. ACCEPTABLE
W	JF1	032332B	082580	BA	E355			2		3 SW BLDG B BTRY SYS LOW SPECIFIC GRAVITY	NO EXTERNAL CAUSE FOR LOW SPECIFIC GRAY
W	JF1	032504	082580	BC	G080			1	NA	SW B DC DISTRIBUTION SYS INOP NO OUTPUT FROM BATT-	-CHRGR 4. HV S/D RELAY ACTUATED
W	JF1	032587	091180	BA	E355			1	NA	SW BLDG "A" BATT SYS LD BATT CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN
W	JF1	033007	102180	BA	E359			2	NA	SW "A" BTRY SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM POST PROX/ACID RESIDUE/DESIGN
W	JF1	033163	102880	BA	E355			1	NA	SW BLDG "A" BATT SYS LOW CELL SPECIFIC GRAVITY	CLOSE TERM PROX/ACID RES/POST SEAL DESIGN
W	Y61	039196	101981	BA	G165	125				3 CELL TO CELL RESISTANCE IN 3 CELLS FOUND HIGH	CORROSION OF TERMINAL CONNECTIONS
W	NA1	026565	062679	BA	C173			D	NA	7 DAY SURVEILLANCE OF EMERGENCY DIESEL GENERATOR -	-BATTERIES EXCEEDED INTERVAL. PROCEDURAL
W	NA1	026656	073179	BA	E355			D	NA	DIESEL GENERATOR BATTERIES SURVEILLANCE NOT DONE	TIME LAG IN IMPLEMENTING NEW PROCEDURES
W	NA1	036491A	022881	BA	C173			D	NA	18 MONTH SURVEILLANCE ON D.C. DISTRIBUTION SERVICE-	-E SYSTEM NOT DONE. PERSONNEL OVERSIGHT
W	NA1	036491B	022881	BC	C173			D	NA	18 MONTH SURVEILLANCE ON D.C. DISTRIBUTION SERVICE-	-B SYSTEM NOT DONE. PERSONNEL OVERSIGHT

 ADDITIONAL INFORMATION CONTAINED IN BATTERY AND BATTERY CHARGER ONE-LINE DESCRIPTIONS

PLANT	CONTROL NUMBER	EVENT DATE	COMP	MANUFACTURER'S OR LATING	FLAUGHTING	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
W NA1	171672	120181	BA			N 1J EMERGENCY D/G INOP CELL 5,6, BELOW 1.2	D/G BATTERY NEAR END OF USEFUL LIFE
W YA2	036466*	021881	BA	E355		C 4 BATTERIES FOR 2J & 2H DIESEL GENERATORS FAILED SUR- NA DATA FROM TWO TESTS ON 2J DIESEL BATTERY FOUND NO-	-VEILLANCE TEST, 4 CELLS REPLACED -T USABLE. NOT COMPARED WITH INITIAL CHG
W YA2	036417	022081	BA	E355		D NA DIESEL DRIVEN WEEKLY BATTERY INSPECTION NOT DONE	PROCEDURES WERE DEFECTIVE
W PR1	026268	053179	BA			D NA INDIVIDUAL FLOAT CELL VOLT MEAS NOT DONE IN STATI-	-ON BATTERY TEST. PERSONNEL OVERSIGHT
W PR1	030917	033180	BA			NA #12 BTRY CHRGR FAILED TO PROVIDE NORMAL OUTPUT	FIRING CARD B NOT PROVIDING PULSE TO SCH
W PR2	014599	041476	BC	E355		NA #12 BATTERY CHARGER FAILED DISABLED *B* DC POWER	VOLTAGE CNTRL CRD LOOSE IN ITS SOCKET
W R02	015515	071076	BA	6185		NA BATTERY B LEADS WERE REMOVED RENDERING BATT INOP	PERG FAILED TO COMPLY W/ T.S. 3-7
W R02	021899	071678	BA			C 2 PLASTIC TOP OF 2 STATN *A* BATT CELLS ON FIRE	RESISTNC HEATG OF STRAP-CELL TERMINAL
W SA1	020738A	020178	BA	E355	125	NA 1C 125V BATTERY VOLTAGE LOW	1C1,1C2 BATT CHARGER D.C. BRKR; TRPD
W SA1	020738B	020178	BC	E355	125	1 NA 1C1,1C2 BATT CHARGER D.C. BRKRS TRIPPED	UNKNOWN CAUSE
W SA1	032162	072180	BA		024	NA 92 DAY & 18 MON SURV NOT DONE ON 24 V STARTG BATT	ELECTRICIAN NOT COMPLETING JOB
W SA1	038334	091891	BA	W059		4 NA BATTERY CABLE CLAMP FOUND ARCING AND CRACKED	CLAMP WAS REPLACED ON #2 FIRE PUMP BTRY
W SA2	038319	072481	BC	E355		24 NA 2C1 BATTERY CHARGER DISCOVERED TRIPPED. VOLTAGE -	-SETTING WAS INCORRECTLY SET
W SA2	038327	081281	BC	E355	028	NA 2B1 BATTERY CHARGER WOULD NOT PICK UP 28 VDC LOAD	HIGH VOLTAGE CUT-OUT ACTUATED
W SA2	039583	090681	BA	V115		NA RAD MONITOR 2R12A BATTERY PACK FAILED	NO CAUSE GIVEN
W SE1	032339	080780	BA	E147		D/G BTRY 18-B CELL 51 SHORTED AND FAILED	NO CAUSE GIVEN
W SE1	032342A	081280	BA	E147		3 D/G BTRY 18-B CELLS 49,50,51 DISCHARGED	INADEQUATE PROCEDURE
W SE1	032342B	081380	BA	E147		3 D/G BTRY 18-B CELLS 49,50,51 DISCHARGED	INADEQUATE PROCEDURE
W SU2	169141	081981	BC			M NA SMOKE DET SYS INOP BTRY CHRGR LOST POWER	FAULTY POWER SUPPLY CARD IN CHARGER
W SU2	038470	090681	BA	P435		SOMKE DETECTOR BATTERY FOUND NOT TO TAKE A CHARGE	NO CAUSE GIVEN
W SU2	038935A	100181	BA	E355		NA SMOKE DETECTOR BATTERY FAILED	CHARGER NOT CHARGING BATTERY
W SU2	038936B	100181	BC	E355		NA BATTERY CHARGER FOR SMOKE DETECTOR BATTERY FAILED	NO CAUSE GIVEN
W TR1	014563	032476	BA	C173		D NA ESF DC PWR SUPPLIES SURV REQ PERFORMD AT WRNG FREQ	PROCEDURE DID NOT USE FREQ REV BY I.S.
W TR1	020985	031778	BA	E226	125	D NA 125 VDC ELECTRICAL SYS OP NOT VERIFIED WK OF 2-26	MAINT PERG FAILED TO INSURE SURV COMPLETED
W TR1	025211A	011979	BA	E226	125	D NA 125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL
W TR1	025211B	011979	BC	E226	125	D NA 125 VDC ELECTRICAL SYSTEM NOT VERIFIED	PERSONNEL
W TR1	032622	090380	BA			NA DIESEL-DRIVEN AFWP FAILED TO START FROM MANUAL SIG	FAILED STARTING BATTERY
W TU3	022961A	122277	BA	C173		D NA EQUALIZING CHARGES ON STATION BATTERIES NOT PERFU-	-RMD. PERSONNEL ERROR, FULL CAPACITY AVL
W TU3	022961B	122977	BA	C173		D NA EQUALIZING CHARGES ON STATION BATTERIES NOT PERFU-	-RMD. PERSONNEL ERROR, FULL CAPACITY AVL

 ADDITIONAL INFORMATION CONTAINED IN BATTERY AND BATTERY CHARGER ONE-LINE DESCRIPTIONS

SYSTEMS	PLANT	CONTROL NUMBER	EVENT DATE	COMP	MANUFACTURERS	VOLTAGE	REPT. TYPE	FLAGGING	CELL #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G	BP1	017704*	033077	BA	E355					D NA NO OUTPUT FROM ALL UPS BATTERY BANKS	CONNECTORS NOT TIGHTENED DURING INTAL
G	BP1	018096A	042177	BA						RDS BATTERY B+ CELL 27 FOUND TO HAVE LOW SPECIFIC GRAVITY OF 1.191. FULL CAPACITY AVAIL	-GRAVITY OF 1.191. FULL CAPACITY AVAIL
G	BP1	018096B	042777	BA					10	SPECIFIC GRAVITY OF 10 MARGINAL CELLS ADJUSTED OF-	-RDS BATTERY B+ FULL CAPACITY AVAILABLE
G	BP1	018462A	061677	BA	E355					WATER ADDED TO CELL 27 OF RDS BATTERY "B"	NO CAUSE GIVEN FOR LOW WATER LEVEL
G	BP1	018462B	061677	BA	E355					SPECIFIC GRAVITY OF CELL 27 OF RDS BATTERY B LOW	WATER ADDED THEN TESTED TOO SOON
G	BP1	019023A	082977	BA	E355					C NA DIESEL FIRE PUMP "A" BATTERY FOUND WITH NO OUTPUT	CONNECTORS NOT TIGHTENED
G	BP1	019023B	082977	BA	E355					C NA DIESEL FIRE PUMP "B" BATTERY FOUND FAILED WITH NO-	-OUTPUT. DISCHR WITH NO APPARENT CAUSE
G	BP1	019472A	092977	BA	E355					WATER ADDED TO CELL 12 OF RDS BATTERY "A"	NO CAUSE GIVEN FOR LOW WATER LEVEL
G	BP1	019472B	092977	BA	E355					SPECIFIC GRAVITY OF CELL 12 OF RDS BATTERY "A" LOW	WATER ADDED, CHARGE INSUFFICIENT TO MIX
G	BP1	019542A	100877	BA	E355				3	WATER ADDED TO 3 CELLS OF RDS BATTERY "D"	NO CAUSE GIVEN FOR LOW WATER LEVEL
G	BP1	019542B	102077	BA	E355				C 3	SPECIFIC GRAVITY OF 3 CELLS OF RDS BATTERY "D" LOW	WATER ADDED, MIXING WAS INADEQUATE
G	BP1	020176	122277	BA					8	SPECIFIC GRAVITY ON RDS BATTERY "A", CELL 12 LOW	EQUALIZING CHARGE FOR 8 HOURS CORRECTED
G	BP1	021357	050476	BA	E355				3	FIRE PUMP DIESEL STARTG BTRY A CELLS 1,3,5 LO	-- ELECTROLYTE SOLN, EXACT CAUSE UNKNOWN
G	BP1	021917	052576	BA	E355				3	FIRE PUMP DIESEL STARTG BTRY "A" CELLS 2,4,6 LO--	ELECTROLYTE SOLN, INADQ MAINTENANCE PROC
G	BP1	022654	083178	BA	E355					RDS BATTERY A+ CELL 12 LO SPECIFIC GRAVITY READING	EXACT CAUSE UNKNOWN
G	BP1	027985	110179	BA	E355					SPECIFIC GRAVITY OF CELL 48 OF RDS BATTERY C LOW	CELL REPLACED, WOULD NOT TAKE EQUAL CHARGE
G	BP1	030237	012480	BA	E355					RDS C BTRY CELL 14 LOW SPECIFIC GRAVITY RDG	DEFECTIVE CELL REPLACED
G	BP1	031176	050180	BA	E355					RDS BTRY "A" CELL 2 LOW SPECIFIC GRAVITY RDG	CELL DID NOT RESPOND ADQ TO EQUALIZG CHRQ
G	BP1	031848	071080	BA	E355				2	RDS C BTRY CELLS 39,34 LOW SPECIFIC GRAVITY RDG	CELL DID NOT RESPOND ADQ TO EQUALIZG CHRQ
G	BP1	032023	071880	BA	E355					RDS C BTRY PILOT CELL UNIT-9 INTERNAL RESISTANCE--	-INCRS, CAUSE UNKNOWN
G	BP1	032297	080980	BA	E355				5	RDS C BTRY CELLS 13,39,36 LOW SPECIFIC GRAVITY	VENDOR RELOW INCRS IN FLOAT VOLTAGE LEVEL
G	BP1	032656	091180	BA	E355					RDS D BATTERY CELL 12 LOW SPECIFIC GRAVITY RDG	CELL DID NOT ADQ RESPOND TO EQUALIZG CHRQ
G	BP1	033544	121180	BA	E355				21	21 CELLS OF RDS "A" BATTERY LOW SPECIFIC GRAVITY	CELL TERMINALS INADQ CLEANED BY MAINT PER
G	BP1	033637	122380	BA						D NA DC BATTERY MONTHLY TESTS OVERDUE	INADQ ADQ IN CONTROLS & PERSONNEL ERROR
G	BP1	037334	010281	BA	E355					RDS CH D BATTERY CELL 56 HAD LOW SG, WOULD NOT RES-	-POND TO EQUALIZING CHARGE.
G	BP1	039112	081581	BA						FOUND PILOT CELL IN CH A RDS POWER SUPPLY WITH A -	-HIGH ELEC LEVEL, POSSIBLY OVERFILLED
G	BP1	039592	083181	BA	E355					LOW SG IN CELL 43 OF ST BTRY, CELL FOUND CRACKED.-	-THIS LEAD TO DILUTION, CRACKED WHEN MOVED
G	BP1	039785	091581	BA	E355					"A" RDS BTRY CELL #5 LOW SPECIFIC GRAVITY	CELL DIDNT RESPOND ADQ TO EQUALIZG CHRQ
G	BRL	019389	122177	BC						NA BATT CHRGR DC DUTPT FUSE FAILD WHEN CHRQ BATT 28-2	HI CURR/TEMP CAUSD SOLDER LINKG SEPARATE
G	BRL	025637A	032979	BA	G16: 125					NA BATTERY 192 VOLTAGE FELL TO 142.5V THEN ROSE TO -	-118V. CORRUPTD AND LOOSE BTRY CONNECT

 ADDITIONAL INFORMATION CONTAINED IN BATTERY AND BATTERY CHARGER ONE-LINE DESCRIPTIONS

SYMBOL	PLANT	CONTROL NUMBER	EVENT DATE	CDR P	MANUFACTURERS	VOLTAG	REPAIR	FLAGGING	CELL #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G BR1		025637B	032779	BA	G185	125				NA BTRY 1B1 VOLTAGE FELL TO 96.8V THM ROSE TO 118V	CORRODED AND LOOSE BTRY CONNECTORS
G BR2		014651	021276	BA						MONTHLY INSTEAD OF QUARTERLY BATTERY P.T. PERFORMED	WRONG P.T. SCHEDULED BY MISTAKE
G C01		022101A	062778	BC	E355	250				NA 1A 250V BTRY CHRGR TIE BREAKER TRIPPED	POOR CNNECTR CNCTCS IN CURRENT MODULE
G C01		022101B	062778	BC	E355	250				NA 1A 250V BTRY CHRGR INPUT BREAKER TRIPPED	LOOSE CNNECTN AT CHRGR INPUT BKRR PHASE A
G C01		037646	050581	BC	E355					NA HIGH RIPPLE FROM BATTERY CHARGER WHICH FAILED INV-	ENTER 1A. FAILED SCR
G C01		037739	052881	BA	E355					NA SG TESTS FOR 125V 1A&B AND 250V 1B NOT PERFORMED -	PROPERLY. PERSONNEL USED WRONG HYDROM
G DA1		030982	041780	BA						D NA WKLY BATT SURV DOCUMENTATION NOT COMPLETED	PERSONNEL ERROR-NONLIC. OPERATIONS PERS
G DA1		171665	120881	BC	P319	024				N NA BATTERY CHARGER OUTPUT INCORRECT	UNKNOWN
G DR1		018553A	072977	BA	U125					D NA DIESEL FIRE PUMP BATTERIES FAILED TO START DIESEL	FAILED FUSE FROM BATTERY CHARGER CIRCUIT
G DR1		018553B	072977	BC	U125					NA FUSE FOUND BLOWN IN DIESEL FIRE PUMP BATTERY CHAR-	GER.
G DR2		039116	102181	BA	G185					D NA QUARTERLY STORAGE BATTERY SURVEILLANCE DONE 3 DAY-	S LATE. OVERSIGHT BY OPERATING SHIFT
G DR3		016265A	101876	BA	G185	250				BATTERY IN A DEGRADED CONDITION	CHARGER SUBJECTED BTRY TO "DEEP CYCLING"
G DR3		016265B	101876	BC	G185	250				NA CHARGER SUBJECTED BTRY TO "DEEP CYCLING"	UNKNOWN CAUSE
G DR3		020953	032878	BA	G185	048				4 24748 V BTRY FAILED THE REFUELING OUTAGE DISCHRG-	TEST. 4 CELLS REPLCD NAT'L END OF LIFE
G DR3		025951	042479	BA		250				D NA UNIT 2'S BATTERY NOT RETURNED TO NORMAL LINEUP	BREAKER COULD HAVE BEEN SHUT AT ANY TIME
G DR3		036569	030381	BA	G185					D NA WEEKLY STORAGE BATTERY SURVEILLANCE DONE 4 DAYS L-	ATE. OVERSIGHT BY OPERATING SHIFT
G EN1		021475*	060476	BC	E355					D NA HEAT-SENSITIVE XSTR ON BATT CHRGR FIRING MODUL CRD	SHOULD BE A NON-HEAT-SENSITIVE TRANSISTOR
G EN1		021719	062778	BA	E355					WKLY PILOT CELL SURV OF 1C D/G BTRY NOT COMPLET--	ED ON TIME. PERSONNEL OVERSIGHT
G EN1		027782	112679	BA						F CELL SURVEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT
G EN2		022203	081676	BA	G190					F WKLY PILOT CELL SURV OF PLANT BATT NOT COMPLETED--	ON TIME. NOTICES ROUTED TO ABSENT PERS
G EN2		026557	071879	BA						F CELL SURVEILLANCE REQUIREMENT NOT PERFORMED	PERSONNEL OVERSIGHT
G EN2		030651*	032580	BC	E355					NA EMER STATION BATT CHRGR 26,2J FAILED TO HOLD LOAD	VOLTG CNTRL & CURR LMT MODULES TUNED
G EN2		030711A	032780	BC	E355					NA STATION BATT CHRGR 2A,2B FAILED TO MAINTAIN LOADS	SILICON CNTRL RECTIFIERS NEEDED LOAD BALANC
G EN2		030711B	032780	BC	E355					NA STATION BATT CHRGR 2C FAILED TO MAINTAIN LOAD	CURRENT LIMIT MODULE NEEDED ADJUSTMENT
G EN2		033991	081180	BA						NA DC BATT GROUND ON 2B STATION SERVICE BATTERY	NO CAUSE GIVEN
G EN2		032781A	032381	BA	G080					POST TREATMENT MON 2D11-K615A BATTERY DRAINED	BATTERY CHARGER 2AB 24748 VDC FAILED
G EN2		032981B	032381	BC	G080	048				24748 VDC BATTERY CHARGER FOUND NOT CHARGING	NO CAUSE GIVEN
G EN2		036943A	040781	BA	G185					E 2 ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF ST -	BTRYS 2R42-5001A&B. PERSONNEL ERROR
G EN2		036943B	040781	BA	G185					E 2 ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF ST B-	TRYS 2R42-5001A&B. PERSONNEL ERROR
G EN2		036943C	040781	BA	G185					E 2 ELECTROLYTE LEVEL FOUND HIGH IN SOME CELLS OF DIE-	SEL GENERATOR BATTERY. PERSONNEL ERROR

ADDITIONAL INFORMATION CONTAINED IN BATTERY AND BATTERY CHARGER ONE-LINE DESCRIPTIONS

PLANT	CONTROL NUMBER	EVENT DATE	CUMP	MANUFACTURERS	VOLTAG	OR LATT	AI	GN	EG	R	W	T	M	TIME	FLAGGING	CELL	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
G EN2	0369430	040781	BA	G185													E 2 ELECTROLYTE LEVEL FOUND LOW IN SOME CELLS OF DIESEL GENERATOR BATTERY. PERSONNEL ERROR	
G FP1	019457	102077	BA	G185													1 STATION BATTERY "B" FOUND TO HAVE CRACKED CELL NO CAUSE KNOWN FOR CRACKED CELL #22B	
G FP1	021433	053178	BA														LO S.G. OF BTRY A2 CELL 1 BAD CELL IN BATTERY	
G FP1	026922	090479	BA	G185													LEAKING CELL NOTED IN BATTERY "B". BATTERY TEMPORARILY INOP WHILE CELL JUMPED	
G FP1	031743*	062880	BA							024							2 DIESEL FIRE PUMP 24V BATT CELLS A2-B, B2-1 LOW S.G. CHARGER DCS DURING SURVEILLANCE	
G FP1	033290	111760	BA	G185													2 STATION BTRY B MADE INOP TO JUMP A CELL CELL #8 POOR PERFORMANCE DUE TO AGE	
G FP1	171911	123081	BA							024							NA LOW VOLTAGE FROM DIVISION I 24 VDC BATTERIES, CAUSED ERRATIC READINGS ON LRM & SRM INST	
G M11	014479	040776	BA	C173													NA SWITCHYARD BTRY SURVEILLANCE NOT PERFORMED W/IN REQ TIME PERIOD. PERSONNEL ERROR	
G M01	166730A	061981	BA							250							NA 250 VDC BATTERY INADVERTENTLY DISCHARGED PERS DISCONNECTED TEMP BATTERY CHARGER	
G M01	166730B	061981	BC							250							NA TEMPORARY BATTERY CHARGER TAKEN OUT OF SERVICE PERSONNEL ERROR, CAUSED BTRY TO DISCHARGE	
G DC1	019293A	062877	BA							125	264						NA ONE OF TWO SWITCHING STATION BATTERIES FOUND DCS - FOR 11 DAYS. BATTERY CHARGER FAILED	
G DC1	019293B	062877	BC							125	264						NA BATTERY CHARGER FOR SWITCHING STATION BATTERY FOUND DCS AFTER 11 DAYS	
G DC1	021477A	052478	BA														NA D/G BTRY LOAD TESTING NOT PERFORMED IN TIME FAILED TO ADHERE TO SURVEILLANCE SCHEDULE	
G DC1	021497B	052478	BA														NA STATION BTRY LOAD TESTING NOT PERFORMED IN TIME FAILED TO ADHERE TO SURVEILLANCE SCHEDULE	
G DC1	023298A	121378	BA														NA D/G BTRY NOT TESTED/MONITORED W/IN TIME INTERVAL FAILED TO ADHERE TO SURVEILLANCE SCHEDULE	
G DC1	023298B	121378	BA														NA STATION BTRY NOT TEST/MONITOR W/IN TIME INTERVAL FAILED TO ADHERE TO SURVEILLANCE SCHEDULE	
G DC1	030599A	022880	BA														NA MAIN STATION BTRY SURV TEST NOT PERFORMED PLANT PERS FAILED TO ADHERE TO SURV SCHEDULE	
G DC1	030599B	022880	BA														NA DIESEL GENERATOR BTRY SURV TEST NOT PERFORMED PLANT PERS FAILED TO ADHERE TO SURV SCHEDULE	
G DC1	038737	091181	BA	E355													NA BATTERY SURVEILLANCE PROCEDURES FOUND NOT TO FULLY COMPLY WITH NEW REQUIREMENTS.	
G PB3	G14211	G12976	BA	E355													E B BTRY CAPACITY BELOW DESIGN CELL S.G. IN LRNG, PARTIAL ACIO RPLCD	
G P11	027950A	122379	BC	E226	125	264											C NA SWITCHYARD 125 VDC BATTERY CHARGER FAILED NO CAUSE GIVEN	
G P11	027950B	122479	BC	E226	125	24											C NA SWITCHYARD 125 VDC BACKUP BATTERY CHARGER FAILED NO CAUSE GIVEN	
G P11	033999	082180	BC	E355	125												NA "A" 125 VDC CONTROL BATT CHARGER INOPERABLE VOLTAGE REGULATOR ELECTRONIC MODULES RPLCD	
G DC1	019222	092477	BA	G185	250												D 12 BATTERY SYSTEM TAKEN OUT OF SERVICE REPLACED 12 WEAK CELLS, NORMAL END OF LIFE	
G DC2	018164	031777	BC	G185	250												NA UNITS BATTERY CHARGER APPARENTLY INOPERABLE FAULTY INDUCTIVE CURRENT CONTROL CIRCUIT	
G DC2	019460	060977	BC	G185	250												NA BATTERY CHARGER SUPPLYING CURRENT TO BATTERY FOUND LOW. FLOATING POTENTIOMETER SET LOW	
G VY1	016217A	101376	BA														NA UPS-1B CNTRL PWR BTRY VOLTAGE WAS LOW CNTRL BATT CHRGNG POWER SUPPLY FAILED	
G VY1	016217B	101376	BC														NA CNTRL BTRY CHARGING POWER SUPPLY FAILED INOPERATIVE VOLTAGE REGULATOR CIRCUIT	
G VY1	019407A	031877	BA														A NA UPS-1B ALARMED DUE TO LOW VOLTAGE, CAUSED SCRAM CAPACITOR FAILED IN CHARGING POWER SUPPLY	
G VY1	019407B	031877	BC														A NA UPS-1B CONTROL CHARGING POWER SUPPLY FAILED FAILED CAPACITOR IN ON/OFF CIRCUITRY	

 ADDITIONAL INFORMATION CONTAINED IN BATTERY AND BATTERY CHARGER ONE-LINE DESCRIPTIONS

UNIT	PLANT	CONTROL NUMBER	EVENT DATE	COMP	MANUFACTURER'S	VOLTAG	RETIME	FLAGS	CELL #	FAILURE MODE DESCRIPTION	FAILURE CAUSE DESCRIPTION
6	VY1	021749	061978	BC		125				NA AC INPUT PRKR TO C41 BATT CHRGR TRPD OPEN	
6	VY1	C25519	031779	BC	E355					NA CONTROL CHARGING POWER SUPPLY FAILED	SPURIOUS TRP OF AC BRKR IN AN ELEC STORM NO CAUSE GIVEN. CAUSED BATTERIES DISCH