

File Eff Tech Specs

Draught Collins

Note on copy

Calculated

done

7/26

METROPOLITAN EDISON COMPANY Subsidiary of General Public Utilities Corporation

Subject RADIOLICAL EFFLUENT TECH. SPEC. - TMI-2

Location Reading

To DISTRIBUTION LIST

Date July 21, 1979
GQM

As discussed at the July 19, 1979 meeting with the NRC, please review the draft of the subject Tech. Specs. and submit comments to Roy Harding (Trailer 19) at TMI by 8:00 A.M. Tuesday, July 24, 1979.

Comments will be reviewed by Roy Harding and compiled into a single list for distribution at the inhouse meeting on Wednesday, July 25 at 1:30 P.M. in the Superintendent's Conference Room, of the Processing Center at TMI.

Following the inhouse meeting a draft will be prepared and submitted at the meeting with the NRC on Friday, July 27 in the North Auditorium at 1:30 P.M.

Comments should be made on the attached form.

Also enclosed please find page 6-4 of the draft tech. specs. missing from most copies.

J. Brummer will provide instrumentation, locations and designators.

L. W. Harding
L. W. Harding
Ext. 289, 290
(Catalytic)

LWH:tas
File: 63.0050.0005.0000
Attachments

cc: J. Collins (NRC)
J. Baigly (NRC)

Baigly
DISTRIBUTION LIST

<u>HP</u>	<u>Waste Management</u>	<u>Consultants</u>	<u>Others</u>
D. Dubiel	R. McGoey	T. Potter (PLSG)	J. Mudge
L. Landry	G. Kunder	S. Porter (Porter-Gertz)	J. Herbein
B. Good	J. Logan	S. Gertz (Porter-Gertz)	E. Blake
D. Limroth	J. Daniels		G. Miller
	B. Rusche		R. Arnold
	J. Barton		J. Brummer
	T. Hillard		G. Hitz

Licensing

J. Hilbish D. Reppert
J. Thorpe D. G. Mitchell

INTER-OFFICE MEMORANDUM

TMI-2 RECOVERY MODE TECH. SPEC. COMMENT FORM

Page #	Tech. Spec. #	Comment or Question

ADMINISTRATIVE CONTROLS

- d. type of waste (e.g., spent resin, compacted dry waste, evaporator bottoms),
- e. type of container (e.g., LSA, Type A, Type B, Large Quantity), and
- f. solidification agent (e.g., cement, urea formaldehyde).

The radioactive effluent release reports shall include unplanned releases from the site to unrestricted areas of radioactive materials in gaseous and liquid effluents on a quarterly basis.

The radioactive effluent release reports shall include any changes to the PROCESS CONTROL PROGRAM (PCP) made during the reporting period.

MONTHLY REACTOR OPERATING REPORT

6.9.1.10 Routine reports of operating statistics and shutdown experience shall be submitted on a monthly basis to the Director, Office of Management and Program Analysis, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, with a copy to the Regional Office of Inspection and Enforcement, no later than the 15th of each month following the calendar month covered by the report.

Any changes to the OFFSITE DOSE CALCULATION MANUAL shall be submitted with the Monthly Operating Report within 90 days in which the change(s) was made effective. In addition, a report of any major changes to the radioactive waste treatment systems shall be submitted with the Monthly Operating Report for the period in which the evaluation was reviewed and accepted by the (Unit Review Group).

PROMPT NOTIFICATION WITH WRITTEN FOLLOWUP

6.9.1.12

- j. Offsite releases of radioactive materials in liquid and gaseous effluents which exceed the limits of Specification 3.11.1.1 or 3.11.2.1.
- k. Exceeding the limits in Specification 3.11.1.4 or 3.11.2.6 for the storage of radioactive materials in the listed tanks. The written follow-up report shall include a schedule and a description of activities planned and/or taken to reduce the contents to within the specified limits.