June 23, 575 per method to rank 2-63 nev4, temp spess Gumb I. Villner Liwler #7 Date June 17, 1979 TSG-228 as of 6/27/79 hoh's hoh's RCS Pressure Indication Subject core for lest you Three Mile Island Location J. G. Herbein To As a result of the loss of the last "normal" RCS pressure indication (PT 400) as of 0600 hours this morning, the following is a list of options to be considered for RCS pressure control in order of preference. Maintain pressure by using DVM in Control Room within 365 psig + 25 psi or 4.473 to 4.836 volts, (See Attachment 4(b) and 2) as indicated in EP-12. of same perent, a

Maintain pressure by using RCS Sample Line Heise gage readings within 365 psig + 25 psi (See Attachment 4(a) and 1) as indicated in EP-12.

C. Maintain pressure by using RCP-2A cavity seal pressure readings within 375 psig + 25 psi (See Attachment 4(c) and 3).

If any two of the three items above, A., B. and C., have failed and if RCS Pressure and Volume Control System is available, system should be put in to 900 psig and found acceptable except for minor modifications. I have provided to 900 psig hydrotest with B&W and have received. Is this option operation. It is my understanding that the system has been hydrotested is eloded; ! in conjustion verbal acceptance per Bill Spangler, Dick Skillman and Greg Schaedel. win Am B letter has been written by B&W concurring with the above hydro and should be received on site by tomorrow, Monday, June 18, 1979. of above.

to operation

Due to the possible urgency of the matter, it is suggested that the system be made available for use as soon as possible with local rather than Control Room control, if such a change will help make the system available for use at an earlier date.

E. Redraw the bubble in the pressurizer and maintain pressure with the heaters as-indicated in Procedure 2-63. - CVI Ed.

- Use the Heise gage between DH-V-2 and DH-V-3 by opening DH-V-1 or DH-V-171. Consideration should be given to lowering RCS system pressure to the lowest allowable point such that the possibility of lifting of DH-Rl is minimized. Installation of at least one additional Heise gage of the same connection as the existing one should be considered for redundancy.
- G. As a last resort, Procedure Z-58 "RCS Pressure Control Solid System with Core Flood Tanks Floating" should be reviewed and PORC'd. It should be noted that possible problems with this procedure are:

ED 15 Why han the god god

8212020031 790617 FDR ADDCK 05000289

school

RCPIS .

J. G. Herbein RCS Pressure Indication Page Two

- 1. Possible loss of CF Tank level indication.
- 2. Possible loss of CF Tank pressure indication.
- 3. Need to drain CF Tanks (disposal and containment integrity).
- 4. Possible addition of nitrogen to RCS.
- 5. Possibility of loss of natural circulation due to gas in RCS following a rapid depressurization.

In conclusion, items A., B. and C. are strongly recommended. Items D., E., F. and G. should only be used in the given order only if the situation warrants the action.

Other items to be considered are:

- 1. Verifying the ability to change narrow range pressure transmitters to wide range pressure transmitters if the instruments are still functioning.
- 2. Installation of a Heise gage of MU-V-400.

The above items will be included in EP-12 as required.

If you have any further questions, please feel free to ask.

JDA/al ATTACHMENTS(5)

co: R. C. Arnold

- G. R. Capodanno
- D. K. Croneberger
- B. D. Elam
- J. Floyd
- R. W. Keaten
- G. Kunder
- J. B. Logan
- G. P. Miller
- J. P. Moore, Jr.
- R. F. Wilson

Data Collection File

- W. Spangler (B&W)
- D. Vollmer (NRC)

Stally Control
Control
Again

ROUTING A	ND TRANSMITTAL SLIP	Dete		
TO: (Name, office symbol, room number, building, Agency/Post)			Initials	Date
s. S. Newb	erry P-1132			
A. Ignatonis P-1132				
J. Wermeil P-802				
M. Gree	enberg P-802			
Action	File	Not	Note and Return	
Approval	For Clearance	Per	Per Conversation	
As Requested	For Correction	Pre	Prepare Reply	
Circulate	Circulate For Your Information		See Me	
Comment Investigate		Sign	Signature	
Coordination	Justify			
REMARKS				

Please provide comments by 7/2/79

If option D (RCS Pressure and Volume Control
System) is elected, which mest likely will be in
the aptron A or B should be used in
conjunction. The reason is that RCS pressure
should be monitored to provide a high & Palarm
between the RCS and pressure control system.
Option A is preferable because it can be contained,
monitored. Option C may not be available when
DO NOT use this form as a RECORD of approvals, concurrences, disposals,
clearances, and similar actions

R. H. Vollmer Room No.—Bidg.

R. H. Vollmer 542

Phose No. 27349.

5041-102

OPTIONAL FORM 41 (Rev. 7-76) Prescribed by GSA FPMR (41 CFR) 101-11.206

☆U. S. GPO:1978-0-261-647 3354

the standby pessure control system is in use because makeup pumps would be racked out and no flow to the RC pump seals be provided. also, since Ris pressure will be reduced, pressure set paints for options A, B, and c should be longited.

06/28/79