

Inter-Office Memorandum  
Review & Comment

Date: August 15, 1979  
TSG-362

Subject: Guidance on Turbine Bypass Valve Operation

*File  
Bypass/Vol Control  
System*

**GPU Service**

To: J. G. Herbein

Location:

TMI

Reference: Control of Natural Circulation Using the Turbine Bypass Valves,  
J. P. Moore to R. C. Arnold, TSG-333, dated August 6, 1979

There are several conditions which can contribute to an inaccurate prediction of the required turbine bypass flow demand to maintain primary plant conditions. To compensate for the inaccurate prediction, additional guidance is required for future turbine bypass valve operation. It is GPU Technical Support's recommendation that the following guidance be used during turbine bypass valve operation.

Maintain  $T_h$  in the "A" loop between 160° F and 170° F while in the natural circulation mode steaming the "A" OTSG. The target value is approximately 165° F. If  $T_h$  in the "A" loop increases to 168° F increase the turbine bypass valve position controller setting by 2%. Monitor  $T_h$  in the "A" loop and  $\Delta T$  in the "A" loop for 4 - 6 hours to establish any trend. If  $T_h$  in the "A" loop decreases to 162° F decrease the turbine bypass valve position controller setting by 2%. Monitor  $T_h$  in the "A" loop and  $\Delta T$  in the "A" loop for 4 - 6 hours to establish any trend. Obtain guidance and permission from the GPU Control Room Watch and/or the Shift Supervisor whenever opening or closing MS-V25A.

Careful consideration should be given to the effects of a "B" loop 'Burp' before altering the position of MS-V25A. The "B" loop 'Burp' causes cyclic variations in the primary temperature and will, therefore, impede control of  $T_h$  in the "A" loop.

Attached are revised copies of the curves included with the reference. These curves have been biased by the difference between the calculated position and the actual position obtained after the transition had reached equilibrium. Use of these curves and the additional guidance provided above is recommended for turbine bypass valve operation.

If you have any questions concerning this matter, please contact me at Extension 8268.

*John*

*I have no comments on this  
memo. I concur with the  
proposed actions.*

*(BD Elam)*  
B. D. Elam

*J. Wernell 8/17/79*

RMM/BDE/jb  
Attachments

cc: R. C. Arnold w/att.	F. G. Maus w/att.	GPU Control Room Watch w/att.
J. G. Herbein "	M. Konya "	TMI-2 Control Room "
R. F. Wilson "	W. H. Zewe "	Data Reduction File "
D. K. Croneberger "	J. Collins NRC "	J. P. Moore "
J. R. Floyd "	L. Rogers B&W "	

8212020172 7908150  
PDR ADDCK 050003000  
P




Figure 1




Figure 2




Figure 3




Figure 4