


THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201
November 19, 1982
QA-2124

E. A. BORGMANN
SENIOR VICE PRESIDENT

U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. J. G. Keppler
Regional Administrator

RE: WM. H. ZIMMER NUCLEAR POWER STATION UNIT I
10CFR50.55(e), ITEM M-65, SEISMIC CLEARANCE
DEFICIENCIES, DOCKET NO. 50-358, CONSTRUCTION PERMIT NO. CPPR-88, W.O. #57300
JOB E-5590, FILE NO. NRC-8, M-65

Gentlemen:

This letter constitutes an interim report concerning the subject condition, initially reported to the Commission on October 29, 1982 as a potentially reportable deficiency under the requirements of 10CFR50.55(e).

Task VI of the Zimmer Quality Confirmation Program identified on Nonconformance Report (NR) #Q-QAD-82-4218E that the inspection procedure for pipe support installation, MIP-13, does not contain seismic clearance criteria between pipe supports and cable trays, conduits and their associated supports as required by S&L Design Specifications H-2256 and H-2173.

In addition, it had been determined through project meetings that S&L would no longer compute, on a case by case basis, seismic deflection for conduit supported by vertical hangers greater than 60 inches in length and horizontal hangers greater than 50 inches and will generate specific seismic separation criteria for the above mentioned instances. S&L is currently evaluating and clarifying the seismic separation criteria in H-2256 and H-2173.

8212020257 821119
PDR ADOCK 05000358
S PDR

IE27
NOV 26 1982

Mr. J. G. Keppler
Regional Administrator
Region III
November 19, 1982
QA-2124
Page 2

CG&E Management Corrective Action Request No. 82-11 has been issued to resolve the above mentioned condition.


A walkdown of the as-built installations will be performed to assure compliance with these requirements. These actions are expected to be completed and a report submitted by July 31, 1983.

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Yours very truly,

THE CINCINNATI GAS & ELECTRIC COMPANY

By



E. A. Borgmann
Senior Vice President

FKP:plc

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
Attn: W. F. Christianson
Zimmer Project Inspector
Region III