



PROJECT NAME: Zion Station  
 PROJECT NO.: 8986-10  
 CLIENT: Commonwealth Edison Company  
 CALC. NO.: ATD-0206  
 TITLE: Organic Iodine Recirculation Spray Removal Rate

UNIT NO.: 1&2  
 FILE NO.: 4.6, 13.1  
 SYSTEM: CS  
 DIVISION: ATD

# TRIALS VQ

DESIGN CONTROL SUMMARY  
 DESIGN VERIFICATION  
 PAGE 1

SAFETY RELATED  NON SAFETY RELATED

REV. #	DATE	APPROVER	REVIEWER	PREPARER	IDENTIFICATION OF PAGES ADDED/REVISED/SUPERSEDED/VOIDED & REVIEW METHOD	REVIEW METHOD	STATUS
REV. 0	DATE 11/30/92	G. P. Lahti	W. J. Johnson	R. S. Hubner	Pages 1 through 81, all new calculation.	See page 81.	Verified Data
REV. 1	DATE 2-17-93	G. P. Lahti	W. J. Johnson	A. G. Klazura	Revised Page 1, Design Control Summary Sheet, to add Revision 1 information. Added Pages 82 thru 86 (Revision 1).	See Page 86	Verified
REV. 2	DATE 3-31-94	W. J. Johnson	W. E. DeLise	B. C. Schwartz	Revised Page 1, Design Control Summary Sheet, to add Revision 2 information Added Pages 87 through 91 (Revision 2)	See Page 91	Verified
REV. #	DATE	APPROVER	REVIEWER	PREPARER			

DEC 1 1928 067

SUN 22 93 4421

9406220248 940525  
 PDR ADDCK 05000295  
 PDR



Calc. For Organic Iodine Recirculation Spray Removal	
Rate	
X	Safety-Related
	Non-Safety-Related

Calc. No. ATD-0206	
Rev. 2	Date
Page 87	of

Client Commonwealth Edison Company	
Project Zion Station - Units 1 & 2	
Proj. No. 9140-98	Equip. No.
System Code	Subsystem

Prepared by	Date
Reviewed by	Date
Approved by	Date
Division	File No.

1. PURPOSE

The purpose of this calculation is to determine the removal rate of organic iodine from containment atmosphere due to containment spray operation during the recirculation mode. This revision will use a calculated value for the containment recirculation flowrate from a single RHR pump.

2. DESIGN INPUT

All design input parameters are the same as those provided in Revision 0 and 1 of this calculation except as follows:

- 1) The Post-LOCA recirculation flowrate through the CS header is (Page 6 of Reference 1): 1450 gpm
- 2) The Nozzle Pressure Drop 12.06 psi
- 3) Geometric Mean Water Drop Diameter Case 1 524.5 microns
- Standard Deviation of Geometric Mean Diameter Case 1 1.884
- Geometric Mean Water Drop Diameter Case 2 393.8 microns
- Standard Deviation of Geometric Mean, Case 2 1.970

3. ASSUMPTIONS

The assumptions and engineering judgement used in this revision are the same as those presented in Revisions 0 and 1 to this calculation.

As an additional assumption in Revision 2, drop size and standard deviation Equations of Revision 0 can be extrapolated to the average nozzle pressure drop associated with 1450 gpm for 171 nozzles, i.e.,  $Q=8.48$  gpm/nozzle.

4. APPROACH

All information presented in the Approach Section of Revisions 0 and 1 to this calculation is applicable to this revision. The computer code, SPRT-PC, (Reference 2) will be used to calculate the organic iodine removal rate due to the containment spray. SPRT-PC was also used in Revisions 0 and 1.



Calc. For Organic Iodine Recirculation Spray Removal			
Rate			
X	Safety-Related		Non-Safety-Related

Calc. No. ATD-0206	
Rev. 2	Date
Page 88	of

Client Commonwealth Edison Company	
Project Zion Station - Units 1 & 2	
Proj. No. 9140-98	Equip. No.
System Code	Subsystem

Prepared by	Date
Reviewed by	Date
Approved by	Date
Division	File No.

5. CALCULATION

All information presented in the Calculation Section of Revisions 0 and 1 to this calculation is applicable to this revision except as follows:

- The  $\Delta P$  parameter which is the pressure drop of a nozzle is determined using Equation 7 from Page 11 of Revision 0. SPIRT-PC input parameters DMEANG and SIGMAG which pertain to the geometric mean diameter and the standard deviation of the geometric mean, respectively, are determined using the Equations 8a, 8b, 9a and 9b from Page 42 of Revision 0. The changes are noted as follows:

	Revision 0 & 1		Revision 2	
	DMEANG	SIGMAG	DMEANG	SIGMAG
Case 1	.0328 cm	1.993	.05245 cm	1.884
Case 2	.03032 cm	2.009	.03938 cm	1.970
Bulk				
Flow gpm	2460		1450	
$\Delta P$ psi	34.7		12.06	


The value for all other SPIRT-PC parameters are as described in Revisions 0 and 1.

As was done in Revisions 0 and 1, two (2) SPIRT-PC computer program runs were made (Case 1 and Case 2). The cases are defined in Revisions 0 and 1 and differ only in CS header flow, the geometric mean, the standard deviation of the geometric mean, and the case title.

6.0 RESULTS

SPIRT-PC calculated iodine recirculation spray removal rates follow.

SPIRT-PC Input for $\Delta P = 12.06\text{psi}$			SPIRT-PC Output
SPIRT-PC Case - 1450 gpm	Geometric Mean Diameter (Microns)	Standard Deviation of Geometric Mean Diameter	Organic Iodine Removal Rate (Per Hour)
1	524.5	1.884	.01704
2	393.8	1.970	.01794



Calc. For Organic Iodine Recirculation Spray Removal	
Rate	
<input checked="" type="checkbox"/>	Safety-Related
<input type="checkbox"/>	Non-Safety-Related

Calc. No. ATD-0206	
Rev. 2	Date
Page 89	of

Client Commonwealth Edison Company	
Project Zion Station - Units 1 & 2	
Proj. No. 9140-98	Equip. No.
System Code	Subsystem

Prepared by	Date
Reviewed by	Date
Approved by	Date
Division	File No.

As was done with the previous revision, the smaller organic removal rate will be selected since the smaller removal rate will result in conservative radiological evaluations where the post-accident containment atmosphere is concerned. Thus the organic iodine removal rate for the recirculation phase is .01704 per hour.

#### 7. REFERENCES

1. Calculation Number ATD-0377, Rev. 0, RHR Pump Recirculation Flow.
2. Sargent & Lundy (S&L) validated computer program "SPIRT-PC, a computer program for calculating spray iodine removal constraints" S&L Program No. 03.7.366-1.0, Rev.0, 01-31-91.

**SARGENT & LUNDY**  
ENGINEERS

Calc. For Organic Iodine Recirculation Spray Removal			
Rate			
<input checked="" type="checkbox"/>	Safety-Related	<input type="checkbox"/>	Non-Safety-Related

Calc. No. ATD-0206	
Rev. 2	Date
Page 90	of

Client Commonwealth Edison Company	
Project Zion Station - Units 1 & 2	
Proj. No. 9140-98	Equip. No.
System Code	Subsystem

Prepared by	Date
Reviewed by	Date
Approved by	Date
Division	File No.

**anacom<sup>®</sup>**

REVIEW METHOD SHEET

Calc. No. ATD-0206  
 Revision 2  
 Page 91 fo Final  
 Proj. No. 9140-98  
 SAFETY RELATED

This calculation has been reviewed by me according to the method(s) checked below.

1. Computer Aided Calculations

a	Review to determine that the computer program(s) has been validated and documented, is suitable to the problem being analyzed, and that the calculation contains all necessary information for reconstruction at a later date.
b	Review to determine that the input data as specific for program execution is consistent with the design input, correctly defines the problem for the computer algorithm and is sufficiently accurate to produce results within any numerical limitations of the program.
c	Review to verify that the results obtained from the program are correct and within stated assumptions and limitations of the program and are consistent with the input.
d	Review validation documentation for temporary changes to listed, or developmental, or unique single application programs, to assure that methods used adequately validate the program for the intended application.
e <input checked="" type="checkbox"/>	Review of code input only, since the computer program has sufficient history of use at Sargent & Lundy in similar calculations.
f <input checked="" type="checkbox"/>	Review arithmetic necessary to prepare code input data.
g	Other:

2. Hand Prepared Calculations

a	Detailed review of the original calculation.
b	Review by an alternate, simplified, or approximate method of calculation.
c	Review of a representative sample of repetitive calculations.
d	Review of the calculation against a similar calculation previously performed.

3. Revisions

a	Editorial changes only.
b	Elimination of unapproved input data without altering calculation results.
c	Other:

4. Other


Reviewer: *W. E. De Lisle* Date: *3/22/94*